



ORDER #: \_\_\_\_\_ DATE: \_\_\_\_\_

PROJECT: \_\_\_\_\_

LOCATION: \_\_\_\_\_

CUSTOMER: \_\_\_\_\_

APPROVED: \_\_\_\_\_ DATE: \_\_\_\_\_

MODEL	O.D. OF CURB	QUANTITY
5555	51" X 51"	
5566	51" X 63"	
5578	51" X 75"	
5596	51" X 93"	
55102	51" X 99"	
6666	63" X 63"	
6678	63" X 75"	
6696	63" X 93"	
66102	63" X 99"	

FINISH: MILL (STANDARD)

☐ OTHER \_\_\_\_\_

ACRYLIC GLAZING:

OUTER	INNER
CLEAR	CLEAR
#2412 BRONZE	#2447 WHITE

CAUTION: WHEN INSTALLING THIS PRODUCT THE AREA BELOW THE UNIT MUST BE CLEAR OF OBSTRUCTIONS WHICH COULD IMPEDE THE RELEASE OF THE DOMES.



AUTOMATICALLY OPERATED ROOF VENT  
4LM7 ROOF CLASS 90  
UL LISTED UNITS ARE DESIGNED TO DROP  
OUT IN LESS THAN 5 MINUTES AT 500°F  
WHEN SUBJECTED TO THE STANDARD UL  
793 FIRE EXPOSURE TEST.

**Wasco** Part of  
**VELUX® Commercial**

VELUX Wells  
85 Spencer Dr, Unit A  
Wells, ME 04090  
1-800-88-VELUX  
veluxusa.com



Skylights pose an inherent risk of injury or death from fall throughs, and the safety of others is of the utmost importance to VELUX. VELUX recommends that the customer, building owner or manager use additional protection with the skylight such as an exterior or interior safety cage, to enhance long-term safety. The building owner or manager is responsible for providing fall protection around the skylight in accordance with OSHA regulations. VELUX also recommends that the building owner or manager restrict roof access only to personnel who have been cautioned as to the location of the skylights, and warned not to sit, step or walk on the skylights.

DATE: 05/2019 DRAWING NO.: CSOS REV 0 SHEET 1 OF 1

CSOS CURB MOUNT SHRINK-OUT SMOKE VENT