

CERTIFICATE NUMBER AC105.4

CERTIFICATE OF APPROVAL

This is to certify that Sherwin Williams UK Limited has carried out the certification of FIRETEX® FX6010 intumescent paint in accordance with the Jensen Hughes FireMark scheme rules document – ATS00 – for the certification of fire protection products in Australia. The products have also been assessed against the requirements of the specific product Technical Schedule ATS56 - Intumescent coatings to protect steel – and are approved for use subject to the conditions outlined in this document.

Sherwin Williams UK Limited

Avenue One, Station Lane, Witney, Oxfordshire, OX28 4XR, United Kingdom

Certified product	Technical schedule	Approved standard
FIRETEX® FX6010	ATS56 – Intumescent coating for steelwork 15 December 2025	AS 1530.4:2014 AS 4100:1998 (R2016)

Jensen Hughes project number: CER220027
 On behalf of Jensen Hughes

DocuSigned by:

 DFD1B30AAE994A5...

JASON JEFFRESS
 Vice President

JENSEN HUGHES
 FireMark



Issue date	30 March 2023
Re-issued date	15 December 2025
Certificate valid to	30 March 2028

1.0 Introduction

This certificate of approval is for the use of FIRETEX® FX6010 intumescent paint for the fire protection of structural steel. The products have been assessed against the requirements of Technical Schedule ATS56 and are approved for use as a fire resisting intumescent coating for the protection of structural steel.

The detailed scope is given in the tables in the approval matrix in section 2 of this certificate. These show the approved applications of the FIRETEX® FX6010 intumescent paint protecting the following structural steel sections:

- + I-section beams and columns
- + circular hollow columns
- + rectangular hollow column and beams.

The precise scope is given in the tables below, which show the total dry film thickness of all FIRETEX® FX6010 (excluding primer and top sealer) required to provide fire resistance periods in accordance with AS 1530.4:2014 of up to 120 minutes for I-section beams, rectangular hollow columns, circular hollow columns and rectangular hollow beams, 150 minutes for I-section columns.

The data referring to three-sided fire exposure of beams relates to beams supporting concrete floor slabs. Separate consideration is required where this is not the case.

The data shown are applicable to steel sections blast cleaned to AS 1627.9-2002, ISO 8501-1 SA2.5, or equivalent, and primed with a suitable and compatible primer. Specifications of surface preparations, primers and top sealers are available from Sherwin-Williams UK Limited, whose responsibility is to ensure that FIRETEX® FX6010 is compatible for use in respect of both ambient and fire conditions. The total dry film thickness of primer should not exceed that tested.

The data shown is applicable to FIRETEX® FX6010 applied by spray to horizontal, vertical, flexural and compression members supporting loads up to the maximum design loads specified in AS 4100:1998 (R2016). Specifications for other steel design temperatures are available from Sherwin-Williams UK Limited.

The approval relates to ongoing production. The product and/or its immediate packaging are identified with the manufacturer's name; the product name or number come up the Jensen Hughes FireMark name or name and mark, together with the Jensen Hughes FireMark certificate number and application where appropriate.

The data shown in the tables is based on assessments that comply with the criteria for acceptability now incorporated within the Jensen Hughes FireMark scheme.

The product is approved based on satisfying the requirements in Table 1 and the factory production control (FPC) audits carried out for each location where the product is manufactured for the Australian market. The audit report has been prepared and is retained in a confidential file by Jensen Hughes. General details are provided in Table 2.

All work and services carried out by Jensen Hughes are subject to and conducted in accordance with our standard terms and conditions. These are available on request.

Table 1 Basis of evidence

Evidence	Comments
Evidence of relevant testing and assessments provided	See Appendix A
Testing carried out within the last 5 years to validate ongoing quality and performance of the product	Yes
Independent sampling of tested product for traceability	Yes
Batch number confirmed	Yes
The deemed-to-satisfy requirements of technical schedule met	Yes
The manufacturing facilities accredited to ISO 9001:2015	Yes

Table 2 FPC audit report

Item	Detail
Audit company	Jensen Hughes
Audit objectives	<p>The objective of the audit is to:</p> <ul style="list-style-type: none"> <li data-bbox="425 1028 1394 1084">+ determine the conformity of the client's management system, or parts of it, with audit criteria, <li data-bbox="425 1095 1394 1151">+ determine the ability of the management system to ensure the client meets applicable contractual requirements, <li data-bbox="425 1162 1394 1219">+ determine the effectiveness of the management system to ensure the client can reasonably expect to achieve their specified objectives, <li data-bbox="425 1230 1394 1286">+ determine adequate process control of product manufacturing, <li data-bbox="425 1297 1394 1331">+ as applicable, identify areas for potential improvement in the management system.
Date of inspection	10 May 2023
Outcome	The audit satisfied the requirements of the Jensen Hughes FireMark scheme.

2.0 Formal scope of product certification

General product description

FIRETEX® FX6010 is a two-component, ultra-fast-drying, durable, intumescent fire protection coating that is designed to give rapid overcoating and handling times for fire resistance periods up to two hours for structural steel.

A representative image of the product is shown here.



3.0 Approval matrix

Table 1 I-Section / H-Section Beams 15 minutes
Required Thickness (mm) for a Design Temperature (°C)

The thickness is intumescent only. Results apply to beams with concrete slabs with 3-sided fire exposure.

Table 2 I-Section / H-Section Beams 20 minutes

Required Thickness (mm) for a Design Temperature (°C)

The thickness is intumescent only. Results apply to beams with concrete slabs with 3-sided fire exposure.

Table 3 I-Section / H-Section Beams 30 minutes

The thickness is intumescent only. Results apply to beams with concrete slabs with 3-sided fire exposure.

Table 4 I-Section / H-Section Beams 45 minutes

Section Factor (m ⁻¹)	Required Thickness (mm) for a Design Temperature (°C)																
	350	400	450	500	544	550	553	575	576	580	583	600	603	610	620	650	700
50	0.744	0.420	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
55	0.819	0.467	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
60	0.893	0.514	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
65	0.968	0.560	0.374	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
70	1.042	0.607	0.401	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
75	1.116	0.654	0.429	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
80	1.191	0.701	0.456	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
85	1.265	0.747	0.483	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
90	1.340	0.794	0.510	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
95	1.414	0.841	0.537	0.386	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
100	1.488	0.888	0.564	0.405	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
105	1.528	0.935	0.591	0.425	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
110	1.550	0.981	0.618	0.444	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
115	1.572	1.028	0.645	0.463	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
120	1.594	1.075	0.673	0.483	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
125	1.617	1.122	0.700	0.502	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
130	1.639	1.168	0.727	0.522	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
135	1.661	1.215	0.754	0.541	0.381	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
140	1.683	1.262	0.781	0.561	0.400	0.371	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
145	1.705	1.309	0.808	0.580	0.419	0.390	0.375	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
150	1.727	1.356	0.835	0.600	0.438	0.409	0.394	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
155	1.750	1.402	0.862	0.619	0.457	0.428	0.413	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
160	1.772	1.449	0.890	0.638	0.476	0.447	0.432	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
165	1.794	1.496	0.917	0.658	0.495	0.466	0.451	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
170	1.816	1.526	0.944	0.677	0.514	0.485	0.470	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
175	1.838	1.546	0.971	0.697	0.533	0.504	0.489	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
180	1.860	1.567	0.998	0.716	0.551	0.523	0.508	0.368	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
185	1.883	1.587	1.025	0.736	0.570	0.542	0.527	0.388	0.380	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
190	1.905	1.608	1.052	0.755	0.589	0.561	0.546	0.408	0.400	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
195	1.927	1.628	1.079	0.775	0.608	0.580	0.565	0.428	0.420	0.387	0.367	0.367	0.367	0.367	0.367	0.367	0.367
200	1.949	1.649	1.106	0.794	0.627	0.599	0.584	0.448	0.440	0.407	0.381	0.367	0.367	0.367	0.367	0.367	0.367
205	1.971	1.669	1.134	0.813	0.646	0.618	0.603	0.468	0.460	0.428	0.401	0.367	0.367	0.367	0.367	0.367	0.367
210	1.993	1.690	1.161	0.833	0.665	0.637	0.622	0.488	0.480	0.448	0.421	0.367	0.367	0.367	0.367	0.367	0.367
215	2.016	1.710	1.188	0.852	0.684	0.656	0.641	0.508	0.500	0.468	0.442	0.367	0.367	0.367	0.367	0.367	0.367
220	2.038	1.731	1.215	0.872	0.708	0.675	0.660	0.527	0.520	0.488	0.462	0.367	0.367	0.367	0.367	0.367	0.367
225	2.060	1.751	1.242	0.891	0.722	0.694	0.679	0.547	0.540	0.508	0.483	0.367	0.367	0.367	0.367	0.367	0.367
230	2.082	1.771	1.269	0.911	0.741	0.713	0.698	0.567	0.560	0.528	0.503	0.367	0.367	0.367	0.367	0.367	0.367
235	2.104	1.792	1.296	0.930	0.760	0.731	0.717	0.587	0.580	0.548	0.523	0.367	0.367	0.367	0.367	0.367	0.367
240	2.126	1.812	1.323	0.950	0.779	0.750	0.736	0.607	0.600	0.569	0.544	0.367	0.367	0.367	0.367	0.367	0.367
245	2.149	1.833	1.350	0.969	0.798	0.769	0.755	0.627	0.620	0.589	0.564	0.374	0.367	0.367	0.367	0.367	0.367
250	2.171	1.853	1.378	0.988	0.817	0.788	0.774	0.647	0.639	0.609	0.584	0.397	0.367	0.367	0.367	0.367	0.367
255	2.193	1.874	1.405	1.008	0.836	0.807	0.793	0.667	0.659	0.629	0.605	0.420	0.378	0.367	0.367	0.367	0.367
260	2.215	1.894	1.432	1.027	0.855	0.826	0.812	0.686	0.679	0.649	0.625	0.443	0.402	0.367	0.367	0.367	0.367
265	2.237	1.915	1.459	1.047	0.874	0.845	0.831	0.705	0.699	0.669	0.645	0.466	0.425	0.367	0.367	0.367	0.367
270	2.259	1.935	1.486	1.066	0.893	0.864	0.850	0.725	0.719	0.690	0.666	0.489	0.449	0.367	0.367	0.367	0.367
275	2.282	1.956	1.513	1.086	0.912	0.883	0.869	0.745	0.739	0.710	0.686	0.512	0.472	0.367	0.367	0.367	0.367
280	2.304	1.976	1.536	1.105	0.931	0.902	0.888	0.766	0.759	0.730	0.707	0.535	0.496	0.370	0.367	0.367	0.367
285	2.326	1.997	1.559	1.125	0.950	0.921	0.907	0.786	0.779	0.750	0.727	0.558	0.519	0.396	0.367	0.367	0.367
290	2.348	2.017	1.582	1.144	0.969	0.940	0.926	0.806	0.799	0.770	0.747	0.581	0.543	0.421	0.373	0.367	0.367
295	2.370	2.037	1.605	1.163	0.988	0.959	0.945	0.826	0.819	0.790	0.768	0.604	0.566	0.447	0.388	0.367	0.367
300	2.392	2.058	1.628	1.183	1.007	0.978	0.964	0.845	0.839	0.810	0.788	0.626	0.590	0.473	0.423	0.367	0.367
305	2.415	2.078	1.651	1.202	1.026	0.997	0.983	0.865	0.859	0.831	0.808	0.649	0.613	0.499	0.449	0.367	0.367
310	2.437	2.099	1.674	1.222	1.045	1.016	1.002	0.885	0.879	0.851	0.829	0.672	0.637	0.524	0.474	0.367	0.367
315	2.459	2.119	1.697	1.241	1.064	1.035	1.021	0.905	0.899	0.871	0.849	0.695	0.661	0.550	0.499	0.367	0.367
320	2.481	2.140	1.720	1.261	1.083	1.054	1.040	0.925	0.918	0.891	0.869	0.718	0.684	0.576	0.525	0.377	0.367
325	2.503	2.160	1.742	1.280	1.102	1.073	1.059	0.945	0.938	0.911	0.890	0.741	0.708	0.602	0.550	0.402	0.367
330	2.525	2.181	1.765	1.300	1.121	1.092	1.078	0.965	0.958	0.931	0.910	0.764	0.731	0.628	0.576	0.428	0.367
335	2.548	2.201	1.788	1.319	1.140	1.111	1.097	0.985	0.978	0.952	0.930	0.787	0.755	0.653	0.601	0.454	0.367
340	2.570	2.222	1.811	1.338	1.158	1.130	1.116	1.005	0.998	0.972	0.951	0.810	0.778	0.679	0.626	0.480	0.367
345	2.592	2.242	1.834	1.358	1.177	1.149	1.135	1.024	1.018	0.992	0.971	0.833	0.802	0.705	0.652	0.506	0.367
350	2.614	2.262	1.857	1.377	1.196	1.168	1.154	1.044	1.038	1.012	0.992	0.856	0.825	0.731	0.677	0.531	0.367
355	2.636	2.283	1.880	1.397	1.215	1.187	1.173	1.064	1.058	1.032	1.012	0.879	0.849	0.756	0.702	0.557	0.367
360	2.658	2.303	1.903	1.416	1.234	1.206	1.191	1.084	1.078	1.052	1.032	0.902	0.873	0.782	0.728	0.583	0.367
365	2.681	2.324	1.926	1.436	1.253	1.225	1.210	1.104	1.098	1.072	1.053	0.924	0.89				

The thickness is intumescent only. Results apply to beams with concrete slabs with 3-sided fire exposure.

Section Factor (m ⁻¹)	Table 51-Section / H-Section Beams 60 minutes Required Thickness (mm) for a Design Temperature (°C)																
	350	400	450	500	544	550	553	575	576	580	583	600	603	610	620	650	700
50	1.178	0.773	0.500	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
55	1.296	0.855	0.555	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
60	1.414	0.937	0.614	0.403	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
65	1.523	1.019	0.674	0.448	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
70	1.588	1.102	0.734	0.493	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
75	1.652	1.184	0.793	0.538	0.397	0.381	0.374	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
80	1.717	1.266	0.853	0.583	0.430	0.413	0.405	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
85	1.782	1.348	0.912	0.628	0.464	0.445	0.436	0.375	0.372	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
90	1.846	1.430	0.972	0.673	0.497	0.477	0.468	0.402	0.399	0.389	0.381	0.367	0.367	0.367	0.367	0.367	0.367
95	1.911	1.512	1.032	0.718	0.531	0.509	0.499	0.429	0.426	0.415	0.406	0.367	0.367	0.367	0.367	0.367	0.367
100	1.975	1.543	1.091	0.763	0.564	0.541	0.530	0.457	0.453	0.441	0.432	0.382	0.374	0.367	0.367	0.367	0.367
105	2.040	1.574	1.151	0.808	0.598	0.573	0.561	0.484	0.480	0.467	0.457	0.405	0.397	0.374	0.367	0.367	0.367
110	2.105	1.605	1.210	0.852	0.631	0.605	0.592	0.511	0.507	0.493	0.483	0.429	0.420	0.396	0.367	0.367	0.367
115	2.169	1.636	1.270	0.897	0.665	0.637	0.624	0.538	0.534	0.519	0.508	0.452	0.444	0.419	0.387	0.367	0.367
120	2.234	1.667	1.330	0.942	0.698	0.669	0.655	0.565	0.561	0.545	0.534	0.476	0.467	0.441	0.409	0.367	0.367
125	2.298	1.697	1.389	0.987	0.732	0.701	0.686	0.592	0.588	0.571	0.559	0.499	0.490	0.464	0.431	0.367	0.367
130	2.363	1.728	1.449	1.032	0.765	0.733	0.717	0.620	0.615	0.597	0.585	0.523	0.513	0.487	0.454	0.367	0.367
135	2.428	1.759	1.509	1.077	0.799	0.765	0.749	0.647	0.642	0.623	0.610	0.546	0.536	0.509	0.476	0.367	0.367
140	2.492	1.790	1.534	1.122	0.832	0.797	0.780	0.674	0.669	0.649	0.635	0.570	0.559	0.532	0.498	0.385	0.367
145	2.557	1.820	1.557	1.167	0.866	0.829	0.811	0.701	0.696	0.676	0.661	0.593	0.583	0.554	0.520	0.410	0.367
150	2.621	1.851	1.580	1.212	0.899	0.861	0.842	0.728	0.723	0.702	0.686	0.617	0.606	0.577	0.542	0.433	0.367
155	2.686	1.882	1.603	1.257	0.933	0.893	0.873	0.756	0.750	0.728	0.712	0.640	0.629	0.599	0.564	0.456	0.367
160	2.740	1.913	1.626	1.301	0.966	0.925	0.905	0.783	0.777	0.754	0.737	0.664	0.652	0.622	0.586	0.479	0.367
165	2.778	1.943	1.649	1.346	1.000	0.957	0.936	0.810	0.804	0.780	0.763	0.687	0.675	0.645	0.608	0.502	0.367
170	2.816	1.974	1.672	1.381	1.033	0.988	0.967	0.837	0.831	0.806	0.788	0.711	0.698	0.667	0.630	0.525	0.367
175	2.854	2.005	1.695	1.436	1.067	1.020	0.998	0.864	0.858	0.832	0.814	0.734	0.721	0.690	0.652	0.548	0.367
180	2.892	2.036	1.718	1.481	1.100	1.052	1.029	0.892	0.885	0.858	0.839	0.758	0.745	0.712	0.674	0.571	0.367
185	2.930	2.066	1.741	1.519	1.134	1.084	1.061	0.919	0.912	0.884	0.865	0.781	0.768	0.735	0.697	0.595	0.367
190	2.968	2.097	1.764	1.542	1.167	1.116	1.092	0.946	0.939	0.910	0.890	0.804	0.791	0.757	0.719	0.618	0.367
195	3.006	2.128	1.787	1.564	1.201	1.148	1.123	0.973	0.966	0.937	0.916	0.828	0.814	0.780	0.741	0.643	0.367
200	3.044	2.159	1.810	1.587	1.234	1.180	1.154	1.000	0.993	0.963	0.941	0.851	0.837	0.808	0.763	0.664	0.367
205	3.082	2.189	1.833	1.609	1.268	1.212	1.186	1.028	1.020	0.989	0.967	0.875	0.860	0.825	0.785	0.687	0.418
210	3.120	2.220	1.855	1.631	1.301	1.244	1.217	1.055	1.047	1.015	0.992	0.898	0.884	0.848	0.807	0.710	0.444
215	3.158	2.251	1.878	1.654	1.335	1.276	1.248	1.082	1.074	1.041	1.018	0.922	0.907	0.870	0.829	0.733	0.469
220	3.196	2.282	1.901	1.676	1.368	1.308	1.279	1.109	1.101	1.067	1.043	0.945	0.930	0.893	0.851	0.757	0.459
225	3.234	2.312	1.924	1.698	1.402	1.340	1.310	1.136	1.128	1.093	1.069	0.969	0.953	0.915	0.873	0.780	0.520
230	3.272	2.343	1.947	1.721	1.458	1.372	1.342	1.164	1.155	1.119	1.094	0.992	0.976	0.938	0.895	0.803	0.545
235	3.310	2.374	1.970	1.743	1.469	1.404	1.373	1.191	1.182	1.145	1.119	1.016	0.999	0.961	0.918	0.826	0.571
240	3.348	2.405	1.993	1.765	1.503	1.436	1.404	1.218	1.209	1.171	1.145	1.039	1.023	0.983	0.940	0.849	0.596
245	3.386	2.436	2.016	1.788	1.529	1.468	1.435	1.245	1.236	1.197	1.170	1.063	1.046	1.006	0.962	0.872	0.622
250	3.423	2.466	2.039	1.810	1.552	1.500	1.467	1.272	1.262	1.224	1.196	1.086	1.069	1.028	0.984	0.895	0.647
255	3.461	2.497	2.062	1.833	1.575	1.527	1.498	1.300	1.289	1.250	1.221	1.110	1.092	1.051	1.006	0.918	0.673
260	3.499	2.528	2.085	1.858	1.550	1.525	1.327	1.316	1.276	1.247	1.133	1.115	1.073	1.028	0.942	0.698	0.367
265	3.536	2.559	2.108	1.877	1.621	1.573	1.548	1.354	1.343	1.302	1.272	1.157	1.138	1.096	1.050	0.965	0.724
270	3.569	2.589	2.131	1.900	1.644	1.596	1.572	1.381	1.370	1.328	1.298	1.180	1.162	1.119	1.072	0.968	0.749
275	3.603	2.620	2.154	1.922	1.666	1.620	1.595	1.408	1.397	1.354	1.323	1.204	1.185	1.141	1.094	1.011	0.775
280	3.636	2.651	2.177	1.944	1.689	1.643	1.619	1.436	1.424	1.380	1.349	1.227	1.208	1.164	1.116	1.084	0.867
285	3.670	2.682	2.200	1.967	1.712	1.666	1.642	1.463	1.451	1.406	1.374	1.251	1.231	1.186	1.138	1.057	0.826
290	3.703	2.712	2.223	1.989	1.735	1.689	1.666	1.490	1.478	1.432	1.400	1.274	1.254	1.209	1.161	1.080	0.851
295	3.737	2.744	2.246	2.011	1.758	1.713	1.689	1.517	1.505	1.458	1.425	1.298	1.277	1.231	1.183	1.103	0.877
300	3.771	2.777	2.268	2.034	1.781	1.736	1.712	1.541	1.530	1.485	1.451	1.321	1.301	1.254	1.205	1.127	0.902
305	3.804	2.810	2.291	2.056	1.804	1.759	1.736	1.565	1.555	1.511	1.476	1.344	1.324	1.277	1.227	1.150	0.928
310	3.838	2.843	2.314	2.079	1.827	1.782	1.759	1.590	1.579	1.536	1.502	1.368	1.347	1.299	1.249	1.173	0.953
315	3.871	2.877	2.337	2.101	1.850	1.806	1.783	1.614	1.604	1.561	1.527	1.391	1.370	1.322	1.271	1.196	0.979
320	3.905	2.910	2.360	2.123	1.873	1.829	1.806	1.639	1.628	1.585	1.552	1.415	1.393	1.344	1.293	1.219	1.004
325	3.938	2.943	2.383	2.146	1.896	1.852	1.829	1.663	1.653	1.610	1.577	1.438	1.416	1.367	1.315	1.242	1.030

Section Factor (m ⁻¹)	Table 61-Section / H-Section Beams 75 minutes Required Thickness (mm) for a Design Temperature (°C)																	
	350	400	450	500	544	550	553	575	576	580	583	600	603	610	620	650	700	750
50	1.660	1.126	0.799	0.566	0.398	0.377	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
55	1.773	1.244	0.887	0.628	0.441	0.419	0.410	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367	0.367
60	1.886	1.361	0.977	0.702	0.508	0.479	0.469	0.404	0.401	0.390	0.382	0.367	0.367	0.367	0.367	0.367	0.367	0.367
65	1.998	1.479	1.067	0.775	0.565	0.539	0.529	0.458	0.455	0.443	0.434	0.385	0.377	0.367	0.367	0.367	0.367	0.367
70	2.111	1.586	1.157	0.848	0.627	0.599	0.588	0.513	0.509	0.496	0.486	0.434	0.426	0.408	0.375	0.367	0.367	0.367
75	2.224	1.640	1.247	0.922	0.689	0.660	0.647	0.567	0.563	0.549	0.538	0.484	0.475	0.451	0.421	0.367	0.367	0.367
80	2.336	1.714	1.337	0.995	0.751	0.720	0.707	0.621	0.617	0.602	0.591	0.533	0.524	0.499	0.467	0.379	0.367	0.367
85	2.449	1.789	1.427	1.069	0.813	0.780	0.766	0.675	0.671	0.655	0.643	0.583	0.573	0.548	0.513	0.422	0.367	0.367
90	2.562	1.863	1.515	1.142	0.875	0.841	0.825	0.730	0.725	0.708	0.695	0.633	0.623	0.596	0.559	0.465	0.367	0.367
95	2.674	1.937	1.561	1.215	0.937	0.901	0.885	0.784	0.779	0.760	0.747	0.682	0.672	0.644	0.605	0.508	0.367	0.367
100	2.826	2.012	1.607	1.289	0.999	0.961	0.944	0.838	0.833	0.813	0.799	0.732	0.721	0.692	0.650	0.550	0.390	0.367
105	3.012	2.086	1.652	1.362	1.060	1.021	1.004	0.893	0.887	0.866	0.851	0.781	0.770	0.741	0.696	0.593	0.426	0.367
110	3.198	2.161	1.698	1.436	1.122	1.082	1.063	0.947	0.941	0.919	0.903	0.831	0.819	0.789	0.742	0.636	0.461	0.367
115	3.384	2.235	1.744	1.509	1.184	1.142	1.122	1.001	0.995	0.972	0.955	0.880	0.868	0.837	0.788	0.679	0.496	0.367
120	3.532	2.309	1.790	1.537	1.246	1.202	1.182	1.055	1.049	1.025	1.008	0.930	0.917	0.885	0.834	0.722	0.532	0.367
125	3.563	2.384	1.836	1.563	1.308	1.262	1.241	1.110	1.103	1.078	1.060	0.979	0.966	0.934	0.879	0.764	0.567	0.389
130	3.594	2.458	1.882	1.589	1.370	1.323	1.300	1.164	1.157	1.131	1.112	1.029	1.015	0.982	0.925	0.807	0.603	0.416
135	3.625	2.532	1.927	1.615	1.432	1.383	1.360	1.218	1.211	1.184	1.164	1.078	1.064	1.030	0.971	0.850	0.638	0.443
140	3.656	2.607	1.973	1.641	1.494	1.443	1.419	1.273	1.265	1.237	1.216	1.128	1.113	1.078	1.017	0.893	0.673	0.470
145	3.687	2.681	2.019	1.667	1.529	1.504	1.478	1.327	1.319	1.290	1.268	1.177	1.162	1.127	1.063	0.936	0.709	0.497
150	3.718	2.747	2.065	1.693	1.553	1.533	1.523	1.381	1.373	1.343	1.320	1.227	1.211	1.175	1.109	0.978	0.744	0.524
155	3.749	2.801	2.111	1.719	1.576	1.556	1.546	1.435	1.427	1.395	1.372	1.277	1.260	1.223	1.154	1.021	0.780	0.551
160	3.780	2.856	2.157	1.744	1.600	1.580	1.570	1.490	1.481	1.448	1.425	1.326	1.309	1.271	1.200	1.064	0.815	0.578
165	3.811	2.910	2.202	1.770	1.623	1.603	1.593	1.526	1.522	1.501	1.477	1.376	1.359	1.320	1.246	1.107	0.850	0.605
170	3.842	2.964	2.248	1.796	1.647	1.627	1.616	1.549	1.545	1.531	1.520	1.425	1.408	1.368	1.292	1.150	0.886	0.632
175	3.874	3.018	2.294	1.822	1.671	1.650	1.640	1.572	1.568	1.554	1.543	1.475	1.457	1.416	1.338	1.192	0.921	0.659
180	3.905	3.072	2.340	1.848	1.694	1.674	1.663	1.595	1.591	1.577	1.566	1.518	1.506	1.484	1.383	1.235	0.956	0.686
185	3.936	3.126	2.386	1.874	1.718	1.697	1.687	1.618	1.614	1.598	1.589	1.541	1.532	1.513	1.429	1.278	0.992	0.713
190	3.967	3.181	2.431	1.900	1.741	1.720	1.710	1.641	1.637	1.622	1.611	1.563	1.554	1.535	1.475	1.321	1.027	0.740
195	3.998	3.235	2.477	1.926	1.765	1.744	1.733	1.664	1.660	1.645	1.634	1.585	1.577	1.557	1.517	1.364	1.063	0.767
200	4.029	3.288	2.523	1.951	1.788	1.767	1.757	1.687	1.683	1.668	1.657	1.608	1.599	1.580	1.539	1.406	1.098	0.794
205	4.060	3.343	2.569	1.977	1.812	1.791	1.780	1.709	1.705	1.691	1.680	1.630	1.622	1.602	1.561	1.449	1.133	0.821
210	4.091	3.397	2.615	2.003	1.836	1.814	1.804	1.732	1.729	1.714	1.703	1.653	1.644	1.624	1.584	1.492	1.169	0.848
215	4.122	3.451	2.661	2.029	1.859	1.838	1.827	1.755	1.752	1.737	1.726	1.675	1.666	1.646	1.606	1.524	1.204	0.875
220	4.153	3.506	2.706	2.055	1.883	1.861	1.851	1.778	1.775	1.760	1.749	1.698	1.689	1.668	1.628	1.546	1.240	0.902
225	4.184	3.543	2.741	2.081	1.906	1.885	1.874	1.801	1.797	1.783	1.771	1.720	1.711	1.691	1.650	1.567	1.275	0.929
230	4.215	3.572	2.768	2.107	1.930	1.908	1.897	1.824	1.820	1.805	1.794	1.743	1.734	1.713	1.672	1.589	1.310	0.956
235	4.246	3.601	2.795	2.132	1.953	1.932	1.921	1.847	1.843	1.828	1.817	1.765	1.756	1.735	1.695	1.611	1.346	0.983
240	4.277	3.630	2.822	2.158	1.977	1.955	1.944	1.870	1.866	1.851	1.840	1.788	1.778	1.757	1.717	1.633	1.381	1.010
245	4.309	3.659	2.848	2.184	2.000	1.979	1.968	1.893	1.889	1.874	1.863	1.810	1.801	1.780	1.654	1.417	1.037	
250	4.340	3.688	2.875	2.210	2.024	2.002	1.991	1.916	1.912	1.897	1.886	1.833	1.823	1.802	1.764	1.676	1.452	1.064
255	4.371	3.717	2.902	2.236	2.048	2.025	2.014	1.939	1.935	1.920	1.909	1.855	1.846	1.824	1.784	1.698	1.487	1.091
260	4.402	3.746	2.929	2.262	2.071	2.049	2.038	1.962	1.958	1.943	1.931	1.878	1.868	1.846	1.806	1.719	1.519	1.118
265	4.433	3.775	2.955	2.288	2.095	2.072	2.061	1.985	1.981	1.966	1.954	1.900	1.890	1.869	1.828	1.741	1.542	1.145
270	4.464	3.805	2.982	2.314	2.118	2.096	2.085	2.007	2.004	1.989	1.977	1.922	1.913	1.891	1.850	1.763	1.564	1.172
275	4.497	3.834	3.009	2.339	2.142	2.119	2.108	2.030	2.027	2.011	2.000	1.945	1.935	1.913	1.873	1.784	1.587	1.199
280	4.556	3.863	3.036	2.365	2.165	2.143	2.132	2.053	2.050	2.034	2.023	1.967	1.958	1.935	1.895	1.806	1.609	1.226
285	4.615	3.892	3.063	2.391	2.189	2.166	2.155	2.076	2.072	2.057	2.046	1.990	1.980	1.957	1.917	1.828	1.632	1.253
290	4.674	3.921	3.089	2.417	2.212	2.190	2.178	2.099	2.095	2.080	2.069	2.012	2.002	1.980	1.939	1.850	1.654	1.280
295	4.733	3.950	3.116	2.443	2.336	2.213	2.202	2.122	2.118	2.103	2.091	2.035	2.025	2.002	1.962	1.871	1.677	1.307
300	4.792	3.979	3.143	2.469	2.360	2.237	2.225	2.145	2.141	2.126	2.114	2.057	2.047	2.024	1.984	1.893	1.699	1.334
305	4.851	4.008	3.170	2.495	2.388	2.260	2.249	2.168	2.164	2.149	2.137	2.080	2.070	2.046	2.006	1.915	1.721	1.361
310	4.910	4.037	3.196	2.521	2.307	2.283	2.272	2.191	2.187	2.172	2.160	2.102	2.092	2.069	1.986	1.744	1.388	
315	4.969	4.06																

Table 7 I-Section / H-Section Beams 90 minutes

Required Thickness (mm) for a Design Temperature (°C)

Section Factor (m ⁻¹)	350	400	450	500	544	550	553	575	576	580	583	600	603	610	620	650	700	750
50	2.094	1.528	1.100	0.836	0.651	0.629	0.617	0.540	0.537	0.523	0.513	0.458	0.449	0.425	0.395	0.367	0.367	0.367
55	2.250	1.650	1.220	0.928	0.723	0.698	0.685	0.599	0.596	0.580	0.569	0.508	0.499	0.471	0.439	0.367	0.367	0.367
60	2.406	1.772	1.341	1.029	0.811	0.784	0.770	0.680	0.676	0.659	0.647	0.584	0.574	0.546	0.511	0.427	0.367	0.367
65	2.562	1.893	1.461	1.130	0.898	0.869	0.855	0.760	0.756	0.738	0.725	0.660	0.649	0.621	0.582	0.494	0.367	0.367
70	2.718	2.015	1.563	1.231	0.986	0.955	0.940	0.840	0.836	0.817	0.804	0.736	0.725	0.695	0.654	0.562	0.422	0.367
75	3.315	2.137	1.651	1.381	1.073	1.041	1.025	0.921	0.916	0.896	0.882	0.812	0.800	0.770	0.726	0.629	0.480	0.367
80	3.574	2.259	1.739	1.432	1.161	1.127	1.110	1.001	0.996	0.975	0.960	0.887	0.875	0.844	0.798	0.697	0.538	0.381
85	3.649	2.381	1.827	1.525	1.249	1.212	1.194	1.081	1.076	1.054	1.038	0.963	0.951	0.919	0.870	0.764	0.596	0.429
90	3.724	2.503	1.916	1.584	1.336	1.298	1.279	1.161	1.156	1.133	1.116	1.039	1.026	0.993	0.942	0.832	0.654	0.477
95	3.800	2.625	2.004	1.644	1.424	1.384	1.364	1.242	1.236	1.212	1.195	1.115	1.101	1.068	1.013	0.899	0.712	0.525
100	3.875	2.758	2.092	1.703	1.511	1.469	1.449	1.322	1.316	1.291	1.273	1.191	1.177	1.143	1.085	0.967	0.770	0.573
105	3.950	2.939	2.180	1.762	1.552	1.532	1.522	1.402	1.396	1.370	1.351	1.267	1.252	1.217	1.157	1.084	0.828	0.621
110	4.025	3.121	2.268	1.822	1.593	1.570	1.559	1.482	1.476	1.449	1.429	1.342	1.327	1.292	1.229	1.102	0.886	0.669
115	4.100	3.302	2.356	1.881	1.633	1.608	1.596	1.531	1.529	1.518	1.507	1.418	1.403	1.366	1.301	1.169	0.944	0.717
120	4.175	3.484	2.445	1.941	1.673	1.646	1.633	1.561	1.558	1.546	1.538	1.494	1.478	1.441	1.372	1.237	1.002	0.765
125	4.251	3.551	2.533	2.000	1.713	1.684	1.670	1.590	1.587	1.575	1.566	1.531	1.526	1.514	1.444	1.305	1.060	0.813
130	4.326	3.585	2.621	2.060	1.753	1.722	1.707	1.620	1.617	1.603	1.593	1.556	1.550	1.538	1.514	1.372	1.118	0.861
135	4.401	3.620	2.709	2.119	1.793	1.760	1.744	1.650	1.646	1.631	1.620	1.580	1.575	1.562	1.538	1.440	1.176	0.909
140	4.476	3.654	2.799	2.179	1.834	1.798	1.781	1.679	1.675	1.659	1.648	1.605	1.599	1.586	1.562	1.507	1.234	0.957
145	4.538	3.689	2.888	2.238	1.874	1.836	1.818	1.709	1.704	1.687	1.675	1.629	1.624	1.610	1.586	1.534	1.292	1.005
150	4.597	3.723	2.978	2.298	1.914	1.874	1.855	1.738	1.734	1.715	1.702	1.654	1.648	1.635	1.610	1.557	1.350	1.052
155	4.655	3.757	3.068	2.357	1.954	1.912	1.892	1.768	1.763	1.743	1.729	1.678	1.672	1.659	1.634	1.581	1.408	1.100
160	4.713	3.792	3.158	2.416	1.994	1.950	1.929	1.798	1.792	1.772	1.757	1.703	1.697	1.683	1.658	1.604	1.466	1.148
165	4.772	3.826	3.248	2.476	2.034	1.988	1.966	1.827	1.822	1.800	1.784	1.727	1.721	1.707	1.682	1.627	1.517	1.196
170	4.830	3.861	3.338	2.535	2.075	2.026	2.003	1.857	1.851	1.828	1.811	1.752	1.746	1.731	1.706	1.650	1.540	1.244
175	4.889	3.895	3.428	2.595	2.115	2.064	2.040	1.886	1.880	1.856	1.839	1.776	1.770	1.755	1.730	1.674	1.563	1.292
180	4.947	3.930	3.517	2.654	2.155	2.102	2.077	1.916	1.910	1.884	1.866	1.801	1.794	1.780	1.754	1.697	1.586	1.340
185	5.005	3.964	3.548	2.714	2.195	2.140	2.114	1.946	1.939	1.912	1.893	1.825	1.819	1.804	1.778	1.720	1.609	1.388
190	5.064	3.998	3.574	2.764	2.235	2.178	2.150	1.975	1.968	1.940	1.920	1.850	1.843	1.828	1.802	1.743	1.632	1.436
195	5.122	4.033	3.601	2.813	2.275	2.216	2.187	2.005	1.997	1.969	1.948	1.874	1.868	1.852	1.826	1.766	1.655	1.484
200	5.181	4.067	3.627	2.862	2.316	2.254	2.224	2.034	2.027	1.997	1.975	1.899	1.892	1.876	1.850	1.790	1.678	1.523
205	5.239	4.102	3.653	2.910	2.356	2.292	2.261	2.064	2.056	2.025	2.002	1.923	1.916	1.900	1.874	1.813	1.701	1.547
210	5.297	4.136	3.679	2.959	2.396	2.330	2.298	2.093	2.085	2.053	2.030	1.948	1.941	1.925	1.899	1.836	1.725	1.572
215	5.356	4.171	3.705	3.007	2.436	2.368	2.335	2.129	2.115	2.081	2.057	1.972	1.965	1.949	1.922	1.859	1.748	1.597
220	5.414	4.205	3.731	3.056	2.476	2.406	2.372	2.153	2.144	2.109	2.084	1.997	1.990	1.973	1.946	1.882	1.771	1.621
225	5.472	4.240	3.758	3.104	2.513	2.444	2.409	2.182	2.173	2.138	2.112	2.021	2.014	1.997	1.969	1.906	1.794	1.646
230	5.531	4.274	3.784	3.153	2.557	2.482	2.446	2.212	2.203	2.166	2.139	2.046	2.038	2.021	1.993	1.929	1.817	1.670
235	5.589	4.308	3.810	3.201	2.597	2.520	2.483	2.241	2.232	2.194	2.166	2.070	2.063	2.045	2.017	1.952	1.840	1.695
240	5.648	4.343	3.836	3.250	2.637	2.558	2.520	2.271	2.261	2.222	2.193	2.095	2.087	2.070	2.041	1.975	1.863	1.719
245	5.706	4.377	3.862	3.298	2.677	2.596	2.557	2.301	2.290	2.250	2.221	2.119	2.112	2.094	2.065	1.999	1.886	1.744
250	5.764	4.412	3.888	3.347	2.717	2.634	2.594	2.330	2.320	2.278	2.248	2.144	2.136	2.118	2.089	2.022	1.909	1.769
255	-	4.446	3.914	3.395	2.752	2.672	2.631	2.360	2.349	2.306	2.275	2.168	2.160	2.142	2.113	2.045	1.932	1.793
260	-	4.481	3.941	3.444	2.786	2.710	2.668	2.389	2.378	2.335	2.308	2.193	2.185	2.166	2.137	2.068	1.955	1.818
265	-	4.532	3.967	3.492	2.820	2.747	2.705	2.419	2.408	2.363	2.330	2.217	2.209	2.190	2.161	2.091	1.978	1.842
270	-	4.594	3.993	3.536	2.853	2.782	2.742	2.449	2.437	2.391	2.357	2.242	2.234	2.215	2.185	2.115	2.001	1.867
275	-	4.655	4.019	3.569	2.887	2.818	2.779	2.478	2.466	2.419	2.384	2.266	2.258	2.239	2.209	2.138	2.024	1.891
280	-	4.716	4.045	3.603	2.920	2.854	2.816	2.508	2.496	2.447	2.412	2.291	2.282	2.263	2.233	2.161	2.047	1.916
285	-	4.778	4.071	3.637	2.954	2.889	2.853	2.537	2.525	2.475	2.439	2.315	2.307	2.287	2.257	2.184	2.070	1.941
290	-	4.839	4.098	3.670	2.988	2.925	2.890	2.567	2.554	2.503	2.466	2.340	2.331	2.311	2.281	2.208	2.093	1.965
295	-	4.900	4.124	3.704	3.021	2.961	2.927	2.596	2.583	2.532	2.494	2.364	2.356	2.335	2.305	2.231	2.116	1.990
300	-	4.962	4.150	3.738	3.055	2.997	2.964	2.626	2.613	2.560	2.521	2.389	2.380	2.360	2.329	2.254	2.139	2.014
305	-	5.023	4.176	3.771	3.088	3.032	3.000	2.656	2.642	2.588	2.548	2.413	2.404	2.384	2.353	2.277	2.162	2.039
310	-	5.084	4.202	3.805	3.122	3.068	3.037	2.685	2.671	2.616	2.576	2.438	2.429	2.408	2.377	2.300	2.185	2.063
315	-	5.146	4.228	3.839	3.156	3.104	3.074	2.715	2.701	2.644	2.603	2.462	2.453	2.432	2.401	2.324	2.208	2.088
320	-	5.207	4.255	3.872	3.188</													

Section Factor (m ⁻¹)	Table 8 I-Section / H-Section Beams 105 minutes																	
	Required Thickness (mm) for a Design Temperature (°C)																	
350	400	450	500	544	550	553	575	576	580	583	600	603	610	620	650	700	750	
50	2.457	1.931	1.428	1.106	0.905	0.880	0.868	0.785	0.782	0.767	0.757	0.700	0.690	0.665	0.631	0.544	0.418	0.367
55	2.730	2.093	1.564	1.229	1.005	0.978	0.964	0.873	0.869	0.852	0.840	0.777	0.766	0.738	0.701	0.604	0.464	0.367
60	3.610	2.255	1.699	1.357	1.118	1.089	1.074	0.978	0.974	0.956	0.943	0.877	0.866	0.837	0.796	0.695	0.544	0.393
65	3.736	2.417	1.834	1.485	1.232	1.200	1.184	1.083	1.078	1.060	1.046	0.977	0.966	0.936	0.892	0.786	0.625	0.462
70	3.862	2.580	1.969	1.591	1.345	1.311	1.294	1.188	1.183	1.163	1.149	1.078	1.065	1.035	0.987	0.877	0.705	0.531
75	3.989	2.771	2.105	1.691	1.458	1.422	1.405	1.293	1.288	1.267	1.252	1.178	1.165	1.134	1.083	0.968	0.786	0.601
80	4.115	3.224	2.240	1.791	1.551	1.526	1.514	1.399	1.393	1.371	1.354	1.278	1.265	1.233	1.179	1.060	0.866	0.670
85	4.242	3.551	2.375	1.891	1.625	1.597	1.584	1.504	1.498	1.474	1.457	1.379	1.364	1.331	1.274	1.151	0.947	0.739
90	4.368	3.630	2.511	1.991	1.700	1.669	1.654	1.567	1.564	1.549	1.539	1.479	1.464	1.430	1.370	1.242	1.027	0.808
95	4.494	3.709	2.646	2.091	1.774	1.740	1.724	1.627	1.623	1.607	1.595	1.546	1.538	1.521	1.466	1.333	1.108	0.878
100	4.612	3.788	2.819	2.191	1.848	1.811	1.793	1.686	1.682	1.664	1.652	1.595	1.586	1.567	1.535	1.424	1.188	0.947
105	4.729	3.867	3.045	2.291	1.922	1.882	1.863	1.746	1.741	1.722	1.708	1.645	1.635	1.613	1.578	1.514	1.269	1.016
110	4.847	3.946	3.272	2.391	1.996	1.954	1.933	1.806	1.800	1.779	1.764	1.695	1.683	1.659	1.621	1.549	1.349	1.086
115	4.964	4.025	3.499	2.491	2.071	2.025	2.003	1.865	1.859	1.837	1.821	1.744	1.732	1.705	1.664	1.584	1.430	1.155
120	5.082	4.104	3.564	2.591	2.145	2.096	2.073	1.925	1.919	1.894	1.877	1.794	1.781	1.751	1.705	1.619	1.510	1.224
125	5.199	4.183	3.608	2.691	2.219	2.167	2.143	1.984	1.978	1.952	1.933	1.844	1.829	1.797	1.749	1.654	1.539	1.293
130	5.317	4.263	3.653	2.814	2.293	2.239	2.213	2.044	2.037	2.009	1.990	1.893	1.878	1.843	1.792	1.689	1.566	1.363
135	5.434	4.342	3.697	2.947	2.368	2.310	2.282	2.103	2.096	2.067	2.046	1.943	1.926	1.889	1.835	1.724	1.593	1.432
140	5.552	4.421	3.742	3.081	2.442	2.381	2.352	2.163	2.155	2.124	2.102	1.993	1.975	1.935	1.878	1.759	1.620	1.501
145	5.670	4.499	3.786	3.215	2.516	2.453	2.422	2.222	2.214	2.182	2.159	2.042	2.024	1.981	1.921	1.794	1.647	1.535
150	-	4.571	3.831	3.349	2.590	2.524	2.492	2.282	2.273	2.240	2.215	2.092	2.072	2.027	1.964	1.829	1.674	1.561
155	-	4.643	3.875	3.483	2.664	2.595	2.562	2.341	2.333	2.297	2.271	2.142	2.121	2.073	2.007	1.864	1.701	1.588
160	-	4.714	3.920	3.541	2.741	2.666	2.632	2.401	2.392	2.355	2.328	2.191	2.169	2.119	2.050	1.899	1.728	1.614
165	-	4.786	3.964	3.566	2.830	2.740	2.701	2.461	2.451	2.412	2.384	2.241	2.218	2.166	2.093	1.934	1.755	1.641
170	-	4.858	4.009	3.591	2.919	2.824	2.779	2.520	2.510	2.470	2.440	2.291	2.266	2.212	2.136	1.969	1.782	1.668
175	-	4.930	4.053	3.616	3.008	2.908	2.861	2.580	2.569	2.527	2.497	2.340	2.315	2.258	2.179	2.004	1.809	1.694
180	-	5.001	4.098	3.640	3.097	2.992	2.942	2.639	2.628	2.585	2.553	2.390	2.364	2.304	2.222	2.039	1.836	1.721
185	-	5.073	4.142	3.665	3.186	3.076	3.024	2.699	2.687	2.642	2.609	2.440	2.412	2.350	2.265	2.074	1.863	1.747
190	-	5.145	4.187	3.690	3.275	3.160	3.105	2.763	2.750	2.700	2.666	2.489	2.461	2.396	2.308	2.109	1.889	1.774
195	-	5.217	4.232	3.715	3.364	3.244	3.187	2.832	2.818	2.762	2.722	2.539	2.509	2.442	2.350	2.144	1.916	1.800
200	-	5.288	4.276	3.740	3.453	3.328	3.268	2.900	2.886	2.828	2.786	2.589	2.558	2.488	2.393	2.179	1.943	1.827
205	-	5.360	4.321	3.765	3.529	3.412	3.350	2.969	2.954	2.894	2.850	2.638	2.606	2.534	2.436	2.214	1.970	1.853
210	-	5.432	4.365	3.789	3.556	3.496	3.432	3.038	3.022	2.959	2.914	2.688	2.655	2.580	2.479	2.249	1.997	1.880
215	-	5.503	4.410	3.814	3.588	3.542	3.513	3.106	3.090	3.025	2.979	2.739	2.704	2.626	2.522	2.284	2.024	1.906
220	-	5.575	4.454	3.839	3.609	3.569	3.548	3.175	3.158	3.091	3.043	2.796	2.756	2.672	2.565	2.319	2.051	1.933
225	-	5.647	4.500	3.864	3.636	3.596	3.575	3.244	3.226	3.157	3.107	2.852	2.811	2.718	2.608	2.354	2.078	1.959
230	-	5.719	4.554	3.889	3.662	3.623	3.603	3.312	3.294	3.223	3.172	2.909	2.866	2.769	2.651	2.389	2.105	1.986
235	-	-	4.609	3.914	3.689	3.650	3.630	3.381	3.362	3.289	3.236	2.965	2.921	2.821	2.694	2.424	2.132	2.012
240	-	-	4.663	3.938	3.716	3.678	3.657	3.449	3.430	3.354	3.300	3.022	2.976	2.873	2.738	2.459	2.159	2.039
245	-	-	4.718	3.963	3.742	3.705	3.685	3.518	3.498	3.420	3.365	3.078	3.031	2.925	2.786	2.494	2.186	2.065
250	-	-	4.772	3.988	3.769	3.732	3.712	3.552	3.543	3.486	3.429	3.134	3.086	2.976	2.834	2.529	2.213	2.092
255	-	-	4.826	4.013	3.795	3.759	3.740	3.582	3.573	3.537	3.493	3.191	3.141	3.028	2.881	2.565	2.240	2.118
260	-	-	4.881	4.038	3.822	3.785	3.767	3.612	3.604	3.568	3.541	3.247	3.196	3.080	2.929	2.600	2.267	2.145
265	-	-	4.935	4.063	3.849	3.813	3.794	3.642	3.634	3.599	3.572	3.304	3.251	3.132	2.977	2.635	2.294	2.171
270	-	-	4.990	4.087	3.875	3.840	3.822	3.672	3.664	3.630	3.603	3.306	3.183	3.024	2.670	2.321	2.198	
275	-	-	5.044	4.112	3.902	3.867	3.849	3.702	3.695	3.661	3.635	3.417	3.361	3.235	3.072	2.705	2.348	2.224
280	-	-	5.098	4.137	3.928	3.894	3.877	3.733	3.725	3.692	3.666	3.473	3.416	3.287	3.120	2.743	2.375	2.251
285	-	-	5.153	4.162	3.955	3.922	3.904	3.763	3.755	3.723	3.698	3.527	3.471	3.339	3.168	2.787	2.402	2.277
290	-	-	5.207	4.187	3.982	3.949	3.931	3.793	3.785	3.754	3.729	3.563	3.525	3.390	3.215	2.830	2.429	2.304
295	-	-	5.262	4.212	4.008	3.976	3.959	3.823	3.816	3.785	3.761	3.598	3.562	3.442	3.263	2.874	2.456	2.330
300	-	-	5.316	4.236	4.035	4.003	3.986	3.853	3.846	3.816	3.792	3.634	3.598	3.494	3.311	2.917	2.482	2.357
305	-	-	5.370	4.261	4.061	4.030	4.014	3.883	3.876	3.847	3.824	3.669	3.634	3.540	3.358	2.961	2.509	2.383
310	-	-	5.425	4.286	4.088	4.057	4.041	3.914	3.907	3.878	3.855	3.705	3.671	3.580	3.406	3.005	2.536	2.410
315	-	-	5.479	4.311	4.115	4.084	4.068	3.944	3.937	3.909</								

Section Factor (m ⁻¹)	Table 91-Section / H-Section Beams 120 minutes Required Thickness (mm) for a Design Temperature (°C)																	
	350	400	450	500	544	550	553	575	576	580	583	600	603	610	620	650	700	750
50	3.765	2.334	1.806	1.389	1.159	1.132	1.118	1.032	1.028	1.012	1.001	0.941	0.931	0.905	0.867	0.772	0.631	0.482
55	3.934	2.536	1.980	1.534	1.287	1.257	1.242	1.146	1.142	1.124	1.111	1.046	1.034	1.005	0.962	0.858	0.701	0.535
60	4.103	2.792	2.153	1.679	1.426	1.394	1.378	1.276	1.272	1.253	1.239	1.170	1.158	1.128	1.082	0.972	0.803	0.625
65	4.272	3.564	2.326	1.824	1.555	1.527	1.513	1.407	1.401	1.381	1.366	1.295	1.282	1.251	1.201	1.086	0.905	0.715
70	4.441	3.697	2.499	1.969	1.669	1.637	1.621	1.530	1.526	1.510	1.494	1.420	1.406	1.375	1.321	1.200	1.007	0.805
75	4.620	3.831	2.672	2.114	1.783	1.747	1.730	1.625	1.621	1.603	1.590	1.534	1.524	1.498	1.440	1.314	1.109	0.895
80	4.803	3.964	3.051	2.259	1.896	1.857	1.838	1.720	1.715	1.695	1.681	1.616	1.605	1.581	1.542	1.429	1.211	0.985
85	4.986	4.097	3.523	2.404	2.010	1.967	1.946	1.815	1.810	1.788	1.772	1.698	1.686	1.659	1.615	1.530	1.313	1.075
90	5.169	4.230	3.616	2.549	2.124	2.077	2.054	1.910	1.904	1.880	1.863	1.781	1.767	1.736	1.689	1.593	1.415	1.165
95	5.353	4.364	3.708	2.694	2.237	2.187	2.162	2.005	1.999	1.973	1.954	1.863	1.848	1.814	1.763	1.657	1.515	1.255
100	5.536	4.497	3.800	2.942	2.351	2.297	2.270	2.100	2.093	2.065	2.045	1.945	1.928	1.891	1.836	1.720	1.568	1.345
105	5.719	4.626	3.891	3.219	2.465	2.407	2.379	2.195	2.188	2.158	2.136	2.027	2.009	1.969	1.910	1.784	1.621	1.435
110	-	4.756	3.983	3.495	2.578	2.516	2.487	2.290	2.282	2.250	2.227	2.109	2.090	2.047	1.984	1.848	1.674	1.520
115	-	4.886	4.075	3.571	2.692	2.626	2.595	2.385	2.377	2.343	2.318	2.192	2.171	2.124	2.057	1.911	1.726	1.569
120	-	5.015	4.167	3.623	2.861	2.743	2.703	2.480	2.471	2.435	2.409	2.274	2.252	2.202	2.131	1.975	1.779	1.619
125	-	5.145	4.259	3.676	3.053	2.926	2.867	2.575	2.566	2.527	2.499	2.356	2.333	2.279	2.205	2.038	1.832	1.669
130	-	5.275	4.351	3.728	3.245	3.110	3.046	2.670	2.660	2.620	2.590	2.438	2.413	2.357	2.278	2.102	1.885	1.718
135	-	5.404	4.443	3.780	3.437	3.293	3.224	2.792	2.774	2.712	2.681	2.521	2.494	2.435	2.352	2.165	1.937	1.768
140	-	5.534	4.538	3.832	3.538	3.476	3.403	2.950	2.931	2.857	2.803	2.603	2.575	2.512	2.426	2.229	1.990	1.818
145	-	5.664	4.637	3.885	3.565	3.542	3.532	3.108	3.089	3.012	2.955	2.685	2.656	2.590	2.499	2.293	2.043	1.867
150	-	-	4.735	3.937	3.591	3.566	3.556	3.266	3.246	3.166	3.107	2.797	2.744	2.667	2.573	2.356	2.096	1.917
155	-	-	4.834	3.989	3.617	3.591	3.581	3.425	3.404	3.320	3.259	2.937	2.883	2.759	2.647	2.420	2.148	1.966
160	-	-	4.933	4.042	3.643	3.615	3.605	3.533	3.530	3.474	3.411	3.078	3.022	2.892	2.720	2.483	2.201	2.016
165	-	-	5.031	4.094	3.670	3.640	3.630	3.558	3.555	3.541	3.530	3.219	3.160	3.026	2.843	2.547	2.254	2.066
170	-	-	5.130	4.146	3.696	3.664	3.654	3.583	3.580	3.566	3.555	3.359	3.299	3.159	2.971	2.610	2.307	2.115
175	-	-	5.229	4.199	3.722	3.688	3.679	3.608	3.604	3.591	3.580	3.500	3.438	3.299	3.098	2.674	2.359	2.165
180	-	-	5.327	4.251	3.748	3.713	3.703	3.633	3.629	3.616	3.605	3.545	3.534	3.427	3.226	2.745	2.412	2.215
185	-	-	5.426	4.303	3.775	3.737	3.727	3.658	3.654	3.641	3.630	3.571	3.559	3.531	3.353	2.848	2.465	2.264
190	-	-	5.524	4.356	3.801	3.762	3.752	3.682	3.679	3.666	3.655	3.597	3.585	3.557	3.481	2.950	2.517	2.314
195	-	-	5.623	4.408	3.827	3.788	3.776	3.707	3.704	3.691	3.680	3.622	3.611	3.584	3.542	3.053	2.570	2.363
200	-	-	5.722	4.460	3.853	3.810	3.801	3.732	3.729	3.715	3.705	3.648	3.637	3.610	3.569	3.156	2.623	2.413
205	-	-	-	4.527	3.880	3.835	3.825	3.757	3.754	3.740	3.730	3.674	3.663	3.636	3.596	3.259	2.676	2.463
210	-	-	-	4.617	3.906	3.859	3.850	3.782	3.779	3.765	3.755	3.699	3.688	3.662	3.623	3.361	2.730	2.512
215	-	-	-	4.708	3.932	3.884	3.874	3.807	3.803	3.790	3.780	3.725	3.714	3.689	3.650	3.464	2.804	2.562
220	-	-	-	4.798	3.959	3.908	3.899	3.832	3.828	3.815	3.805	3.751	3.740	3.715	3.678	3.537	2.879	2.612
225	-	-	-	4.889	3.985	3.933	3.923	3.856	3.853	3.840	3.830	3.776	3.766	3.741	3.705	3.567	2.953	2.661
230	-	-	-	4.979	4.011	3.957	3.947	3.881	3.878	3.865	3.855	3.802	3.791	3.767	3.732	3.597	3.028	2.711
235	-	-	-	5.069	4.037	3.981	3.972	3.906	3.903	3.890	3.880	3.828	3.817	3.794	3.759	3.628	3.102	2.766
240	-	-	-	5.160	4.064	4.006	3.996	3.931	3.928	3.915	3.905	3.853	3.843	3.820	3.786	3.658	3.177	2.824
245	-	-	-	5.250	4.090	4.030	4.021	3.956	3.953	3.940	3.930	3.879	3.869	3.846	3.813	3.688	3.251	2.882
250	-	-	-	5.341	4.116	4.055	4.045	3.981	3.978	3.965	3.955	3.905	3.894	3.872	3.840	3.719	3.326	2.940
255	-	-	-	5.431	4.142	4.079	4.070	4.006	4.002	3.990	3.980	3.930	3.920	3.899	3.868	3.749	3.401	2.998
260	-	-	-	5.522	4.169	4.103	4.094	4.030	4.027	4.015	4.005	3.956	3.946	3.925	3.895	3.779	3.475	3.056
265	-	-	-	5.612	4.195	4.128	4.119	4.055	4.052	4.040	4.030	3.982	3.972	3.951	3.922	3.810	3.537	3.114
270	-	-	-	5.703	4.221	4.152	4.143	4.080	4.077	4.065	4.055	4.007	3.997	3.977	3.949	3.840	3.576	3.172
275	-	-	-	-	4.247	4.177	4.167	4.105	4.102	4.090	4.080	4.033	4.023	4.004	3.976	3.870	3.615	3.230
280	-	-	-	-	4.274	4.201	4.192	4.130	4.127	4.115	4.105	4.059	4.049	4.030	3.901	3.654	3.288	
285	-	-	-	-	4.300	4.225	4.216	4.155	4.152	4.140	4.130	4.085	4.075	4.056	4.030	3.931	3.692	3.346
290	-	-	-	-	4.326	4.250	4.241	4.180	4.177	4.165	4.155	4.110	4.101	4.082	4.058	3.961	3.731	3.403
295	-	-	-	-	4.352	4.274	4.265	4.204	4.201	4.189	4.180	4.136	4.126	4.109	4.085	3.992	3.770	3.461
300	-	-	-	-	4.379	4.299	4.290	4.229	4.226	4.214	4.205	4.162	4.152	4.135	4.112	4.022	3.809	3.519
305	-	-	-	-	4.405	4.323	4.314	4.254	4.251	4.239	4.230	4.187	4.178	4.161	4.139	4.052	3.847	3.558
310	-	-	-	-	4.431	4.347	4.338	4.279	4.276	4.264	4.255	4.213	4.204	4.187	4.166	4.083	3.886	3.596
315	-	-	-	-	4.457	4.372	4.363	4.304	4.301	4.289	4.280	4.239	4.229	4.214	4.193	4.113	3.925	3.633
320	-	-	-	-	4.484	4.396	4.387	4.329	4.326	4.314	4.305	4.264	4.255	4.240	4.220	4.143	3.964	3.671
325	-	-	-	-	4.619	4.421	4.412	4.354	4.351	4.339	4.330	4.290	4.281	4.266	4.247	4.174	4.002	3.708
330	-	-	-	-														

Thickness is intumescent only. Results also apply to I/H-section beams exposed on all four sides, limited to a maximum protection thickness of 5.770 mm.

Section Factor (m ⁻¹)	Table 111-Section / H-Section Columns 20 minutes Required Thickness (mm) for a Design Temperature (°C)														
	350	400	450	500	510	530	539	545	550	563	580	600	650	700	750
50	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
55	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
60	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
65	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
70	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
75	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
80	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
85	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
90	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
95	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
100	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
105	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
110	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
115	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
120	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
125	0.477	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
130	0.501	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
135	0.524	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
140	0.548	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
145	0.572	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
150	0.596	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
155	0.619	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
160	0.643	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
165	0.667	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
170	0.690	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
175	0.714	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
180	0.738	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
185	0.761	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
190	0.785	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
195	0.809	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
200	0.833	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
205	0.856	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
210	0.880	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
215	0.904	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
220	0.927	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
225	0.951	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
230	0.975	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
235	0.998	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
240	1.022	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
245	1.046	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
250	1.070	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
255	1.093	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
260	1.117	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
265	1.141	0.480	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
270	1.164	0.504	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
275	1.188	0.528	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
280	1.212	0.552	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
285	1.235	0.576	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
290	1.259	0.600	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
295	1.283	0.623	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
300	1.307	0.647	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
305	1.330	0.674	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
310	1.354	0.695	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
315	1.378	0.719	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
320	1.401	0.743	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
325	1.425	0.766	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
330	1.449	0.790	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
335	1.472	0.814	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
340	1.496	0.838	0.480	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
345	1.520	0.862	0.499	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
350	1.542	0.886	0.518	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
355	1.562	0.909	0.537	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
360	1.581	0.933	0.555	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
365	1.601	0.957	0.574	0.472	0.472										

Section Factor (m ⁻¹)	Table 12 I-Section / H-Section Columns 30 minutes Required Thickness (mm) for a Design Temperature (°C)													
	350	400	450	500	510	530	539	545	550	563	580	600	650	700
50	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
55	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
60	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
65	0.500	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
70	0.549	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
75	0.598	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
80	0.647	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
85	0.696	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
90	0.746	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
95	0.795	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
100	0.844	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
105	0.893	0.486	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
110	0.942	0.513	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
115	0.992	0.540	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
120	1.041	0.567	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
125	1.090	0.594	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
130	1.139	0.621	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
135	1.188	0.648	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
140	1.238	0.675	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
145	1.287	0.702	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
150	1.336	0.729	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
155	1.385	0.756	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
160	1.434	0.783	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
165	1.484	0.810	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
170	1.533	0.837	0.493	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
175	1.557	0.864	0.516	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
180	1.581	0.891	0.539	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
185	1.604	0.918	0.562	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
190	1.628	0.945	0.585	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
195	1.651	0.972	0.608	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
200	1.675	0.999	0.630	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
205	1.699	1.026	0.653	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
210	1.722	1.053	0.676	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
215	1.745	1.080	0.699	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
220	1.769	1.107	0.722	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
225	1.793	1.134	0.745	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
230	1.817	1.160	0.768	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
235	1.840	1.187	0.791	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
240	1.864	1.214	0.814	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
245	1.887	1.241	0.837	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
250	1.911	1.268	0.860	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
255	1.935	1.295	0.882	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
260	1.958	1.322	0.905	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
265	1.982	1.349	0.928	0.494	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
270	2.005	1.376	0.951	0.519	0.474	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
275	2.029	1.403	0.974	0.544	0.494	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
280	2.053	1.430	0.997	0.568	0.522	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
285	2.076	1.457	1.020	0.593	0.546	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
290	2.100	1.484	1.043	0.618	0.570	0.493	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
295	2.123	1.511	1.066	0.643	0.594	0.505	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
300	2.147	1.537	1.089	0.668	0.618	0.528	0.490	0.472	0.472	0.472	0.472	0.472	0.472	0.472
305	2.170	1.561	1.112	0.693	0.643	0.550	0.512	0.492	0.476	0.472	0.472	0.472	0.472	0.472
310	2.194	1.585	1.135	0.718	0.667	0.572	0.533	0.513	0.497	0.472	0.472	0.472	0.472	0.472
315	2.218	1.608	1.157	0.743	0.691	0.594	0.555	0.534	0.517	0.477	0.472	0.472	0.472	0.472
320	2.241	1.632	1.180	0.768	0.715	0.617	0.576	0.555	0.537	0.496	0.472	0.472	0.472	0.472
325	2.265	1.655	1.203	0.793	0.739	0.639	0.597	0.575	0.558	0.515	0.472	0.472	0.472	0.472
330	2.288	1.679	1.226	0.818	0.763	0.661	0.619	0.596	0.578	0.534	0.484	0.472	0.472	0.472
335	2.312	1.702	1.249	0.843	0.787	0.683	0.640	0.617	0.598	0.553	0.501	0.472	0.472	0.472
340	2.336	1.726	1.272	0.868	0.811	0.706	0.662	0.638	0.619	0.572	0.519	0.472	0.472	0.472
345	2.359	1.749	1.295	0.893	0.835	0.728	0.683	0.659	0.639	0.592	0.538	0.479	0.472	0.472
350	2.383	1.773	1.318	0.918	0.859	0.750	0.705	0.680	0.659	0.611	0.554	0.495	0.472	0.472
355	2.406	1.796	1.341	0.943	0.883	0.772	0.726	0.701	0.680	0.630	0.572	0.510	0.472	0.472
360	2.430	1.820	1.364	0.968	0.907	0.795	0.748	0.721	0.700	0.649	0.589	0.526	0.472	0.472
365	2.454	1.843	1.387	0.993	0.931	0.817	0.769	0.742	0.721	0.668	0.607	0.542	0.472	0.472
370	2.477	1.867	1.410	1.017	0.955	0.839	0.791	0.763	0.741	0.687	0.624	0.558	0.472	0.472
375	2.501	1.890	1.432	1.042	0.979	0.861	0.812	0.784	0.761	0.706	0.642	0.574	0.472	0.472
380	2.524	1.914	1.455	1.067	1.003	0.884	0.834	0.805	0.782	0.725	0.659	0.590	0.472	0.472
385	2.548	1.937	1.478	1.092	1.027	0.906	0.855	0.826						

Section Factor (m ⁻¹)	Table 131-Section / H-Section Columns 45 minutes Required Thickness (mm) for a Design Temperature (°C)													
	350	400	450	500	510	530	539	545	550	563	580	600	650	700
50	0.755	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
55	0.838	0.514	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
60	0.928	0.576	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
65	1.017	0.637	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
70	1.107	0.698	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
75	1.196	0.760	0.483	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
80	1.286	0.821	0.525	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
85	1.376	0.883	0.568	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
90	1.465	0.944	0.611	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
95	1.544	1.005	0.654	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
100	1.589	1.067	0.697	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
105	1.633	1.128	0.739	0.491	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
110	1.678	1.189	0.782	0.523	0.483	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
115	1.722	1.251	0.825	0.554	0.511	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
120	1.767	1.312	0.868	0.585	0.540	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
125	1.811	1.373	0.910	0.615	0.568	0.488	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
130	1.856	1.435	0.953	0.646	0.596	0.512	0.480	0.472	0.472	0.472	0.472	0.472	0.472	0.472
135	1.901	1.496	0.996	0.676	0.625	0.537	0.505	0.486	0.472	0.472	0.472	0.472	0.472	0.472
140	1.945	1.544	1.039	0.707	0.653	0.562	0.529	0.511	0.495	0.472	0.472	0.472	0.472	0.472
145	1.990	1.571	1.082	0.737	0.681	0.587	0.554	0.535	0.519	0.480	0.472	0.472	0.472	0.472
150	2.034	1.598	1.124	0.768	0.709	0.612	0.578	0.559	0.543	0.503	0.472	0.472	0.472	0.472
155	2.079	1.625	1.167	0.799	0.738	0.637	0.603	0.583	0.567	0.526	0.475	0.472	0.472	0.472
160	2.123	1.652	1.210	0.829	0.766	0.662	0.627	0.607	0.591	0.549	0.497	0.472	0.472	0.472
165	2.168	1.679	1.253	0.860	0.794	0.687	0.652	0.631	0.615	0.572	0.519	0.472	0.472	0.472
170	2.212	1.706	1.296	0.890	0.823	0.711	0.676	0.656	0.639	0.596	0.542	0.480	0.472	0.472
175	2.257	1.733	1.334	0.921	0.851	0.736	0.701	0.680	0.661	0.619	0.564	0.502	0.472	0.472
180	2.301	1.760	1.381	0.951	0.879	0.761	0.725	0.704	0.687	0.642	0.586	0.523	0.472	0.472
185	2.346	1.787	1.424	0.982	0.908	0.786	0.750	0.728	0.710	0.665	0.609	0.544	0.472	0.472
190	2.390	1.814	1.467	1.013	0.936	0.811	0.774	0.752	0.734	0.689	0.631	0.566	0.472	0.472
195	2.435	1.841	1.510	1.043	0.964	0.836	0.799	0.776	0.758	0.712	0.653	0.587	0.472	0.472
200	2.480	1.868	1.545	1.074	0.993	0.861	0.823	0.801	0.782	0.735	0.675	0.608	0.472	0.472
205	2.524	1.895	1.572	1.104	1.021	0.886	0.848	0.825	0.806	0.758	0.698	0.629	0.472	0.472
210	2.569	1.922	1.599	1.135	1.049	0.910	0.872	0.849	0.830	0.781	0.720	0.651	0.488	0.472
215	2.613	1.949	1.625	1.165	1.077	0.935	0.897	0.873	0.854	0.805	0.742	0.672	0.506	0.472
220	2.658	1.976	1.652	1.196	1.106	0.960	0.921	0.897	0.878	0.828	0.765	0.693	0.525	0.472
225	2.702	2.003	1.679	1.227	1.134	0.985	0.946	0.921	0.902	0.851	0.787	0.715	0.544	0.472
230	2.747	2.030	1.705	1.257	1.162	1.010	0.970	0.946	0.926	0.874	0.809	0.736	0.563	0.472
235	2.791	2.057	1.732	1.288	1.191	1.035	0.995	0.970	0.949	0.897	0.832	0.757	0.582	0.472
240	2.833	2.084	1.759	1.318	1.219	1.060	1.019	0.994	0.973	0.921	0.854	0.778	0.600	0.472
245	2.874	2.111	1.785	1.349	1.247	1.085	1.044	1.018	0.997	0.944	0.876	0.800	0.619	0.472
250	2.915	2.138	1.812	1.388	1.276	1.109	1.068	1.042	1.021	0.967	0.899	0.821	0.638	0.472
255	2.955	2.165	1.839	1.410	1.304	1.134	1.093	1.066	1.045	0.990	0.921	0.842	0.657	0.472
260	2.996	2.192	1.865	1.441	1.332	1.159	1.117	1.091	1.069	1.014	0.943	0.864	0.676	0.492
265	3.037	2.219	1.892	1.471	1.360	1.184	1.142	1.115	1.093	1.037	0.966	0.885	0.694	0.507
270	3.078	2.246	1.918	1.502	1.389	1.209	1.166	1.139	1.117	1.064	0.988	0.906	0.713	0.526
275	3.119	2.273	1.945	1.532	1.417	1.234	1.191	1.163	1.141	1.083	1.010	0.927	0.732	0.542
280	3.160	2.300	1.972	1.561	1.445	1.259	1.215	1.187	1.165	1.106	1.033	0.949	0.751	0.559
285	3.201	2.327	1.998	1.590	1.474	1.263	1.240	1.211	1.188	1.130	1.055	0.970	0.770	0.576
290	3.241	2.354	2.025	1.618	1.502	1.308	1.264	1.236	1.212	1.153	1.077	0.991	0.788	0.592
295	3.282	2.381	2.052	1.647	1.530	1.333	1.289	1.260	1.236	1.176	1.100	1.013	0.807	0.609
300	3.323	2.408	2.078	1.676	1.560	1.358	1.313	1.284	1.260	1.199	1.122	1.034	0.826	0.626
305	3.364	2.435	2.105	1.704	1.589	1.383	1.338	1.308	1.284	1.223	1.144	1.055	0.845	0.642
310	3.405	2.462	2.132	1.733	1.619	1.408	1.362	1.332	1.308	1.246	1.167	1.077	0.864	0.659
315	3.446	2.489	2.158	1.762	1.649	1.433	1.386	1.357	1.332	1.269	1.189	1.098	0.882	0.675
320	3.486	2.516	2.185	1.790	1.678	1.458	1.411	1.381	1.356	1.292	1.211	1.119	0.901	0.692
325	3.527	2.543	2.212	1.819	1.708	1.482	1.435	1.405	1.380	1.315	1.234	1.140	0.920	0.709
330	3.568	2.570	2.238	1.848	1.738	1.507	1.460	1.429	1.403	1.339	1.256	1.162	0.939	0.725
335	3.609	2.597	2.265	1.876	1.767	1.532	1.484	1.453	1.427	1.362	1.278	1.183	0.958	0.742
340	3.650	2.624	2.292	1.908	1.797	1.563	1.509	1.477	1.451	1.385	1.301	1.204	0.976	0.759
345	3.691	2.651	2.318	1.934	1.827	1.595	1.533	1.502	1.475	1.408	1.323	1.226	0.995	0.775
350	3.732	2.678	2.345	1.962	1.856	1.626	1.564	1.526	1.499	1.431	1.345	1.247	1.014	0.792
355	3.772	2.705	2.372	1.991	1.886	1.658	1.596	1.554	1.523	1.455	1.368	1.268	1.033	0.809
360	3.813	2.732	2.398	2.020	1.916	1.689	1.627	1.585	1.550	1.478	1.390	1.289	1.052	0.825
365	3.854	2.759	2.425	2.048	1.945	1.721	1.658	1.616	1.581	1.501	1.412	1.311	1.070	0.842
370	3.895	2.786	2.452	2.077	1.975	1.753	1.689	1.647	1.612	1.524	1.435	1.332	1.089	0.859
375	3.936	2.828	2.478	2.106	2.005	1.784	1.720	1.677	1.642	1.551	1.457	1.353	1.108	0.875
380	3.977	2.869	2.505	2.134	2.034	1.816	1.751	1.708	1.673	1.581	1.479	1.375	1.127	0.892
385	4.017	2.949	2.531	2.163	2.064	1.847	1.782							

Section Factor (m ⁻¹)	Table 14 I-Section / H-Section Columns 60 minutes Required Thickness (mm) for a Design Temperature (°C)														
	350	400	450	500	510	530	539	545	550	563	580	600	650	700	750
50	1.152	0.790	0.537	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
55	1.280	0.878	0.596	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
60	1.410	0.972	0.668	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
65	1.538	1.067	0.740	0.505	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
70	1.635	1.161	0.812	0.562	0.522	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
75	1.733	1.255	0.884	0.620	0.577	0.498	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
80	1.830	1.350	0.956	0.677	0.632	0.547	0.513	0.494	0.480	0.472	0.472	0.472	0.472	0.472	0.472
85	1.927	1.444	1.028	0.735	0.686	0.597	0.560	0.544	0.524	0.485	0.472	0.472	0.472	0.472	0.472
90	2.025	1.537	1.100	0.792	0.741	0.646	0.607	0.585	0.568	0.526	0.478	0.472	0.472	0.472	0.472
95	2.122	1.590	1.173	0.850	0.796	0.695	0.654	0.630	0.612	0.566	0.514	0.472	0.472	0.472	0.472
100	2.219	1.643	1.245	0.907	0.850	0.745	0.701	0.676	0.656	0.607	0.551	0.497	0.472	0.472	0.472
105	2.317	1.697	1.317	0.965	0.905	0.794	0.748	0.721	0.700	0.647	0.587	0.528	0.472	0.472	0.472
110	2.414	1.750	1.389	1.022	0.960	0.844	0.796	0.767	0.744	0.688	0.623	0.559	0.472	0.472	0.472
115	2.511	1.804	1.461	1.080	1.014	0.893	0.843	0.812	0.788	0.728	0.659	0.590	0.475	0.472	0.472
120	2.609	1.857	1.533	1.137	1.069	0.942	0.890	0.857	0.832	0.769	0.695	0.621	0.498	0.472	0.472
125	2.706	1.910	1.566	1.194	1.124	0.992	0.937	0.903	0.876	0.810	0.732	0.653	0.521	0.472	0.472
130	2.802	1.964	1.599	1.252	1.179	1.041	0.984	0.948	0.920	0.850	0.768	0.684	0.544	0.472	0.472
135	2.860	2.017	1.631	1.309	1.233	1.090	1.031	0.993	0.964	0.891	0.804	0.715	0.567	0.473	0.472
140	2.917	2.071	1.664	1.367	1.288	1.140	1.078	1.039	1.008	0.931	0.840	0.746	0.590	0.494	0.472
145	2.974	2.124	1.697	1.424	1.343	1.189	1.125	1.084	1.052	0.972	0.876	0.778	0.612	0.514	0.472
150	3.031	2.177	1.729	1.482	1.397	1.239	1.172	1.130	1.096	1.012	0.913	0.809	0.635	0.534	0.472
155	3.089	2.231	1.762	1.537	1.452	1.288	1.219	1.175	1.140	1.053	0.949	0.840	0.658	0.555	0.472
160	3.146	2.284	1.795	1.567	1.507	1.337	1.266	1.220	1.184	1.094	0.985	0.871	0.681	0.575	0.472
165	3.203	2.338	1.827	1.597	1.549	1.387	1.313	1.266	1.228	1.134	1.021	0.902	0.704	0.596	0.479
170	3.260	2.393	1.860	1.627	1.579	1.436	1.360	1.311	1.272	1.175	1.057	0.934	0.727	0.616	0.497
175	3.318	2.444	1.892	1.657	1.609	1.485	1.407	1.357	1.316	1.215	1.094	0.965	0.749	0.636	0.515
180	3.375	2.498	1.925	1.687	1.639	1.535	1.454	1.402	1.360	1.256	1.130	0.996	0.772	0.657	0.534
185	3.432	2.551	1.958	1.717	1.668	1.564	1.501	1.447	1.404	1.296	1.166	1.027	0.795	0.677	0.552
190	3.489	2.605	1.990	1.747	1.698	1.594	1.543	1.493	1.448	1.337	1.202	1.058	0.818	0.697	0.571
195	3.547	2.658	2.023	1.777	1.728	1.623	1.573	1.537	1.492	1.378	1.238	1.090	0.841	0.718	0.589
200	3.604	2.711	2.056	1.807	1.758	1.653	1.602	1.566	1.535	1.418	1.275	1.121	0.864	0.738	0.607
205	3.661	2.765	2.088	1.837	1.788	1.683	1.632	1.596	1.565	1.459	1.311	1.152	0.886	0.758	0.626
210	3.718	2.818	2.121	1.867	1.818	1.712	1.662	1.626	1.595	1.499	1.347	1.183	0.909	0.779	0.644
215	3.776	2.870	2.154	1.897	1.847	1.742	1.691	1.655	1.624	1.538	1.383	1.214	0.932	0.799	0.663
220	3.833	2.922	2.186	1.927	1.877	1.772	1.721	1.685	1.654	1.568	1.419	1.246	0.955	0.819	0.681
225	3.890	2.974	2.219	1.957	1.907	1.801	1.751	1.715	1.684	1.598	1.456	1.277	0.978	0.840	0.700
230	3.947	3.025	2.251	1.987	1.937	1.831	1.780	1.744	1.714	1.628	1.492	1.308	1.001	0.860	0.718
235	4.005	3.077	2.284	2.017	1.967	1.861	1.810	1.774	1.743	1.658	1.528	1.339	1.024	0.881	0.736
240	4.062	3.129	2.317	2.047	1.997	1.890	1.839	1.804	1.773	1.688	1.559	1.371	1.046	0.901	0.755
245	4.119	3.181	2.349	2.076	2.026	1.920	1.869	1.834	1.803	1.718	1.590	1.402	1.069	0.921	0.773
250	4.176	3.233	2.382	2.106	2.056	1.950	1.899	1.863	1.833	1.748	1.620	1.433	1.092	0.942	0.792
255	4.234	3.285	2.415	2.136	2.086	1.979	1.928	1.893	1.862	1.778	1.651	1.454	1.115	0.962	0.810
260	4.291	3.337	2.447	2.166	2.116	2.009	1.958	1.923	1.892	1.808	1.681	1.495	1.136	0.982	0.828
265	4.348	3.389	2.480	2.196	2.146	2.039	1.988	1.952	1.922	1.838	1.712	1.527	1.161	1.003	0.847
270	4.405	3.441	2.512	2.226	2.175	2.068	2.017	1.982	1.951	1.867	1.742	1.558	1.283	1.023	0.865
275	4.463	3.493	2.545	2.256	2.205	2.098	2.047	2.012	1.981	1.897	1.773	1.590	1.306	1.043	0.884
280	4.520	3.545	2.576	2.286	2.235	2.128	2.077	2.041	2.011	1.927	1.803	1.621	1.329	1.064	0.902
285	4.577	3.597	2.610	2.316	2.265	2.157	2.106	2.071	2.041	1.957	1.834	1.653	1.352	1.084	0.920
290	4.631	3.649	2.643	2.346	2.295	2.187	2.136	2.101	2.070	1.987	1.864	1.685	1.375	1.104	0.939
295	4.681	3.701	2.676	2.376	2.325	2.217	2.166	2.130	2.100	2.017	1.894	1.717	1.428	1.125	0.957
300	4.731	3.753	2.708	2.406	2.354	2.246	2.195	2.160	2.130	2.047	1.925	1.748	1.430	1.145	0.976
305	4.780	3.805	2.741	2.436	2.384	2.276	2.225	2.190	2.160	2.077	1.955	1.780	1.434	1.165	0.994
310	4.830	3.857	2.774	2.466	2.414	2.306	2.255	2.219	2.189	2.107	1.986	1.812	1.566	1.286	1.013
315	4.880	3.909	2.816	2.496	2.444	2.335	2.284	2.249	2.219	2.137	2.016	1.843	1.589	1.306	1.031
320	4.929	3.961	2.907	2.526	2.474	2.365	2.314	2.279	2.249	2.167	2.047	1.875	1.412	1.227	1.049
325	4.979	4.013	2.999	2.556	2.504	2.395	2.344	2.309	2.278	2.197	2.077	1.907	1.435	1.247	1.068
330	5.029	4.065	3.050	2.586	2.533	2.424	2.373	2.338	2.308	2.227	2.108	1.938	1.457	1.267	1.086
335	5.078	4.117	3.182	2.616	2.563	2.454	2.403	2.368	2.338	2.256	2.138	1.970	1.480	1.288	1.105
340	5.128	4.169	3.273	2.646	2.593	2.484	2.433	2.398	2.368	2.286	2.169	2.002	1.503	1.308	1.123
345	5.178	4.221	3.365	2.676	2.623	2.513	2.462	2.427	2.397	2.316	2.199	2.033	1.526	1.328	1.141
350	5.227	4.272	3.457	2.706	2.653	2.543	2.492	2.457	2.427	2.346	2.229	2.065	1.601	1.349	1.160
355	5.277	4.324	3.548	2.736	2.683	2.573	2.521	2.487	2.457	2.376	2.260	2.097	1.707	1.369	1.178
360	5.327	4.376	3.640	2.766	2.712	2.602	2.551	2.516	2.487	2.406	2.290	2.128	1.812	1.389	1.197
365	5.377	4.428	3.731	2.795											

Section Factor (m ⁻¹)	Required Thickness (mm) for a Design Temperature (°C)														
	350	400	450	500	510	530	539	545	550	563	580	600	650	700	750
50	1.602	1.117	0.817	0.595	0.556	0.481	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472	0.472
55	1.754	1.241	0.908	0.660	0.617	0.534	0.499	0.478	0.472	0.472	0.472	0.472	0.472	0.472	0.472
60	1.905	1.369	1.004	0.744	0.697	0.609	0.571	0.549	0.531	0.490	0.472	0.472	0.472	0.472	0.472
65	2.057	1.496	1.108	0.827	0.778	0.684	0.644	0.620	0.601	0.556	0.505	0.472	0.472	0.472	0.472
70	2.208	1.605	1.209	0.910	0.858	0.759	0.716	0.691	0.670	0.622	0.566	0.508	0.472	0.472	0.472
75	2.360	1.706	1.309	0.994	0.939	0.834	0.789	0.761	0.740	0.688	0.627	0.564	0.472	0.472	0.472
80	2.511	1.807	1.410	1.077	1.019	0.909	0.862	0.834	0.809	0.753	0.687	0.619	0.488	0.472	0.472
85	2.663	1.907	1.510	1.160	1.099	0.983	0.934	0.903	0.879	0.819	0.748	0.674	0.530	0.472	0.472
90	2.810	2.008	1.588	1.244	1.180	1.058	1.007	0.974	0.948	0.885	0.809	0.730	0.572	0.472	0.472
95	2.909	2.109	1.659	1.327	1.260	1.133	1.080	1.045	1.018	0.951	0.870	0.785	0.614	0.496	0.472
100	3.009	2.210	1.730	1.410	1.341	1.208	1.152	1.116	1.087	1.016	0.931	0.840	0.656	0.526	0.472
105	3.108	2.310	1.800	1.494	1.421	1.283	1.225	1.187	1.157	1.082	0.992	0.895	0.696	0.557	0.472
110	3.208	2.411	1.871	1.560	1.502	1.358	1.297	1.258	1.226	1.148	1.053	0.951	0.740	0.588	0.479
115	3.307	2.512	1.942	1.610	1.562	1.433	1.370	1.329	1.296	1.214	1.114	1.006	0.782	0.619	0.502
120	3.407	2.613	2.013	1.660	1.608	1.508	1.443	1.400	1.365	1.280	1.174	1.061	0.824	0.650	0.526
125	3.506	2.713	2.084	1.710	1.654	1.560	1.515	1.471	1.435	1.345	1.235	1.116	0.866	0.680	0.549
130	3.606	2.810	2.155	1.759	1.701	1.599	1.561	1.538	1.504	1.411	1.296	1.172	0.906	0.711	0.572
135	3.706	2.880	2.226	1.809	1.747	1.639	1.598	1.573	1.553	1.477	1.357	1.227	0.950	0.742	0.596
140	3.805	2.951	2.297	1.859	1.793	1.679	1.634	1.607	1.586	1.538	1.418	1.282	0.992	0.773	0.619
145	3.905	3.021	2.367	1.909	1.840	1.718	1.671	1.642	1.620	1.571	1.479	1.338	1.034	0.803	0.642
150	4.004	3.092	2.438	1.959	1.886	1.758	1.708	1.677	1.653	1.603	1.537	1.393	1.076	0.834	0.665
155	4.104	3.162	2.509	2.009	1.932	1.797	1.744	1.712	1.686	1.635	1.569	1.448	1.118	0.865	0.689
160	4.203	3.232	2.580	2.059	1.979	1.837	1.781	1.747	1.719	1.668	1.601	1.503	1.160	0.896	0.712
165	4.303	3.303	2.651	2.109	2.025	1.876	1.818	1.781	1.753	1.700	1.633	1.548	1.202	0.926	0.735
170	4.403	3.373	2.722	2.159	2.071	1.916	1.854	1.814	1.786	1.732	1.664	1.579	1.244	0.957	0.759
175	4.502	3.443	2.793	2.209	2.118	1.955	1.891	1.851	1.819	1.765	1.696	1.611	1.286	0.988	0.782
180	4.602	3.514	2.851	2.259	2.164	1.995	1.928	1.886	1.853	1.797	1.728	1.642	1.328	1.019	0.805
185	4.648	3.584	2.908	2.309	2.210	2.034	1.964	1.921	1.886	1.829	1.760	1.673	1.370	1.049	0.829
190	4.689	3.654	2.965	2.359	2.257	2.074	2.001	1.955	1.919	1.862	1.792	1.705	1.412	1.080	0.852
195	4.730	3.725	3.021	2.409	2.303	2.114	2.037	1.994	1.953	1.894	1.823	1.736	1.454	1.111	0.875
200	4.771	3.795	3.078	2.459	2.350	2.153	2.074	2.025	1.986	1.926	1.855	1.767	1.496	1.142	0.898
205	4.812	3.865	3.135	2.509	2.396	2.193	2.111	2.060	2.019	1.959	1.887	1.799	1.540	1.172	0.922
210	4.853	3.936	3.192	2.559	2.442	2.232	2.147	2.095	2.052	1.991	1.919	1.830	1.616	1.203	0.945
215	4.895	4.006	3.248	2.609	2.489	2.272	2.184	2.128	2.086	2.023	1.951	1.861	1.692	1.234	0.968
220	4.936	4.076	3.305	2.658	2.535	2.311	2.221	2.164	2.119	2.056	1.983	1.893	1.769	1.265	0.992
225	4.977	4.147	3.362	2.708	2.581	2.351	2.257	2.199	2.152	2.088	2.014	1.924	1.845	1.295	1.015
230	5.018	4.217	3.418	2.758	2.628	2.390	2.294	2.234	2.186	2.120	2.046	1.955	1.921	1.326	1.038
235	5.059	4.287	3.475	2.812	2.674	2.430	2.331	2.269	2.219	2.153	2.078	1.997	1.997	1.357	1.062
240	5.100	4.358	3.532	2.884	2.720	2.469	2.367	2.303	2.252	2.185	2.110	2.073	2.073	1.388	1.085
245	5.141	4.428	3.589	2.956	2.767	2.509	2.404	2.338	2.285	2.217	2.149	2.149	2.148	1.418	1.108
250	5.182	4.498	3.645	3.028	2.821	2.549	2.440	2.373	2.319	2.250	2.225	2.225	2.225	1.449	1.131
255	5.224	4.569	3.702	3.100	2.900	2.588	2.477	2.408	2.352	2.301	2.301	2.301	2.301	1.480	1.155
260	5.265	4.628	3.759	3.171	2.978	2.628	2.514	2.444	2.385	2.377	2.377	2.377	2.377	1.511	1.178
265	5.306	4.671	3.816	3.243	3.057	2.667	2.550	2.477	2.433	2.453	2.453	2.453	2.453	1.558	1.201
270	5.347	4.715	3.872	3.315	3.135	2.707	2.587	2.529	2.529	2.529	2.529	2.529	2.529	1.658	1.225
275	5.388	4.758	3.929	3.387	3.213	2.746	2.624	2.605	2.605	2.605	2.605	2.605	2.605	1.758	1.248
280	5.429	4.801	3.986	3.459	3.292	2.786	2.681	2.681	2.681	2.681	2.681	2.681	2.681	1.858	1.271
285	5.470	4.845	4.043	3.531	3.370	2.863	2.757	2.757	2.757	2.757	2.757	2.757	2.757	1.958	1.295
290	5.525	4.888	4.093	3.603	3.449	2.964	2.833	2.833	2.833	2.833	2.833	2.833	2.833	2.057	1.318
295	5.563	4.931	4.156	3.675	3.527	3.064	2.909	2.909	2.909	2.909	2.909	2.909	2.909	2.157	1.341
300	5.604	4.974	4.213	3.747	3.605	3.165	2.986	2.986	2.986	2.986	2.986	2.986	2.986	2.257	1.364
305	5.701	5.018	4.270	3.819	3.684	3.266	3.063	3.063	3.062	3.062	3.062	3.062	3.062	2.357	1.388
310	5.760	5.061	4.326	3.891	3.762	3.366	3.138	3.138	3.138	3.138	3.138	3.138	3.138	2.456	1.411
315	5.818	5.104	4.383	3.963	3.841	3.467	3.214	3.214	3.214	3.214	3.214	3.214	3.214	2.556	1.434
320	5.877	5.148	4.440	4.035	3.919	3.568	3.297	3.290	3.290	3.290	3.290	3.290	3.290	2.656	1.458
325	5.936	5.191	4.497	4.107	3.997	3.668	3.416	3.366	3.366	3.366	3.366	3.366	3.366	2.756	1.481
330	5.995	5.234	4.553	4.179	4.076	3.769	3.535	3.442	3.442	3.442	3.442	3.442	3.442	2.855	1.504
335	6.054	5.278	4.610	4.251	4.154	3.870	3.655	3.518	3.518	3.518	3.518	3.518	3.518	2.955	1.528
340	6.112	5.321	4.697	4.323	4.233	3.970	3.774	3.594	3.594	3.594	3.594	3.594	3.594	3.055	1.654
345	6.171	5.364	4.783	4.395	4.311	4.071	3.893	3.724	3.670	3.670	3.670	3.670	3.670	3.155	1.821
350	6.230	5.408	4.870	4.467	4.390	4.172	4.013	3.862	3.746	3.746	3.746	3.746	3.746	3.255	1.987
355	6.289	5.451	4.957	4.539	4.468	4.272	4.132	4.000	3.845	3.822	3.822	3.822	3.822	3.354	2.154
360	6.347	5.501	5.043	4.612	4.546	4.373	4.251	4.136	4.006	3.898	3.898	3.898	3.898	3.454	2.321
365	6.406	5.564	5.130	4.712	4.629	4.474	4								

Section Factor (m ⁻¹)	Table 16 I-Section / H-Section Columns 90 minutes Required Thickness (mm) for a Design Temperature (°C)														
	350	400	450	500	510	530	539	545	550	563	580	600	650	700	750
50	2.072	1.472	1.097	0.846	0.803	0.721	0.686	0.665	0.649	0.606	0.554	0.495	0.472	0.472	0.472
55	2.271	1.624	1.219	0.940	0.892	0.800	0.762	0.739	0.720	0.673	0.614	0.550	0.472	0.472	0.472
60	2.469	1.775	1.348	1.048	0.997	0.899	0.859	0.833	0.813	0.762	0.699	0.629	0.481	0.472	0.472
65	2.668	1.927	1.477	1.157	1.102	0.999	0.955	0.928	0.906	0.852	0.783	0.708	0.547	0.472	0.472
70	2.836	2.079	1.598	1.266	1.208	1.098	1.052	1.023	0.999	0.941	0.868	0.787	0.613	0.489	0.472
75	2.944	2.231	1.714	1.375	1.313	1.197	1.148	1.117	1.092	1.030	0.952	0.866	0.679	0.543	0.472
80	3.051	2.383	1.830	1.483	1.419	1.296	1.245	1.212	1.186	1.119	1.037	0.945	0.745	0.596	0.472
85	3.159	2.534	1.946	1.581	1.524	1.395	1.342	1.307	1.279	1.209	1.121	1.024	0.811	0.649	0.513
90	3.266	2.686	2.062	1.669	1.609	1.495	1.438	1.401	1.372	1.298	1.205	1.103	0.877	0.702	0.556
95	3.374	2.826	2.178	1.757	1.692	1.579	1.535	1.496	1.465	1.387	1.290	1.182	0.943	0.755	0.598
100	3.481	2.931	2.294	1.845	1.775	1.652	1.604	1.574	1.551	1.476	1.374	1.262	1.009	0.808	0.641
105	3.589	3.035	2.416	1.933	1.858	1.726	1.674	1.641	1.615	1.555	1.459	1.341	1.075	0.862	0.683
110	3.696	3.139	2.526	2.021	1.942	1.800	1.743	1.708	1.680	1.614	1.540	1.420	1.141	0.915	0.726
115	3.804	3.243	2.642	2.108	2.025	1.874	1.813	1.775	1.745	1.674	1.593	1.499	1.207	0.968	0.768
120	3.911	3.347	2.758	2.196	2.108	1.948	1.882	1.842	1.810	1.734	1.646	1.559	1.273	1.021	0.811
125	4.019	3.451	2.854	2.284	2.191	2.022	1.952	1.909	1.875	1.793	1.699	1.605	1.339	1.074	0.853
130	4.126	3.556	2.936	2.372	2.274	2.096	2.022	1.976	1.940	1.853	1.752	1.651	1.405	1.127	0.896
135	4.234	3.660	3.021	2.460	2.357	2.170	2.091	2.043	2.005	1.912	1.805	1.697	1.471	1.181	0.939
140	4.342	3.764	3.105	2.548	2.440	2.244	2.161	2.110	2.070	1.972	1.858	1.742	1.535	1.234	0.981
145	4.449	3.868	3.189	2.636	2.523	2.318	2.230	2.177	2.134	2.031	1.911	1.788	1.568	1.287	1.024
150	4.557	3.972	3.273	2.724	2.606	2.391	2.300	2.244	2.199	2.091	1.964	1.834	1.601	1.340	1.066
155	4.711	4.076	3.356	2.810	2.689	2.465	2.370	2.311	2.264	2.151	2.017	1.880	1.633	1.393	1.109
160	4.913	4.181	3.440	2.880	2.772	2.539	2.439	2.378	2.329	2.210	2.070	1.925	1.666	1.446	1.151
165	5.114	4.285	3.524	2.950	2.845	2.613	2.509	2.445	2.394	2.270	2.123	1.971	1.698	1.500	1.194
170	5.316	4.389	3.606	3.020	2.913	2.687	2.578	2.512	2.459	2.329	2.176	2.017	1.731	1.545	1.237
175	5.495	4.493	3.691	3.090	2.981	2.761	2.648	2.579	2.524	2.389	2.229	2.062	1.763	1.576	1.279
180	5.570	4.597	3.775	3.160	3.049	2.830	2.717	2.646	2.589	2.448	2.282	2.108	1.796	1.607	1.322
185	5.645	4.650	3.859	3.231	3.117	2.894	2.787	2.713	2.653	2.508	2.335	2.154	1.828	1.638	1.364
190	5.721	4.696	3.943	3.301	3.185	2.958	2.852	2.784	2.718	2.567	2.388	2.200	1.861	1.668	1.407
195	5.796	4.742	4.026	3.371	3.253	3.022	2.915	2.846	2.783	2.627	2.441	2.245	1.891	1.699	1.449
200	5.871	4.788	4.110	3.441	3.321	3.086	2.979	2.910	2.849	2.687	2.494	2.291	1.926	1.730	1.492
205	5.947	4.934	4.194	3.511	3.389	3.150	3.043	2.975	2.915	2.746	2.547	2.337	1.959	1.761	1.535
210	6.022	4.879	4.278	3.582	3.457	3.213	3.106	3.040	2.982	2.807	2.600	2.383	1.991	1.792	1.615
215	6.088	4.925	4.361	3.652	3.525	3.277	3.170	3.105	3.048	2.877	2.653	2.428	2.024	1.823	1.696
220	6.173	4.971	4.445	3.722	3.592	3.341	3.233	3.170	3.114	2.947	2.706	2.474	2.056	1.854	1.776
225	6.248	5.017	4.529	3.792	3.660	3.405	3.297	3.235	3.180	3.017	2.759	2.520	2.089	1.885	1.856
230	6.324	5.063	4.611	3.862	3.728	3.469	3.360	3.300	3.246	3.068	2.817	2.566	2.121	1.937	1.937
235	6.399	5.108	4.651	3.932	3.796	3.533	3.424	3.365	3.313	3.158	2.895	2.611	2.154	2.017	2.017
240	6.474	5.154	4.690	4.003	3.864	3.597	3.488	3.430	3.379	3.228	2.973	2.657	2.187	2.098	2.098
245	6.550	5.200	4.729	4.073	3.932	3.660	3.551	3.495	3.445	3.299	3.051	2.703	2.219	2.178	2.178
250	6.625	5.246	4.769	4.143	4.000	3.774	3.615	3.560	3.511	3.369	3.128	2.748	2.259	2.259	2.259
255	6.700	5.292	4.808	4.213	4.068	3.788	3.678	3.625	3.578	3.439	3.207	2.794	2.339	2.339	2.339
260	6.776	5.338	4.848	4.283	4.136	3.852	3.742	3.694	3.644	3.509	3.285	2.881	2.419	2.419	2.419
265	6.851	5.383	4.887	4.354	4.204	3.916	3.806	3.755	3.710	3.580	3.363	2.975	2.500	2.500	2.500
270	6.927	5.429	4.926	4.424	4.271	3.980	3.869	3.820	3.776	3.650	3.442	3.069	2.580	2.580	2.580
275	7.002	5.475	4.966	4.494	4.339	4.044	3.933	3.885	3.843	3.720	3.520	3.162	2.661	2.661	2.661
280	7.077	5.545	5.005	4.564	4.407	4.107	3.996	3.950	3.909	3.791	3.598	3.256	2.741	2.741	2.741
285	7.153	5.618	5.044	4.630	4.475	4.171	4.060	4.015	3.975	3.861	3.676	3.350	2.822	2.822	2.822
290	7.228	5.692	5.084	4.687	4.543	4.235	4.124	4.080	4.041	3.931	3.754	3.444	2.902	2.902	2.902
295	7.303	5.765	5.123	4.744	4.611	4.299	4.187	4.144	4.107	4.001	3.892	3.538	2.982	2.982	2.982
300	7.379	5.839	5.163	4.801	4.675	4.363	4.251	4.209	4.174	4.072	3.910	3.631	3.063	3.063	3.063
305	7.454	5.912	5.202	4.858	4.738	4.427	4.314	4.274	4.240	4.142	3.988	3.725	3.143	3.143	3.143
310	-	5.986	5.241	4.915	4.802	4.491	4.378	4.339	4.306	4.212	4.066	3.819	3.224	3.224	3.224
315	-	6.059	5.281	4.971	4.866	4.555	4.441	4.404	4.372	4.283	4.144	3.913	3.304	3.304	3.304
320	-	6.133	5.320	5.028	4.930	4.611	4.505	4.469	4.439	4.353	4.222	4.007	3.585	3.385	3.385
325	-	6.206	5.359	5.085	4.993	4.707	4.569	4.534	4.505	4.423	4.300	4.100	3.465	3.465	3.465
330	-	6.280	5.399	5.142	5.057	4.793	4.644	4.599	4.571	4.494	4.378	4.194	3.545	3.545	3.545
335	-	6.353	5.438	5.199	5.121	4.879	4.741	4.692	4.651	4.564	4.456	4.288	3.626	3.626	3.626
340	-	6.427	5.478	5.256	5.185	4.965	4.839	4.791	4.751	4.645	4.534	4.382	3.706	3.706	3.706
345	-	6.500	5.558	5.313	5.248	5.051	4.936	4.890	4.851	4.748	4.613	4.476	3.787	3.787	3.787
350	-	6.574	5.642	5.370	5.312	5.137	5.033	4.988	4.951	4.851	4.719	4.570	3.867	3.867	3.867
355	-	6.647	5.726	5.427	5.376	5.223	5.131	5.087	5.051	4.953	4.825	4.672	3.948	3.948	3.948
360	-	6.721	5.810	4.985	4.440	5.308	5.186	5.150	5.056	4.931	4.781	4.159	4.028	4.028	4.028
365	-	6.794	5.894	5.564	5.508	5.394	5.325	5.285	5.250	5.159					

Table 17I-Section / H-Section Columns 105 minutes Required Thickness (mm) for a Design Temperature (°C)														
Section Factor (m ³)	350	400	450	500	510	530	545	550	563	580	600	650	700	750
50	2.542	1.889	1.378	1.097	1.050	0.961	0.923	0.900	0.882	0.835	0.777	0.714	0.572	0.472
55	2.788	2.083	1.531	1.219	1.166	1.067	1.026	1.000	0.979	0.927	0.863	0.793	0.635	0.484
60	2.907	2.276	1.697	1.353	1.297	1.190	1.146	1.118	1.096	1.040	0.970	0.894	0.723	0.561
65	3.019	2.470	1.862	1.487	1.427	1.314	1.267	1.236	1.212	1.152	1.077	0.996	0.811	0.637
70	3.131	2.664	2.028	1.619	1.557	1.437	1.387	1.355	1.329	1.264	1.184	1.097	0.899	0.714
75	3.243	2.834	2.194	1.750	1.681	1.559	1.508	1.473	1.445	1.377	1.291	1.198	0.986	0.790
80	3.355	2.946	2.360	1.881	1.806	1.672	1.618	1.585	1.558	1.489	1.398	1.299	1.074	0.867
85	3.467	3.058	2.526	2.012	1.931	1.785	1.726	1.689	1.660	1.591	1.505	1.400	1.162	0.944
90	3.579	3.171	2.692	2.143	2.056	1.899	1.834	1.793	1.762	1.686	1.597	1.502	1.250	1.020
95	3.691	3.283	2.840	2.274	2.181	2.012	1.941	1.888	1.863	1.780	1.683	1.586	1.338	1.097
100	3.802	3.396	2.954	2.405	2.306	2.126	2.049	2.002	1.965	1.875	1.770	1.663	1.426	1.174
105	3.914	3.508	3.067	2.536	2.431	2.239	2.156	2.106	2.066	1.970	1.856	1.740	1.514	1.250
110	4.026	3.621	3.181	2.667	2.556	2.353	2.264	2.210	2.168	2.064	1.942	1.817	1.577	1.327
115	4.138	3.733	3.295	2.797	2.681	2.466	2.372	2.315	2.269	2.159	2.029	1.894	1.634	1.404
120	4.250	3.846	3.408	2.894	2.805	2.580	2.479	2.419	2.371	2.254	2.115	1.971	1.690	1.480
125	4.362	3.958	3.522	2.990	2.897	2.693	2.587	2.523	2.472	2.348	2.201	2.047	1.747	1.546
130	4.474	4.070	3.636	3.085	2.989	2.805	2.694	2.627	2.574	2.443	2.287	2.124	1.803	1.584
135	4.586	4.183	3.749	3.181	3.082	2.899	2.802	2.732	2.676	2.538	2.374	2.201	1.859	1.623
140	5.129	4.295	3.863	3.277	3.174	2.979	2.887	2.829	2.777	2.632	2.460	2.278	1.916	1.662
145	5.540	4.408	3.977	3.372	3.267	3.066	2.971	2.912	2.864	2.727	2.546	2.355	1.972	1.701
150	5.667	4.520	4.090	3.468	3.359	3.152	3.056	2.995	2.946	2.818	2.632	2.432	2.029	1.740
155	5.794	4.645	4.204	3.563	3.452	3.239	3.141	3.079	3.028	2.897	2.719	2.509	2.085	1.778
160	5.921	4.821	4.318	3.659	3.544	3.326	3.225	3.162	3.110	2.976	2.804	2.585	2.142	1.817
165	6.048	4.996	4.431	3.755	3.637	3.413	3.310	3.245	3.192	3.055	2.880	2.662	2.198	1.856
170	6.175	5.171	4.545	3.850	3.729	3.499	3.395	3.328	3.274	3.134	2.955	2.739	2.254	1.895
175	6.302	5.346	4.633	3.946	3.822	3.586	3.479	3.411	3.356	3.213	3.030	2.815	2.311	1.934
180	6.429	5.504	4.686	4.042	3.914	3.673	3.564	3.495	3.438	3.292	3.105	2.886	2.367	1.972
185	6.556	5.604	4.739	4.137	4.007	3.760	3.649	3.578	3.520	3.371	3.180	2.957	2.424	2.011
190	6.683	5.704	4.793	4.233	4.099	3.847	3.733	3.661	3.602	3.450	3.255	3.028	2.480	2.050
195	6.810	5.803	4.846	4.328	4.192	3.933	3.818	3.744	3.684	3.529	3.330	3.099	2.536	2.089
200	6.937	5.903	4.899	4.424	4.284	4.020	3.903	3.827	3.766	3.405	3.170	2.593	2.128	1.892
205	7.064	6.008	4.953	4.520	4.377	4.107	3.987	3.911	3.848	3.686	3.480	3.242	2.649	2.167
210	7.190	6.102	5.006	4.612	4.469	4.194	4.072	3.994	3.930	3.765	3.556	3.313	2.706	2.205
215	7.317	6.202	5.059	4.656	4.562	4.280	4.157	4.077	4.012	3.844	3.631	3.384	2.762	2.244
220	7.444	6.302	5.112	4.700	4.630	4.367	4.242	4.160	4.094	3.932	3.706	3.455	2.825	2.283
225	-	5.401	5.166	4.745	4.673	4.454	4.326	4.243	4.175	4.002	3.781	3.526	2.901	2.322
230	-	6.501	5.219	4.789	4.716	4.541	4.411	4.327	4.257	4.081	3.856	3.597	2.978	2.361
235	-	6.601	5.272	4.833	4.759	4.619	4.496	4.410	4.339	4.160	3.931	3.668	3.054	2.399
240	-	6.700	5.326	4.877	4.802	4.662	4.580	4.493	4.421	4.239	4.006	3.739	3.130	2.438
245	-	6.800	5.379	4.921	4.844	4.705	4.639	4.576	4.503	4.318	4.081	3.811	3.207	2.477
250	-	6.900	5.432	4.965	4.887	4.748	4.684	4.638	4.585	4.396	4.156	3.882	3.283	2.516
255	-	6.999	5.491	5.009	4.930	4.791	4.729	4.684	4.644	4.475	4.232	3.953	3.360	2.555
260	-	7.099	5.602	5.053	4.973	4.834	4.774	4.731	4.692	4.554	4.307	4.024	3.436	2.993
265	-	7.199	5.714	5.097	5.015	4.877	4.820	4.778	4.740	4.625	4.382	4.095	3.512	2.632
270	-	7.299	5.826	5.141	5.058	4.920	4.865	4.824	4.788	4.678	4.457	4.166	3.589	2.671
275	-	7.398	5.938	5.185	5.101	4.963	4.910	4.871	4.836	4.731	4.532	4.237	3.665	2.710
280	-	7.498	6.050	5.229	5.144	5.006	4.955	4.918	4.884	4.782	4.607	4.308	3.742	2.741
285	-	-	6.162	5.273	5.187	5.049	5.000	4.964	4.932	4.836	4.636	4.379	3.818	2.822
290	-	-	6.274	5.317	5.229	5.091	5.045	5.011	4.980	4.888	4.729	4.451	3.894	2.902
295	-	-	6.385	5.361	5.272	5.138	5.090	5.057	5.028	4.941	4.790	4.522	3.971	3.025
300	-	-	6.497	5.405	5.315	5.178	5.135	5.104	5.076	4.993	4.851	4.593	4.047	3.161
305	-	-	6.609	5.449	5.358	5.221	5.180	5.151	5.124	5.046	4.911	4.668	4.124	3.297
310	-	-	6.721	5.512	5.401	5.264	5.225	5.197	5.173	5.099	4.972	4.744	4.200	3.433
315	-	-	6.833	5.625	5.443	5.307	5.270	5.244	5.221	5.151	5.033	4.820	4.276	3.569
320	-	-	6.945	5.739	5.495	5.349	5.315	5.291	5.269	5.204	5.093	4.896	4.353	3.704
325	-	-	7.056	5.852	5.611	5.392	5.360	5.337	5.317	5.256	5.154	4.973	4.429	3.840
330	-	-	7.168	5.966	5.726	5.435	5.405	5.384	5.365	5.309	5.215	5.049	4.506	3.976
335	-	-	7.280	6.079	5.842	5.476	5.451	5.431	5.413	5.361	5.276	5.125	4.582	4.112
340	-	-	7.392	6.193	5.958	5.588	5.517	5.477	5.461	5.414	5.336	5.201	4.684	4.247
345	-	-	7.504	6.306	6.074	5.704	5.626	5.579	5.543	5.467	5.397	5.278	4.800	4.383
350	-	-	6.420	6.190	5.819	5.736	5.686	5.648	5.556	5.458	5.354	4.917	4.519	3.867
355	-	-	6.533	6.305	5.933	5.846	5.792	5.754	5.660	5.543	5.430	5.034	4.649	3.948
360	-	-	6.647	6.421	6.048	5.955	5.899	5.859	5.763	5.644	5.513	5.150	4.767	4.074
365	-	-	6.760	6.537	6.163	6.065	6.005	5.965	5.867	5.745	5.611	5.267	4.885	4.382
370	-	-	6.874	6.653	6.278	6.175	6.112	6.070	5.970	5.845	5.708	5.384	5.003	4.640
375	-	-	6.987	6.768	6.393	6.284	6.219	6.176	6.074	5.946	5.806	5.495	5.122	4.796
380	-	-	7.101	6.884	6.508	6.394	6.325	6.281	6.177	6.047	5.903	5.582	5.240	4.873
385	-	-	7.214	7.000	6.622	6.504	6.432	6.387	6.281	6.147	6.000	5.670	5.358	4.989
390	-	-	7.328	7.116	6.737	6.614	6.539	6.492	6.385	6.248	6.098	5.757	5.476	5.106
395	-	-	7.442	7.232	6.852	6.723	6.645	6.598	6.488	6.349	6.195	5.844	5.552	5.222
400	-	-	-	-	7.347	6.967	6.833	6.752	6.703	6.592	6.449	6.293	5.931	5.626
405	-	-	-	-	7.463	7.082	6.943	6.858	6.809	6.695	6.550	6.390	6.018	5.701
410	-	-	-	-	7.196	7.052	6.965	6.914	6.799	6.651	6.487	6.105	5.775	5.527
415	-	-	-	-	7.311	7.162	7.072	7.020	6.903	6.752	6.585	6.192	5.849	5.586
420	-	-	-	-	7.426	7.272	7.178	7.125	7.006	6.852	6.682	6.279	5.923	5.645
425	-	-	-	-	-	7.381	7.285	7.231	7.110	6.953	6.780	6.366	5.997	5.704
430	-	-	-	-	-	7.491	7.391	7.336	7.213	7.054	6.877	6.453	6.071	5.763
435	-	-	-	-	-	-	7.498	7.442	7.317	7.154	6.975	6.541	6.146	5.822
440	-	-	-	-	-	-	-	-	-	7.420	7.255	7.072	6.628	6.220
445	-	-	-	-	-	-	-	-	-	7.356	7.169	6.715	6.294	5.940
450	-	-	-	-	-	-	-	-	-	7.456	7.267	6.802	6.368	

The thickness is intumescent only. Results also apply to I/H-section beams exposed on all four sides, limited to a maximum protection thickness of 5.770 mm.

Table 18 I-Section / H-Section Columns 120 minutes
Required Thickness (mm) for a Design Temperature (°C)

Table 18 I-Section / H-Section Columns 120 minutes Required Thickness (mm) for a Design Temperature (°C)																
Section Factor (m ³)	350	400	450	500	510	530	539	545	550	563	580	600	650	700	750	
50	3.308	2.307	1.762	1.349	1.297	1.200	1.161	1.135	1.114	1.064	1.001	0.933	0.781	0.638	0.478	
55	3.455	2.542	1.958	1.499	1.441	1.333	1.289	1.261	1.238	1.182	1.112	1.036	0.867	0.708	0.530	
60	3.602	2.777	2.163	1.672	1.603	1.481	1.434	1.403	1.378	1.317	1.242	1.160	0.976	0.805	0.618	
65	3.749	2.906	2.368	1.850	1.773	1.635	1.580	1.545	1.518	1.453	1.371	1.283	1.085	0.902	0.705	
70	3.896	3.023	2.573	2.027	1.943	1.792	1.729	1.690	1.660	1.587	1.501	1.407	1.194	0.999	0.793	
75	4.043	3.140	2.778	2.205	2.114	1.948	1.879	1.836	1.802	1.721	1.626	1.530	1.303	1.096	0.881	
80	4.190	3.257	2.906	2.382	2.284	2.105	2.028	1.981	1.944	1.854	1.749	1.642	1.413	1.193	0.968	
85	4.337	3.374	3.024	2.560	2.455	2.262	2.177	2.126	2.086	1.988	1.872	1.754	1.522	1.290	1.056	
90	4.484	3.491	3.142	2.737	2.625	2.419	2.327	2.271	2.228	2.121	1.995	1.865	1.611	1.387	1.143	
95	4.635	3.607	3.260	2.877	2.796	2.576	2.476	2.417	2.369	2.255	2.119	1.977	1.698	1.484	1.231	
100	4.991	3.724	3.378	2.996	2.914	2.733	2.625	2.562	2.511	2.388	2.242	2.089	1.785	1.566	1.319	
105	5.325	3.841	3.496	3.115	3.031	2.863	2.775	2.707	2.653	2.522	2.365	2.200	1.872	1.631	1.406	
110	5.592	3.958	3.614	3.234	3.147	2.972	2.889	2.838	2.795	2.655	2.488	2.312	1.959	1.697	1.494	
115	5.802	4.075	3.732	3.353	3.264	3.081	2.995	2.942	2.900	2.789	2.611	2.424	2.046	1.762	1.562	
120	6.011	4.192	3.850	3.472	3.380	3.190	3.102	3.047	3.003	2.891	2.735	2.536	2.133	1.817	1.505	
125	6.221	4.309	3.969	3.591	3.497	3.300	3.208	3.152	3.106	2.990	2.844	2.647	2.219	1.893	1.667	
130	6.430	4.426	4.087	3.710	3.613	3.409	3.315	3.256	3.209	3.089	2.938	2.799	2.306	1.958	1.719	
135	6.639	4.542	4.205	3.829	3.730	3.518	3.421	3.361	3.312	3.188	3.032	2.856	2.393	2.024	1.771	
140	6.849	4.963	4.323	3.948	3.846	3.627	3.528	3.465	3.414	3.287	3.126	2.945	2.480	2.089	1.824	
145	7.058	5.536	4.441	4.067	3.963	3.737	3.634	3.570	3.517	3.385	3.220	3.034	2.567	2.154	1.876	
150	7.267	5.681	4.559	4.186	4.079	3.846	3.741	3.674	3.620	3.484	3.314	3.122	2.654	2.220	1.928	
155	7.477	5.827	4.739	4.305	4.196	3.955	3.847	3.779	3.723	3.583	3.408	3.211	2.741	2.285	1.980	
160	-	5.972	4.965	4.424	4.313	4.064	3.954	3.883	3.826	3.682	3.502	3.299	2.825	2.351	2.033	
165	-	6.117	5.191	4.543	4.429	4.174	4.060	3.988	3.929	3.781	3.596	3.388	2.901	2.416	2.085	
170	-	6.262	5.417	4.641	4.546	4.283	4.167	4.093	4.032	3.880	3.690	3.477	2.977	2.481	2.137	
175	-	6.408	5.579	4.713	4.638	4.392	4.273	4.197	4.135	3.979	3.784	3.565	3.054	2.547	2.189	
180	-	6.553	5.716	4.785	4.700	4.501	4.380	4.302	4.238	4.078	3.878	3.654	3.130	2.612	2.242	
185	-	6.698	5.852	4.856	4.762	4.610	4.486	4.406	4.341	4.177	3.972	3.743	3.206	2.678	2.294	
190	-	6.843	5.989	4.928	4.824	4.666	4.593	4.511	4.444	4.276	4.066	3.831	3.283	2.743	2.346	
195	-	6.988	6.126	5.000	4.886	4.722	4.656	4.613	4.547	4.375	4.160	3.920	3.539	2.809	2.398	
200	-	7.134	6.263	5.071	4.948	4.778	4.710	4.667	4.631	4.474	4.254	4.009	3.435	2.876	2.451	
205	-	7.279	6.400	5.143	5.011	4.834	4.765	4.720	4.684	4.573	4.348	4.097	3.512	2.944	2.503	
210	-	7.424	6.536	5.215	5.073	4.889	4.820	4.774	4.737	4.642	4.442	4.186	3.588	3.012	2.555	
215	-	-	6.673	5.287	5.135	4.945	4.874	4.828	4.790	4.694	4.536	4.275	3.665	3.079	2.608	
220	-	-	6.810	5.358	5.197	5.001	4.929	4.882	4.843	4.745	4.621	4.363	3.741	3.147	2.660	
225	-	-	6.947	5.430	5.259	5.057	4.984	4.936	4.897	4.797	4.670	4.452	3.817	3.215	2.712	
230	-	-	7.083	5.534	5.321	5.113	5.036	4.989	4.950	4.849	4.720	4.540	3.894	3.283	2.764	
235	-	-	7.220	5.717	5.383	5.169	5.093	5.043	5.003	4.900	4.770	4.620	3.970	3.350	2.825	
240	-	-	7.357	5.899	5.445	5.224	5.147	5.097	5.056	4.952	4.820	4.668	4.046	3.418	2.907	
245	-	-	7.494	6.081	5.559	5.280	5.202	5.151	5.109	5.004	4.870	4.716	4.123	3.486	2.988	
250	-	-	6.264	5.742	5.336	5.257	5.205	5.162	5.055	4.919	4.764	4.199	3.533	3.069	-	
255	-	-	6.446	5.924	5.392	5.311	5.259	5.216	5.107	4.969	4.812	4.275	3.621	3.150	-	
260	-	-	6.629	6.107	5.448	5.366	5.312	5.269	5.158	5.019	4.860	4.352	3.689	3.232	-	
265	-	-	6.811	6.290	5.538	5.420	5.366	5.322	5.210	5.069	4.907	4.428	3.757	3.313	-	
270	-	-	6.994	6.473	5.680	5.475	5.420	5.375	5.262	5.119	4.955	4.504	3.824	3.394	-	
275	-	-	7.176	6.656	5.821	5.603	5.474	5.428	5.313	5.168	5.003	4.581	3.892	3.475	-	
280	-	-	7.359	6.838	5.963	5.740	5.601	5.483	5.365	5.218	5.051	4.649	3.960	3.557	-	
285	-	-	-	7.021	6.104	5.877	5.739	5.622	5.417	5.268	5.099	4.711	4.027	3.638	-	
290	-	-	-	7.204	6.246	6.013	5.877	5.761	5.468	5.318	5.147	4.774	4.095	3.719	-	
295	-	-	-	7.387	6.387	6.150	6.015	5.900	5.589	5.368	5.194	4.837	4.163	3.800	-	
300	-	-	-	-	6.529	6.287	6.153	6.040	5.732	5.417	5.242	4.900	4.231	3.882	-	
305	-	-	-	-	6.670	6.424	6.291	6.179	5.876	5.467	5.290	4.962	4.298	3.963	-	
310	-	-	-	-	6.812	6.561	6.429	6.318	6.019	5.590	5.338	5.025	4.366	4.044	-	
315	-	-	-	-	6.953	6.696	6.567	6.457	6.162	5.740	5.386	5.088	4.434	4.126	-	
320	-	-	-	-	7.095	6.835	6.705	6.596	6.305	5.891	5.434	5.151	4.501	4.207	-	
325	-	-	-	-	7.236	6.971	6.843	6.736	6.449	6.041	5.483	5.213	4.569	4.288	-	
330	-	-	-	-	7.378	7.108	6.981	6.875	6.592	6.192	5.646	5.276	4.660	4.369	-	
335	-	-	-	-	7.519	7.245	7.119	7.014	6.735	6.342	5.809	5.339	4.785	4.451	-	
340	-	-	-	-	7.382	7.257	7.153	6.879	6.492	5.972	5.402	4.910	4.532	-		
345	-	-	-	-	7.519	7.395	7.292	7.022	6.643	6.136	5.646	5.035	4.615	-		
350	-	-	-	-	-	-	-	-	7.432	7.165	6.793	6.299	5.582	5.160	4.742	
355	-	-	-	-	-	-	-	-	-	7.308	6.944	6.462	5.719	5.285	4.869	
360	-	-	-	-	-	-	-	-	-	7.452	7.094	6.625	5.856	5.410	4.996	
365	-	-	-	-	-	-	-	-	-	-	7.245	6.788	5.993	5.530	5.123	
370	-	-	-	-	-	-	-	-	-	-	7.395	6.951	6.130	5.642	5.251	
375	-	-	-	-	-	-	-	-	-	-	7.115	6.267	5.755	5.378	-	
380	-	-	-	-	-	-	-	-	-	-	-	7.278	6.404	5.867	5.498	
385	-	-	-	-	-	-	-	-	-	-	-	7.441	6.542	5.980	5.587	
390	-	-	-	-	-	-	-	-	-	-	-	6.679	6.092	5.676	-	
395	-	-	-	-	-	-	-	-	-	-	-	6.816	6.205	5.765	-	
400	-	-	-	-	-	-	-	-	-	-	-	6.953	6.317	5.854	-	
405	-	-	-	-	-	-	-	-	-	-	-	7.090	6.430	5.943	-	
410	-	-	-	-	-	-	-	-	-	-	-	-	7.227	6.542	6.032	
415	-	-	-	-	-	-	-	-	-	-	-	-	7.364	6.655	6.121	
420	-	-	-	-	-	-	-	-	-	-	-	-	7.501	6.768	6.210	
425	-	-	-	-	-	-	-	-	-	-	-	-	6.880	6.299	-	
430	-	-	-	-	-	-	-	-	-	-	-	-	6.993	6.388	-	
435	-	-	-	-	-	-	-	-	-	-	-	-	7.105	6.477	-	
440	-	-	-	-	-	-	-	-	-	-	-	-	-	7.218	6.565	-
445	-	-	-	-	-	-	-	-	-	-	-	-	-	7.330	6.654	-
450	-	-	-	-	-	-	-	-	-	-	-	-	-	7.443	6.743	-
455	-	-	-	-	-	-	-	-	-	-	-	-	-	-	6.832	-
460	-	-	-	-	-	-	-	-	-	-	-	-	-	-	6.921	-
465	-	-	-	-	-	-	-	-	-	-	-	-	-	-	7.010	-
470	-															

Thickness is intumescent only. Results also apply to I/H-section beams exposed on all four sides, limited to a maximum protection thickness of 5.770 mm.

Section Factor (m ⁻¹)	Table 19 I-Section / H-Section Columns 150 minutes Required Thickness (mm) for a Design Temperature (°C)														
	350	400	450	500	510	530	539	545	550	563	580	600	650	700	750
50	4.456	3.576	2.638	2.054	1.971	1.814	1.744	1.700	1.665	1.580	1.477	1.371	1.199	1.041	0.870
55	4.816	3.795	2.823	2.282	2.190	2.016	1.937	1.889	1.850	1.756	1.641	1.523	1.332	1.156	0.966
60	5.177	4.014	3.008	2.534	2.436	2.251	2.165	2.112	2.070	1.968	1.842	1.711	1.484	1.294	1.093
65	5.545	4.233	3.193	2.785	2.682	2.486	2.392	2.335	2.291	2.179	2.044	1.900	1.638	1.432	1.220
70	5.948	4.452	3.378	2.923	2.868	2.721	2.619	2.559	2.511	2.391	2.245	2.089	1.794	1.567	1.347
75	6.352	4.729	3.564	3.052	2.998	2.886	2.827	2.782	2.731	2.603	2.447	2.276	1.950	1.695	1.475
80	6.755	5.155	3.749	3.182	3.127	3.015	2.955	2.919	2.888	2.809	2.648	2.467	2.106	1.823	1.593
85	7.158	5.553	3.934	3.312	3.256	3.143	3.084	3.047	3.017	2.937	2.831	2.656	2.262	1.950	1.704
90	-	5.863	4.119	3.441	3.386	3.272	3.213	3.176	3.145	3.064	2.957	2.829	2.418	2.078	1.815
95	-	6.172	4.304	3.571	3.515	3.401	3.342	3.305	3.273	3.191	3.082	2.951	2.574	2.206	1.926
100	-	6.481	4.489	3.701	3.645	3.530	3.471	3.433	3.402	3.319	3.208	3.073	2.730	2.334	2.037
105	-	6.790	4.912	3.881	3.774	3.658	3.600	3.562	3.530	3.446	3.333	3.195	2.859	2.461	2.148
110	-	7.100	5.561	3.960	3.904	3.787	3.728	3.690	3.658	3.573	3.458	3.317	2.966	2.589	2.258
115	-	7.409	5.790	4.090	4.033	3.916	3.857	3.819	3.787	3.701	3.584	3.439	3.072	2.717	2.369
120	-	-	6.018	4.220	4.163	4.045	3.986	3.948	3.915	3.828	3.709	3.561	3.179	2.832	2.480
125	-	-	6.247	4.349	4.292	4.174	4.115	4.076	4.043	3.955	3.835	3.683	3.285	2.923	2.591
130	-	-	6.476	4.479	4.421	4.302	4.244	4.205	4.172	4.083	3.960	3.805	3.392	3.014	2.702
135	-	-	6.704	4.609	4.551	4.431	4.373	4.334	4.300	4.210	4.086	3.927	3.498	3.105	2.809
140	-	-	6.933	5.533	5.111	4.560	4.501	4.462	4.428	4.337	4.211	4.049	3.605	3.196	2.882
145	-	-	7.162	5.707	5.584	4.935	4.677	4.591	4.557	4.465	4.337	4.171	3.711	3.287	2.955
150	-	-	7.390	5.882	5.756	5.469	5.103	4.924	4.804	4.592	4.462	4.293	3.828	3.378	3.028
155	-	-	6.056	5.928	5.649	5.501	5.292	5.136	4.816	4.587	4.415	3.924	3.470	3.102	-
160	-	-	6.230	6.100	5.821	5.676	5.567	5.468	5.056	4.745	4.537	4.031	3.561	3.175	-
165	-	-	6.404	6.271	5.994	5.851	5.745	5.654	5.295	4.911	4.657	4.137	3.652	3.248	-
170	-	-	6.578	6.443	6.166	6.025	5.922	5.834	5.524	5.076	4.774	4.244	3.743	3.321	-
175	-	-	6.752	6.615	6.338	6.200	6.100	6.014	5.718	5.241	4.891	4.350	3.834	3.394	-
180	-	-	6.927	6.787	6.510	6.375	6.277	6.194	5.912	5.406	5.008	4.457	3.925	3.468	-
185	-	-	7.101	6.959	6.683	6.550	6.455	6.374	6.105	5.605	5.125	4.563	4.016	3.541	-
190	-	-	7.275	7.131	6.855	6.724	6.632	6.553	6.299	5.832	5.242	4.736	4.107	3.614	-
195	-	-	7.449	7.302	7.027	6.899	6.810	6.733	6.493	6.059	5.359	4.960	4.198	3.687	-
200	-	-	-	7.474	7.199	7.074	6.987	6.913	6.686	6.286	5.476	5.184	4.289	3.760	-
205	-	-	-	-	7.372	7.249	7.165	7.093	6.880	6.513	5.772	5.407	4.380	3.834	-
210	-	-	-	-	-	7.424	7.342	7.273	7.074	6.740	6.076	5.631	4.471	3.907	-
215	-	-	-	-	-	-	7.520	7.453	7.267	6.967	6.380	5.855	4.562	3.980	-
220	-	-	-	-	-	-	-	7.461	7.195	6.684	6.079	5.637	4.053	-	-
225	-	-	-	-	-	-	-	-	7.422	6.988	6.302	4.695	4.126	-	-
230	-	-	-	-	-	-	-	-	-	7.292	6.526	4.753	4.200	-	-
235	-	-	-	-	-	-	-	-	-	-	6.750	4.811	4.273	-	-
240	-	-	-	-	-	-	-	-	-	-	6.974	4.869	4.346	-	-
245	-	-	-	-	-	-	-	-	-	-	-	7.198	4.926	4.419	-
250	-	-	-	-	-	-	-	-	-	-	-	-	7.421	4.984	4.492
255	-	-	-	-	-	-	-	-	-	-	-	-	5.042	4.566	-
260	-	-	-	-	-	-	-	-	-	-	-	-	5.100	4.632	-
265	-	-	-	-	-	-	-	-	-	-	-	-	5.158	4.689	-
270	-	-	-	-	-	-	-	-	-	-	-	-	5.215	4.746	-
275	-	-	-	-	-	-	-	-	-	-	-	-	5.273	4.803	-
280	-	-	-	-	-	-	-	-	-	-	-	-	5.331	4.860	-
285	-	-	-	-	-	-	-	-	-	-	-	-	5.389	4.917	-
290	-	-	-	-	-	-	-	-	-	-	-	-	5.446	4.974	-
295	-	-	-	-	-	-	-	-	-	-	-	-	5.568	5.031	-
300	-	-	-	-	-	-	-	-	-	-	-	-	5.784	5.088	-
305	-	-	-	-	-	-	-	-	-	-	-	-	6.001	5.145	-
310	-	-	-	-	-	-	-	-	-	-	-	-	6.218	5.202	-
315	-	-	-	-	-	-	-	-	-	-	-	-	6.434	5.259	-
320	-	-	-	-	-	-	-	-	-	-	-	-	6.651	5.316	-
325	-	-	-	-	-	-	-	-	-	-	-	-	6.867	5.373	-
330	-	-	-	-	-	-	-	-	-	-	-	-	7.084	5.430	-
335	-	-	-	-	-	-	-	-	-	-	-	-	7.301	5.509	-
340	-	-	-	-	-	-	-	-	-	-	-	-	7.517	5.795	-
345	-	-	-	-	-	-	-	-	-	-	-	-	-	6.081	-
350	-	-	-	-	-	-	-	-	-	-	-	-	-	6.368	-
355	-	-	-	-	-	-	-	-	-	-	-	-	-	6.654	-
360	-	-	-	-	-	-	-	-	-	-	-	-	-	6.940	-
365	-	-	-	-	-	-	-	-	-	-	-	-	-	7.227	-
370	-	-	-	-	-	-	-	-	-	-	-	-	-	7.513	-
375	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
380	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
385	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
390	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
395	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
400	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
405	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
410	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
415	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
420	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
425	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
430	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
435	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
440	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
445	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
450	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
455	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
460	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
465	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
470	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
475	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Thickness is intumescent only. Results only apply to I/H-section columns exposed on all four sides.

Table 20 Circular Hollow Columns 15 minutes
 Required Thickness (mm) for a Design Temperature (°C)

Section Factor (m-1)	350	400	450	500	512	515	520	521	547	550	600	650	700	750
50	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
55	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
60	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
65	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
70	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
75	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
80	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
85	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
90	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
95	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
100	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
105	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
110	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
115	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
120	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
125	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
130	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
135	0.387	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
140	0.413	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
145	0.439	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
150	0.464	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
155	0.490	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
160	0.516	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
165	0.541	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
170	0.567	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
175	0.593	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
180	0.619	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
185	0.644	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
190	0.670	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
195	0.696	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
200	0.721	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
205	0.747	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
210	0.773	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
215	0.798	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
220	0.824	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
225	0.850	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
230	0.875	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
235	0.901	0.384	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
240	0.927	0.409	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
245	0.953	0.434	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
250	0.978	0.460	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
255	1.004	0.485	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
260	1.030	0.511	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
265	1.055	0.536	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
270	1.081	0.561	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
275	1.107	0.587	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
280	1.132	0.612	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
285	1.158	0.638	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
290	1.184	0.663	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
295	1.209	0.689	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
300	1.235	0.714	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
305	1.261	0.739	0.373	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
310	1.286	0.765	0.396	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
315	1.312	0.790	0.419	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
320	1.338	0.816	0.442	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
325	1.364	0.841	0.465	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
330	1.389	0.866	0.488	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365

Thickness is intumescent only.

Issued: 30 March 2023

This certificate is the property of Jensen Hughes Fire Testing Pty Ltd

Valid to: 30 March 2028

Page 24 of 54

Table 21 Circular Hollow Columns 20 minutes
 Required Thickness (mm) for a Design Temperature (°C)

Section Factor (m-1)	350	400	450	500	512	515	520	521	547	550	600	650	700	750
50	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
55	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
60	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
65	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
70	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
75	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
80	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
85	0.383	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
90	0.416	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
95	0.449	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
100	0.481	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
105	0.514	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
110	0.547	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
115	0.580	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
120	0.613	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
125	0.646	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
130	0.679	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
135	0.712	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
140	0.745	0.376	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
145	0.778	0.407	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
150	0.811	0.438	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
155	0.844	0.469	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
160	0.877	0.500	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
165	0.910	0.530	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
170	0.943	0.561	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
175	0.976	0.592	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
180	1.008	0.623	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
185	1.041	0.654	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
190	1.074	0.684	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
195	1.107	0.715	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
200	1.140	0.746	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
205	1.173	0.777	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
210	1.206	0.808	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
215	1.239	0.838	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
220	1.272	0.869	0.373	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
225	1.305	0.900	0.405	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
230	1.338	0.931	0.437	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
235	1.371	0.962	0.469	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
240	1.404	0.992	0.501	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
245	1.437	1.023	0.533	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
250	1.470	1.054	0.565	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
255	1.502	1.085	0.597	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
260	1.535	1.116	0.628	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
265	1.568	1.146	0.660	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
270	1.601	1.177	0.692	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
275	1.634	1.208	0.724	0.420	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
280	1.667	1.239	0.756	0.510	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
285	1.700	1.270	0.788	0.599	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
290	1.733	1.300	0.820	0.688	0.430	0.404	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
295	1.766	1.331	0.852	0.778	0.526	0.502	0.380	0.365	0.365	0.365	0.365	0.365	0.365	0.365
300	1.799	1.362	0.883	0.867	0.621	0.600	0.481	0.456	0.365	0.365	0.365	0.365	0.365	0.365
305	1.832	1.393	0.956	0.956	0.717	0.698	0.582	0.558	0.365	0.365	0.365	0.365	0.365	0.365
310	1.865	1.424	1.046	1.046	0.813	0.796	0.682	0.660	0.365	0.365	0.365	0.365	0.365	0.365
315	1.898	1.454	1.135	1.135	0.909	0.894	0.783	0.761	0.365	0.365	0.365	0.365	0.365	0.365
320	1.931	1.485	1.224	1.224	1.004	0.992	0.884	0.863	0.365	0.365	0.365	0.365	0.365	0.365
325	1.964	1.516	1.314	1.314	1.100	1.090	0.985	0.964	0.365	0.365	0.365	0.365	0.365	0.365
330	1.996	1.547	1.403	1.403	1.196	1.188	1.086	1.066	0.371	0.365	0.365	0.365	0.365	0.365

Thickness is intumescent only.

Issued: 30 March 2023

This certificate is the property of Jensen Hughes Fire Testing Pty Ltd

Valid to: 30 March 2028

Page 25 of 54

Table 22 Circular Hollow Columns 30 minutes
 Required Thickness (mm) for a Design Temperature (°C)

Section Factor (m-1)	350	400	450	500	512	515	520	521	547	550	600	650	700	750
50	0.388	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
55	0.461	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
60	0.533	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
65	0.605	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
70	0.678	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
75	0.750	0.390	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
80	0.822	0.440	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
85	0.895	0.489	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
90	0.967	0.539	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
95	1.040	0.588	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
100	1.112	0.638	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
105	1.184	0.688	0.394	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
110	1.257	0.737	0.435	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
115	1.329	0.787	0.475	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
120	1.401	0.836	0.515	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
125	1.474	0.886	0.555	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
130	1.546	0.935	0.596	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
135	1.618	0.985	0.636	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
140	1.691	1.034	0.676	0.382	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
145	1.763	1.084	0.716	0.498	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
150	1.835	1.134	0.757	0.614	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
155	1.908	1.183	0.797	0.730	0.484	0.465	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
160	1.980	1.233	0.846	0.846	0.609	0.593	0.473	0.448	0.365	0.365	0.365	0.365	0.365	0.365
165	2.041	1.282	0.962	0.962	0.734	0.721	0.606	0.582	0.365	0.365	0.365	0.365	0.365	0.365
170	2.087	1.332	1.078	1.078	0.860	0.849	0.738	0.715	0.365	0.365	0.365	0.365	0.365	0.365
175	2.132	1.381	1.194	1.194	0.985	0.977	0.871	0.849	0.365	0.365	0.365	0.365	0.365	0.365
180	2.177	1.431	1.310	1.310	1.110	1.105	1.003	0.982	0.365	0.365	0.365	0.365	0.365	0.365
185	2.223	1.480	1.425	1.425	1.235	1.233	1.136	1.116	0.365	0.365	0.365	0.365	0.365	0.365
190	2.268	1.541	1.541	1.541	1.361	1.361	1.269	1.249	0.511	0.383	0.365	0.365	0.365	0.365
195	2.314	1.657	1.657	1.657	1.489	1.489	1.401	1.383	0.676	0.554	0.365	0.365	0.365	0.365
200	2.359	1.773	1.773	1.773	1.617	1.617	1.534	1.516	0.842	0.725	0.365	0.365	0.365	0.365
205	2.404	1.889	1.889	1.889	1.745	1.745	1.666	1.650	1.008	0.895	0.365	0.365	0.365	0.365
210	2.450	2.005	2.005	2.005	1.873	1.873	1.799	1.783	1.173	1.066	0.365	0.365	0.365	0.365
215	2.495	2.121	2.121	2.121	2.001	2.001	1.931	1.917	1.339	1.237	0.365	0.365	0.365	0.365
220	2.541	2.237	2.237	2.237	2.129	2.129	2.064	2.050	1.505	1.407	0.365	0.365	0.365	0.365
225	2.586	2.353	2.353	2.353	2.257	2.257	2.196	2.184	1.670	1.578	0.365	0.365	0.365	0.365
230	2.632	2.469	2.469	2.469	2.385	2.385	2.329	2.318	1.836	1.749	0.365	0.365	0.365	0.365
235	2.677	2.585	2.585	2.585	2.513	2.513	2.462	2.451	2.002	1.920	0.365	0.365	0.365	0.365
240	2.722	2.700	2.700	2.700	2.641	2.641	2.594	2.585	2.167	2.090	0.365	0.365	0.365	0.365
245	2.816	2.816	2.816	2.816	2.769	2.769	2.727	2.718	2.333	2.261	0.613	0.365	0.365	0.365
250	2.932	2.932	2.932	2.932	2.897	2.897	2.859	2.852	2.499	2.432	0.861	0.365	0.365	0.365
255	3.048	3.048	3.048	3.048	3.025	3.025	2.992	2.985	2.664	2.602	1.110	0.365	0.365	0.365
260	3.164	3.164	3.164	3.164	3.153	3.153	3.124	3.119	2.830	2.773	1.358	0.365	0.365	0.365
265	3.281	3.281	3.281	3.281	3.281	3.281	3.257	3.252	2.996	2.944	1.607	0.365	0.365	0.365
270	3.409	3.409	3.409	3.409	3.409	3.409	3.390	3.386	3.161	3.114	1.855	0.365	0.365	0.365
275	3.537	3.537	3.537	3.537	3.537	3.537	3.522	3.519	3.327	3.285	2.104	0.365	0.365	0.365
280	3.665	3.665	3.665	3.665	3.665	3.665	3.655	3.653	3.492	3.456	2.352	0.365	0.365	0.365
285	3.793	3.793	3.793	3.793	3.793	3.793	3.787	3.786	3.658	3.626	2.601	0.377	0.365	0.365
290	3.920	3.920	3.920	3.920	3.920	3.920	3.920	3.920	3.824	3.797	2.850	0.616	0.365	0.365
295	4.053	4.053	4.053	4.053	4.053	4.053	4.053	4.053	3.989	3.968	3.098	0.854	0.365	0.365
300	4.187	4.187	4.187	4.187	4.187	4.187	4.187	4.187	4.155	4.138	3.347	1.093	0.365	0.365
305	4.321	4.321	4.321	4.321	4.321	4.321	4.321	4.321	4.321	4.309	3.595	1.332	0.365	0.365
310	4.455	4.455	4.455	4.455	4.455	4.455	4.455	4.455	4.455	4.454	3.844	1.571	0.365	0.365
315	4.487	4.487	4.487	4.487	4.487	4.487	4.487	4.487	4.487	4.485	4.092	1.809	0.365	0.365
320	4.521	4.521	4.521	4.521	4.521	4.521	4.521	4.521	4.519	4.516	4.341	2.048	0.365	0.365
325	4.557	4.557	4.557	4.557	4.557	4.557	4.557	4.557	4.551	4.548	4.463	2.287	0.365	0.365
330	4.593	4.593	4.593	4.593	4.593	4.593	4.593	4.593	4.582	4.579	4.488	2.526	0.365	0.365

Thickness is intumescent only.

Issued: 30 March 2023

This certificate is the property of Jensen Hughes Fire Testing Pty Ltd

Valid to: 30 March 2028

Page 26 of 54

Table 23 Circular Hollow Columns 45 minutes
 Required Thickness (mm) for a Design Temperature (°C)

Section Factor (m-1)	350	400	450	500	512	515	520	521	547	550	600	650	700	750
50	1.051	0.560	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
55	1.194	0.675	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
60	1.338	0.790	0.421	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
65	1.481	0.906	0.514	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
70	1.624	1.021	0.607	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
75	1.767	1.137	0.699	0.430	0.375	0.373	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
80	1.911	1.252	0.792	0.502	0.444	0.441	0.419	0.414	0.365	0.365	0.365	0.365	0.365	0.365
85	2.061	1.367	0.885	0.575	0.513	0.510	0.486	0.481	0.367	0.365	0.365	0.365	0.365	0.365
90	2.237	1.483	0.978	0.648	0.581	0.579	0.553	0.548	0.427	0.413	0.365	0.365	0.365	0.365
95	2.412	1.598	1.070	0.720	0.650	0.648	0.620	0.615	0.486	0.472	0.365	0.365	0.365	0.365
100	2.588	1.713	1.163	0.793	0.719	0.716	0.688	0.682	0.546	0.531	0.365	0.365	0.365	0.365
105	2.763	1.829	1.256	0.866	0.787	0.785	0.755	0.749	0.606	0.591	0.365	0.365	0.365	0.365
110	2.939	1.944	1.348	0.939	0.856	0.854	0.822	0.816	0.666	0.650	0.425	0.365	0.365	0.365
115	3.115	2.057	1.441	1.011	0.925	0.922	0.889	0.882	0.726	0.709	0.553	0.365	0.365	0.365
120	3.290	2.164	1.534	1.084	0.993	0.991	0.956	0.949	0.786	0.768	0.682	0.365	0.365	0.365
125	3.466	2.270	1.626	1.157	1.062	1.060	1.023	1.016	0.846	0.827	0.810	0.365	0.365	0.365
130	3.559	2.377	1.719	1.229	1.131	1.129	1.091	1.083	0.939	0.939	0.939	0.365	0.365	0.365
135	3.599	2.484	1.812	1.302	1.199	1.197	1.158	1.150	1.068	1.068	1.068	0.398	0.365	0.365
140	3.639	2.591	1.904	1.375	1.268	1.266	1.225	1.217	1.196	1.196	1.196	0.541	0.365	0.365
145	3.680	2.697	1.997	1.447	1.337	1.335	1.325	1.325	1.325	1.325	1.325	0.684	0.365	0.365
150	3.720	2.804	2.105	1.520	1.453	1.453	1.453	1.453	1.453	1.453	1.453	0.827	0.365	0.365
155	3.760	2.911	2.219	1.593	1.582	1.582	1.582	1.582	1.582	1.582	1.582	0.969	0.365	0.365
160	3.800	3.018	2.333	1.710	1.710	1.710	1.710	1.710	1.710	1.710	1.710	1.112	0.365	0.365
165	3.840	3.125	2.447	1.839	1.839	1.839	1.839	1.839	1.839	1.839	1.839	1.255	0.365	0.365
170	3.880	3.231	2.560	1.967	1.967	1.967	1.967	1.967	1.967	1.967	1.967	1.397	0.419	0.365
175	3.920	3.338	2.674	2.096	2.096	2.096	2.096	2.096	2.096	2.096	2.096	1.540	0.570	0.365
180	3.960	3.445	2.788	2.224	2.224	2.224	2.224	2.224	2.224	2.224	2.224	1.683	0.722	0.365
185	4.000	3.546	2.902	2.353	2.353	2.353	2.353	2.353	2.353	2.353	2.353	1.826	0.874	0.365
190	4.041	3.620	3.016	2.482	2.482	2.482	2.482	2.482	2.482	2.482	2.482	1.968	1.025	0.365
195	4.081	3.694	3.129	2.610	2.610	2.610	2.610	2.610	2.610	2.610	2.610	2.111	1.177	0.365
200	4.121	3.768	3.243	2.739	2.739	2.739	2.739	2.739	2.739	2.739	2.739	2.254	1.329	0.365
205	4.161	3.841	3.357	2.867	2.867	2.867	2.867	2.867	2.867	2.867	2.867	2.397	1.480	0.365
210	4.201	3.915	3.471	2.996	2.996	2.996	2.996	2.996	2.996	2.996	2.996	2.539	1.632	0.365
215	4.241	3.989	3.584	3.124	3.124	3.124	3.124	3.124	3.124	3.124	3.124	2.682	1.784	0.365
220	4.281	4.062	3.698	3.253	3.253	3.253	3.253	3.253	3.253	3.253	3.253	2.825	1.936	0.365
225	4.321	4.136	3.812	3.392	3.381	3.381	3.381	3.381	3.381	3.381	3.381	2.968	2.087	0.365
230	4.361	4.210	3.926	3.561	3.510	3.510	3.510	3.510	3.510	3.510	3.510	3.110	2.239	0.365
235	4.401	4.284	4.040	3.730	3.638	3.638	3.638	3.638	3.638	3.638	3.638	3.253	2.391	0.365
240	4.442	4.357	4.153	3.900	3.797	3.797	3.767	3.767	3.767	3.767	3.767	3.396	2.542	0.398
245	4.647	4.431	4.267	4.069	3.994	3.994	3.946	3.935	3.896	3.896	3.896	3.539	2.694	0.524
250	4.884	4.538	4.381	4.238	4.192	4.192	4.156	4.149	4.024	4.024	4.024	3.681	2.846	0.651
255	5.120	4.655	4.519	4.408	4.389	4.389	4.367	4.363	4.153	4.153	4.153	3.824	2.997	0.777
260	5.357	4.772	4.692	4.531	4.518	4.518	4.507	4.505	4.456	4.456	4.281	3.967	3.149	0.903
265	5.594	4.888	4.865	4.641	4.618	4.618	4.604	4.601	4.539	4.532	4.410	4.109	3.301	1.030
270	5.831	5.039	5.039	4.750	4.718	4.718	4.700	4.697	4.623	4.614	4.493	4.252	3.453	1.156
275	6.060	5.212	5.212	4.859	4.818	4.818	4.797	4.793	4.706	4.696	4.557	4.395	3.604	1.282
280	6.185	5.385	5.385	4.969	4.918	4.918	4.893	4.889	4.790	4.778	4.621	4.479	3.756	1.409
285	6.311	5.558	5.558	5.078	5.018	5.018	4.990	4.984	4.873	4.859	4.684	4.527	3.908	1.535
290	6.437	5.731	5.731	5.188	5.118	5.118	5.086	5.080	4.957	4.941	4.748	4.576	4.059	1.661
295	6.562	5.904	5.904	5.297	5.218	5.218	5.183	5.176	5.040	5.023	4.812	4.625	4.211	1.788
300	6.688	6.061	6.061	5.406	5.318	5.318	5.279	5.272	5.123	5.105	4.876	4.673	4.363	1.914
305	6.813	6.123	6.123	5.516	5.418	5.418	5.376	5.368	5.207	5.187	4.940	4.722	4.464	2.040
310	6.939	6.186	6.186	5.625	5.518	5.518	5.472	5.463	5.290	5.268	5.004	4.771	4.502	2.167
315	7.065	6.248	6.248	5.734	5.618	5.618	5.569	5.559	5.374	5.350	5.068	4.820	4.539	2.293
320	7.190	6.311	6.311	5.844	5.718	5.718	5.665	5.655	5.457	5.432	5.131	4.868	4.577	2.419
325	7.316	6.374	6.374	5.953	5.818	5.818	5.762	5.751	5.540	5.514	5.195	4.917	4.614	2.546
330	7.442	6.436	6.436	6.057	5.918	5.918	5.858	5.847	5.624	5.595	5.259	4.966	4.652	2.672

Thickness is intumescent only.

Issued: 30 March 2023

This certificate is the property of Jensen Hughes Fire Testing Pty Ltd

Valid to: 30 March 2028

Page 27 of 54

Table 24 Circular Hollow Columns 60 minutes
 Required Thickness (mm) for a Design Temperature (°C)

Section Factor (m-1)	350	400	450	500	512	515	520	521	547	550	600	650	700	750
50	1.741	1.153	0.719	0.444	0.390	0.388	0.365	0.365	0.365	0.365	0.365	0.365	0.365	0.365
55	1.958	1.332	0.868	0.546	0.481	0.479	0.455	0.450	0.365	0.365	0.365	0.365	0.365	0.365
60	2.313	1.511	1.018	0.670	0.600	0.597	0.571	0.566	0.449	0.437	0.365	0.365	0.365	0.365
65	2.727	1.690	1.168	0.793	0.718	0.716	0.687	0.682	0.555	0.541	0.365	0.365	0.365	0.365
70	3.140	1.870	1.317	0.917	0.836	0.834	0.803	0.798	0.661	0.646	0.430	0.365	0.365	0.365
75	3.537	2.067	1.467	1.040	0.954	0.952	0.920	0.913	0.766	0.750	0.519	0.365	0.365	0.365
80	3.578	2.365	1.617	1.164	1.073	1.071	1.036	1.029	0.872	0.855	0.608	0.394	0.365	0.365
85	3.618	2.662	1.766	1.288	1.191	1.189	1.152	1.145	0.978	0.960	0.697	0.469	0.365	0.365
90	3.659	2.960	1.916	1.411	1.309	1.307	1.268	1.261	1.083	1.064	0.786	0.545	0.365	0.365
95	3.700	3.258	2.062	1.535	1.427	1.425	1.384	1.376	1.189	1.169	0.875	0.620	0.399	0.365
100	3.741	3.538	2.197	1.658	1.546	1.544	1.501	1.492	1.295	1.274	0.964	0.696	0.463	0.365
105	3.782	3.583	2.333	1.782	1.664	1.662	1.617	1.608	1.400	1.378	1.053	0.771	0.526	0.365
110	3.822	3.628	2.468	1.906	1.782	1.780	1.733	1.724	1.506	1.483	1.142	0.847	0.589	0.365
115	3.863	3.674	2.604	2.027	1.901	1.899	1.849	1.839	1.612	1.588	1.231	0.923	0.653	0.365
120	3.904	3.719	2.739	2.119	2.019	2.017	1.965	1.955	1.717	1.692	1.320	0.998	0.716	0.365
125	3.945	3.764	2.875	2.210	2.102	2.101	2.063	2.055	1.823	1.797	1.409	1.074	0.779	0.394
130	3.985	3.809	3.010	2.301	2.185	2.184	2.142	2.134	1.928	1.901	1.498	1.149	0.843	0.448
135	4.026	3.854	3.146	2.392	2.268	2.267	2.222	2.213	2.037	2.006	1.587	1.225	0.906	0.502
140	4.067	3.899	3.281	2.484	2.350	2.350	2.302	2.292	2.170	2.136	1.676	1.301	0.969	0.557
145	4.108	3.945	3.417	2.575	2.433	2.433	2.381	2.371	2.302	2.269	1.765	1.376	1.033	0.611
150	4.149	3.990	3.545	2.666	2.516	2.516	2.461	2.450	2.435	2.403	1.854	1.452	1.096	0.665
155	4.189	4.035	3.618	2.757	2.599	2.599	2.568	2.568	2.537	2.537	1.943	1.527	1.159	0.719
160	4.230	4.080	3.691	2.849	2.700	2.700	2.700	2.700	2.671	2.671	1.603	1.223	0.773	
165	4.271	4.125	3.765	2.940	2.833	2.833	2.833	2.833	2.833	2.805	2.200	1.678	1.286	0.827
170	4.312	4.170	3.838	3.031	2.966	2.966	2.966	2.966	2.966	2.939	2.361	1.754	1.349	0.881
175	4.353	4.216	3.911	3.122	3.098	3.098	3.098	3.098	3.098	3.073	2.522	1.830	1.413	0.936
180	4.393	4.261	3.985	3.231	3.231	3.231	3.231	3.231	3.231	3.206	2.683	1.905	1.476	0.990
185	4.434	4.306	4.058	3.363	3.363	3.363	3.363	3.363	3.363	3.340	2.844	1.981	1.539	1.044
190	4.464	4.351	4.131	3.496	3.496	3.496	3.496	3.496	3.474	3.004	2.117	1.603	1.098	
195	4.490	4.396	4.205	3.629	3.629	3.629	3.629	3.629	3.629	3.608	3.165	2.328	1.666	1.152
200	5.252	4.442	4.278	3.761	3.761	3.761	3.761	3.761	3.761	3.742	3.326	2.538	1.729	1.206
205	5.555	4.624	4.352	3.894	3.894	3.894	3.894	3.894	3.894	3.876	3.487	2.748	1.793	1.261
210	5.858	4.830	4.425	4.052	4.027	4.027	4.027	4.027	4.027	4.010	3.648	2.958	1.856	1.315
215	6.126	5.036	4.691	4.260	4.159	4.159	4.159	4.159	4.159	4.143	3.809	3.168	1.919	1.369
220	6.333	5.242	5.044	4.474	4.359	4.359	4.292	4.292	4.277	3.970	3.378	1.983	1.423	
225	6.541	5.448	5.398	4.737	4.649	4.649	4.607	4.599	4.424	4.411	4.130	3.588	2.128	1.477
230	6.748	5.751	5.751	5.000	4.895	4.895	4.847	4.838	4.630	4.606	4.291	3.798	2.406	1.531
235	6.956	6.065	6.065	5.264	5.142	5.142	5.088	5.077	4.851	4.825	4.452	4.008	2.684	1.585
240	7.163	6.160	6.160	5.527	5.388	5.388	5.328	5.317	5.073	5.043	4.617	4.218	2.963	1.640
245	7.371	6.255	6.255	5.790	5.635	5.635	5.569	5.556	5.294	5.262	4.783	4.428	3.241	1.694
250	7.578	6.360	6.350	6.052	5.882	5.882	5.809	5.795	5.516	5.480	4.948	4.555	3.520	1.748
255	7.786	6.509	6.444	6.135	6.076	6.076	6.050	6.035	5.737	5.699	5.113	4.673	3.798	1.802
260	7.993	6.658	6.539	6.218	6.157	6.157	6.131	6.125	5.959	5.917	5.278	4.791	4.076	1.856
265	8.201	6.806	6.634	6.302	6.238	6.238	6.210	6.205	6.094	6.080	5.444	4.908	4.355	1.910
270	8.408	6.955	6.729	6.385	6.319	6.319	6.290	6.285	6.169	6.154	5.609	5.026	4.507	1.965
275	-	7.104	6.823	6.469	6.400	6.400	6.370	6.364	6.244	6.228	5.774	5.144	4.596	2.019
280	-	7.253	6.918	6.552	6.481	6.481	6.450	6.444	6.318	6.301	5.939	5.262	4.685	2.869
285	-	7.402	7.013	6.635	6.562	6.562	6.530	6.524	6.393	6.375	6.072	5.380	4.774	3.771
290	-	7.551	7.108	6.719	6.643	6.643	6.610	6.604	6.467	6.449	6.138	5.498	4.863	4.464
295	-	7.700	7.202	6.802	6.724	6.724	6.690	6.683	6.542	6.523	6.204	5.616	4.952	4.528
300	-	7.849	7.297	6.886	6.805	6.805	6.770	6.763	6.616	6.597	6.270	5.733	5.041	4.592
305	-	7.998	7.392	6.969	6.886	6.886	6.850	6.843	6.691	6.671	6.336	5.851	5.130	4.656
310	-	8.146	7.487	7.052	6.967	6.967	6.930	6.922	6.765	6.745	6.402	5.969	5.218	4.720
315	-	8.295	7.581	7.136	7.048	7.048	7.010	7.002	6.840	6.819	6.468	6.070	5.307	4.784
320	-	8.444	7.676	7.219	7.129	7.129	7.090	7.082	6.914	6.893	6.534	6.132	5.396	4.847
325	-	-	7.771	7.303	7.210	7.210	7.169	7.161	6.989	6.966	6.600	6.193	5.485	4.911
330	-	-	7.866	7.386	7.291	7.291	7.249	7.241	7.064	7.040	6.666	6.255	5.574	4.975

Thickness is intumescent only.

Issued: 30 March 2023

This certificate is the property of Jensen Hughes Fire Testing Pty Ltd

Valid to: 30 March 2028

Page 28 of 54

Table 25 Circular Hollow Columns 75 minutes
 Required Thickness (mm) for a Design Temperature (°C)

Section Factor (m-1)	350	400	450	500	512	515	520	521	547	550	600	650	700	750
50	3.155	1.767	1.247	0.875	0.801	0.799	0.770	0.765	0.637	0.624	0.435	0.365	0.365	0.365
55	3.610	2.012	1.454	1.048	0.967	0.964	0.934	0.927	0.782	0.766	0.538	0.365	0.365	0.365
60	3.795	2.576	1.661	1.220	1.132	1.130	1.097	1.090	0.933	0.916	0.669	0.458	0.365	0.365
65	3.980	3.153	1.867	1.393	1.298	1.296	1.260	1.253	1.083	1.065	0.800	0.573	0.373	0.365
70	4.165	3.568	2.097	1.566	1.464	1.462	1.423	1.415	1.234	1.215	0.931	0.688	0.473	0.365
75	4.350	3.665	2.392	1.738	1.630	1.628	1.586	1.578	1.385	1.364	1.062	0.803	0.573	0.365
80	4.535	3.762	2.688	1.911	1.796	1.793	1.749	1.741	1.535	1.514	1.193	0.918	0.674	0.365
85	4.720	3.859	2.983	2.098	1.961	1.959	1.912	1.903	1.686	1.663	1.324	1.033	0.774	0.433
90	4.905	3.956	3.279	2.310	2.146	2.144	2.084	2.073	1.836	1.812	1.454	1.148	0.874	0.522
95	5.091	4.053	3.542	2.522	2.342	2.340	2.274	2.261	1.987	1.962	1.585	1.263	0.974	0.611
100	5.276	4.151	3.594	2.735	2.537	2.536	2.463	2.449	2.142	2.113	1.716	1.378	1.075	0.701
105	5.461	4.248	3.646	2.947	2.733	2.732	2.653	2.638	2.298	2.266	1.847	1.493	1.175	0.790
110	5.646	4.345	3.698	3.159	2.928	2.928	2.843	2.826	2.454	2.419	1.978	1.608	1.275	0.879
115	5.831	4.442	3.751	3.371	3.125	3.125	3.032	3.014	2.610	2.572	2.092	1.723	1.375	0.968
120	6.016	4.539	3.803	3.549	3.321	3.321	3.222	3.203	2.767	2.724	2.197	1.838	1.476	1.058
125	6.201	4.636	3.855	3.612	3.517	3.517	3.411	3.391	2.923	2.877	2.303	1.953	1.576	1.147
130	6.386	4.733	3.907	3.674	3.595	3.595	3.559	3.551	3.079	3.030	2.408	2.074	1.676	1.236
135	6.572	4.830	3.959	3.737	3.662	3.662	3.627	3.620	3.235	3.183	2.514	2.205	1.776	1.325
140	6.757	4.927	4.012	3.799	3.729	3.729	3.696	3.689	3.391	3.336	2.619	2.336	1.877	1.414
145	6.942	5.024	4.064	3.861	3.795	3.795	3.764	3.758	3.542	3.489	2.725	2.468	1.977	1.504
150	7.127	5.122	4.116	3.924	3.862	3.862	3.833	3.827	3.624	3.594	2.830	2.599	2.095	1.593
155	7.312	5.219	4.168	3.986	3.928	3.928	3.901	3.895	3.706	3.678	2.936	2.730	2.228	1.682
160	7.497	5.316	4.220	4.049	3.995	3.995	3.969	3.964	3.789	3.763	3.041	2.861	2.362	1.771
165	7.682	5.413	4.272	4.111	4.061	4.061	4.038	4.033	3.871	3.847	3.146	2.992	2.495	1.860
170	7.867	5.510	4.325	4.173	4.128	4.128	4.106	4.102	3.954	3.932	3.252	3.124	2.628	1.950
175	8.053	5.607	4.377	4.236	4.195	4.195	4.175	4.171	4.036	4.016	3.357	3.255	2.762	2.050
180	8.238	5.704	4.429	4.298	4.261	4.261	4.243	4.239	4.119	4.101	3.463	3.386	2.895	2.196
185	8.423	5.801	4.769	4.361	4.328	4.328	4.312	4.308	4.201	4.185	3.589	3.517	3.028	2.342
190	-	5.898	5.275	4.423	4.394	4.394	4.380	4.377	4.284	4.270	3.761	3.648	3.162	2.489
195	-	5.995	5.781	4.691	4.522	4.522	4.450	4.446	4.366	4.354	3.933	3.780	3.295	2.635
200	-	6.224	6.116	5.096	4.904	4.904	4.823	4.807	4.450	4.439	4.105	3.911	3.428	2.781
205	-	6.628	6.255	5.502	5.285	5.285	5.195	5.178	4.792	4.749	4.277	4.042	3.562	2.927
210	-	7.033	6.394	5.907	5.666	5.666	5.568	5.549	5.133	5.086	4.450	4.173	3.695	3.074
215	-	7.437	6.533	6.131	6.048	6.048	5.940	5.919	5.475	5.423	4.744	4.305	3.828	3.220
220	-	7.842	6.672	6.255	6.171	6.171	6.135	6.128	5.817	5.760	5.038	4.436	3.962	3.366
225	-	8.246	6.811	6.378	6.292	6.292	6.255	6.247	6.087	6.066	5.332	4.680	4.095	3.513
230	-	-	6.950	6.502	6.413	6.413	6.374	6.366	6.200	6.178	5.626	4.936	4.228	3.659
235	-	-	7.089	6.626	6.534	6.534	6.493	6.486	6.312	6.290	5.920	5.192	4.362	3.805
240	-	-	7.228	6.750	6.655	6.655	6.613	6.605	6.425	6.402	6.105	5.448	4.530	3.952
245	-	-	7.367	6.874	6.775	6.775	6.732	6.724	6.538	6.514	6.202	5.703	4.765	4.098
250	-	-	7.506	6.997	6.896	6.896	6.852	6.843	6.651	6.626	6.299	5.959	4.999	4.244
255	-	-	7.645	7.121	7.017	7.017	6.971	6.962	6.764	6.738	6.396	6.106	5.233	4.391
260	-	-	7.784	7.245	7.138	7.138	7.091	7.082	6.877	6.850	6.493	6.192	5.468	4.542
265	-	-	7.923	7.369	7.259	7.259	7.210	7.201	6.989	6.962	6.590	6.277	5.702	4.698
270	-	-	8.062	7.493	7.380	7.380	7.330	7.320	7.102	7.074	6.687	6.363	5.937	4.853
275	-	-	8.201	7.616	7.501	7.501	7.449	7.439	7.215	7.186	6.784	6.449	6.091	5.009
280	-	-	8.339	7.740	7.622	7.622	7.569	7.558	7.328	7.298	6.881	6.534	6.168	5.164
285	-	-	8.478	7.864	7.743	7.743	7.688	7.678	7.441	7.410	6.978	6.620	6.246	5.320
290	-	-	-	7.988	7.864	7.864	7.808	7.797	7.554	7.522	7.075	6.706	6.323	5.476
295	-	-	-	8.112	7.985	7.985	7.927	7.916	7.667	7.634	7.172	6.791	6.400	5.631
300	-	-	-	8.235	8.106	8.106	8.047	8.035	7.779	7.746	7.269	6.877	6.478	5.787
305	-	-	-	8.359	8.226	8.226	8.166	8.154	7.892	7.858	7.366	6.962	6.555	5.942
310	-	-	-	8.483	8.347	8.347	8.286	8.274	8.005	7.970	7.463	7.048	6.633	6.074
315	-	-	-	-	8.448	8.468	8.405	8.393	8.118	8.082	7.560	7.134	6.710	6.150
320	-	-	-	-	-	-	-	-	8.231	8.194	7.657	7.219	6.788	6.226
325	-	-	-	-	-	-	-	-	8.344	8.306	7.754	7.305	6.865	6.302
330	-	-	-	-	-	-	-	-	8.457	8.418	7.851	7.391	6.943	6.379

Thickness is intumescent only.

Table 26 Circular Hollow Columns 90 minutes
 Required Thickness (mm) for a Design Temperature (°C)

Section Factor (m-1)	350	400	450	500	512	515	520	521	547	550	600	650	700	750
50	-	3.212	1.792	1.340	1.251	1.248	1.214	1.208	1.049	1.032	0.786	0.587	0.411	0.365
55	-	3.662	2.091	1.563	1.465	1.463	1.426	1.418	1.244	1.226	0.958	0.725	0.513	0.365
60	-	3.870	2.609	1.786	1.680	1.677	1.637	1.629	1.440	1.420	1.130	0.879	0.651	0.365
65	-	4.079	3.127	2.009	1.894	1.892	1.848	1.839	1.636	1.615	1.302	1.033	0.788	0.471
70	-	4.287	3.575	2.384	2.166	2.162	2.083	2.068	1.832	1.809	1.474	1.187	0.925	0.595
75	-	4.495	3.763	2.768	2.522	2.520	2.430	2.412	2.030	2.004	1.646	1.341	1.063	0.720
80	-	4.704	3.951	3.152	2.879	2.877	2.776	2.757	2.321	2.280	1.818	1.495	1.200	0.845
85	-	4.912	4.139	3.535	3.235	3.234	3.122	3.101	2.611	2.564	1.990	1.649	1.338	0.969
90	-	5.121	4.327	3.663	3.555	3.555	3.469	3.445	2.901	2.849	2.190	1.803	1.475	1.094
95	-	5.329	4.515	3.790	3.684	3.684	3.640	3.631	3.192	3.134	2.397	1.956	1.613	1.218
100	-	5.537	4.703	3.918	3.813	3.813	3.769	3.761	3.482	3.418	2.604	2.108	1.750	1.343
105	-	5.746	4.891	4.045	3.942	3.942	3.899	3.890	3.645	3.614	2.811	2.259	1.887	1.467
110	-	5.954	5.080	4.173	4.071	4.071	4.028	4.020	3.779	3.749	3.018	2.410	2.024	1.592
115	-	6.162	5.268	4.300	4.200	4.200	4.158	4.150	3.913	3.884	3.224	2.560	2.132	1.717
120	-	6.371	5.456	4.427	4.329	4.329	4.288	4.279	4.047	4.018	3.431	2.711	2.239	1.841
125	-	6.579	5.644	4.555	4.458	4.458	4.417	4.409	4.181	4.153	3.569	2.862	2.347	1.966
130	-	6.788	5.832	4.682	4.587	4.587	4.547	4.538	4.315	4.287	3.637	3.012	2.455	2.086
135	-	6.996	6.020	4.810	4.716	4.716	4.676	4.668	4.449	4.422	3.704	3.163	2.562	2.202
140	-	7.204	6.208	4.937	4.845	4.845	4.806	4.798	4.584	4.557	3.772	3.313	2.670	2.319
145	-	7.413	6.396	5.065	4.974	4.974	4.935	4.927	4.718	4.691	3.840	3.464	2.777	2.435
150	-	7.621	6.584	5.192	5.103	5.103	5.065	5.057	4.852	4.826	3.908	3.581	2.885	2.551
155	-	7.830	6.772	5.319	5.232	5.232	5.194	5.187	4.986	4.960	3.976	3.667	2.993	2.668
160	-	8.038	6.960	5.447	5.361	5.361	5.324	5.316	5.120	5.095	4.043	3.754	3.100	2.784
165	-	8.246	7.148	5.574	5.490	5.490	5.453	5.446	5.254	5.230	4.111	3.841	3.208	2.901
170	-	8.455	7.336	5.702	5.619	5.619	5.583	5.576	5.388	5.364	4.179	3.927	3.315	3.017
175	-	-	7.524	5.829	5.748	5.748	5.713	5.705	5.523	5.499	4.247	4.014	3.423	3.133
180	-	-	7.712	5.957	5.877	5.877	5.842	5.835	5.657	5.633	4.315	4.100	3.531	3.250
185	-	-	7.901	6.123	6.006	6.006	5.972	5.965	5.791	5.768	4.382	4.187	3.660	3.366
190	-	-	8.089	6.402	6.212	6.212	6.142	6.129	5.925	5.903	4.463	4.273	3.790	3.482
195	-	-	8.277	6.681	6.460	6.460	6.377	6.361	6.062	6.037	4.905	4.360	3.920	3.599
200	-	-	8.465	6.960	6.709	6.709	6.612	6.594	6.249	6.214	5.347	4.446	4.050	3.715
205	-	-	-	7.239	6.957	6.957	6.848	6.827	6.436	6.396	5.789	4.817	4.180	3.832
210	-	-	-	7.518	7.205	7.205	7.083	7.060	6.623	6.577	6.108	5.192	4.310	3.948
215	-	-	-	7.797	7.453	7.453	7.318	7.292	6.810	6.759	6.248	5.568	4.440	4.064
220	-	-	-	8.076	7.701	7.701	7.553	7.525	6.997	6.940	6.388	5.943	4.792	4.181
225	-	-	-	8.355	7.950	7.950	7.788	7.758	7.184	7.122	6.528	6.141	5.156	4.297
230	-	-	-	-	8.198	8.198	8.023	7.990	7.371	7.304	6.668	6.268	5.521	4.414
235	-	-	-	-	8.386	8.446	8.258	8.223	7.558	7.485	6.808	6.394	5.886	4.704
240	-	-	-	-	-	-	8.456	7.745	7.667	6.949	6.520	6.114	5.069	
245	-	-	-	-	-	-	-	7.932	7.849	7.089	6.647	6.229	5.433	
250	-	-	-	-	-	-	-	8.119	8.030	7.229	6.773	6.343	5.797	
255	-	-	-	-	-	-	-	8.306	8.212	7.369	6.899	6.458	6.082	
260	-	-	-	-	-	-	-	-	8.393	7.509	7.026	6.573	6.186	
265	-	-	-	-	-	-	-	-	-	7.649	7.152	6.688	6.289	
270	-	-	-	-	-	-	-	-	-	7.789	7.279	6.803	6.392	
275	-	-	-	-	-	-	-	-	-	7.929	7.405	6.918	6.496	
280	-	-	-	-	-	-	-	-	-	8.069	7.531	7.032	6.599	
285	-	-	-	-	-	-	-	-	-	8.209	7.658	7.147	6.703	
290	-	-	-	-	-	-	-	-	-	8.349	7.784	7.262	6.806	
295	-	-	-	-	-	-	-	-	-	8.489	7.910	7.377	6.909	
300	-	-	-	-	-	-	-	-	-	-	8.037	7.492	7.013	
305	-	-	-	-	-	-	-	-	-	-	8.163	7.606	7.116	
310	-	-	-	-	-	-	-	-	-	-	8.290	7.721	7.220	
315	-	-	-	-	-	-	-	-	-	-	8.416	7.836	7.323	
320	-	-	-	-	-	-	-	-	-	-	-	7.951	7.426	
325	-	-	-	-	-	-	-	-	-	-	-	8.066	7.530	
330	-	-	-	-	-	-	-	-	-	-	-	8.180	7.633	

Thickness is intumescent only.

Table 27 Circular Hollow Columns 105 minutes
 Required Thickness (mm) for a Design Temperature (°C)

Section Factor (m-1)	350	400	450	500	512	515	520	521	547	550	600	650	700	750
50	-	-	2.923	1.818	1.712	1.710	1.670	1.662	1.476	1.456	1.173	0.931	0.716	0.453
55	-	-	3.569	2.178	1.977	1.974	1.930	1.922	1.718	1.697	1.387	1.124	0.885	0.572
60	-	-	3.819	2.787	2.492	2.488	2.380	2.359	1.960	1.937	1.601	1.318	1.059	0.732
65	-	-	4.069	3.396	3.059	3.056	2.932	2.908	2.369	2.318	1.815	1.511	1.233	0.892
70	-	-	4.319	3.709	3.571	3.570	3.484	3.457	2.836	2.776	2.034	1.704	1.407	1.053
75	-	-	4.569	3.935	3.791	3.791	3.733	3.722	3.302	3.234	2.375	1.897	1.582	1.213
80	-	-	4.819	4.161	4.012	4.012	3.952	3.940	3.639	3.606	2.717	2.113	1.756	1.373
85	-	-	5.069	4.386	4.233	4.233	4.170	4.158	3.848	3.813	3.059	2.373	1.930	1.533
90	-	-	5.319	4.612	4.454	4.454	4.389	4.376	4.056	4.020	3.401	2.633	2.114	1.693
95	-	-	5.569	4.837	4.675	4.675	4.607	4.594	4.265	4.227	3.617	2.892	2.310	1.853
100	-	-	5.820	5.063	4.896	4.896	4.826	4.812	4.473	4.434	3.752	3.152	2.506	2.013
105	-	-	6.070	5.289	5.117	5.117	5.044	5.030	4.682	4.641	3.887	3.412	2.703	2.155
110	-	-	6.320	5.514	5.338	5.338	5.263	5.248	4.890	4.848	4.022	3.567	2.899	2.295
115	-	-	6.570	5.740	5.559	5.559	5.481	5.466	5.099	5.055	4.157	3.627	3.095	2.436
120	-	-	6.820	5.966	5.780	5.780	5.700	5.684	5.307	5.262	4.292	3.687	3.291	2.577
125	-	-	7.070	6.191	6.001	6.001	5.919	5.902	5.516	5.469	4.427	3.747	3.487	2.717
130	-	-	7.320	6.417	6.222	6.222	6.137	6.120	5.724	5.675	4.562	3.808	3.584	2.858
135	-	-	7.570	6.642	6.443	6.443	6.356	6.338	5.933	5.882	4.697	3.868	3.649	2.999
140	-	-	7.820	6.868	6.664	6.664	6.574	6.556	6.141	6.089	4.832	3.928	3.714	3.139
145	-	-	8.070	7.094	6.885	6.885	6.793	6.774	6.350	6.296	4.967	3.988	3.779	3.280
150	-	-	8.320	7.319	7.106	7.106	7.011	6.992	6.558	6.503	5.102	4.049	3.845	3.421
155	-	-	-	7.545	7.327	7.327	7.230	7.211	6.767	6.710	5.237	4.109	3.910	3.550
160	-	-	-	7.770	7.548	7.548	7.448	7.429	6.975	6.917	5.372	4.169	3.975	3.631
165	-	-	-	7.996	7.769	7.769	7.667	7.647	7.183	7.124	5.507	4.229	4.040	3.712
170	-	-	-	8.222	7.990	7.990	7.885	7.865	7.392	7.331	5.642	4.289	4.105	3.792
175	-	-	-	8.447	8.211	8.211	8.104	8.083	7.600	7.538	5.777	4.350	4.170	3.873
180	-	-	-	-	8.403	8.432	8.322	8.301	7.809	7.745	5.912	4.410	4.235	3.954
185	-	-	-	-	-	-	-	-	8.017	7.952	6.047	4.652	4.300	4.035
190	-	-	-	-	-	-	-	-	8.226	8.159	6.392	5.207	4.365	4.115
195	-	-	-	-	-	-	-	-	8.434	8.366	6.741	5.761	4.430	4.196
200	-	-	-	-	-	-	-	-	-	-	7.091	6.157	4.822	4.277
205	-	-	-	-	-	-	-	-	-	-	7.441	6.377	5.338	4.358
210	-	-	-	-	-	-	-	-	-	-	7.790	6.598	5.853	4.438
215	-	-	-	-	-	-	-	-	-	-	8.140	6.819	6.153	4.921
220	-	-	-	-	-	-	-	-	-	-	8.490	7.040	6.320	5.458
225	-	-	-	-	-	-	-	-	-	-	-	7.260	6.486	5.995
230	-	-	-	-	-	-	-	-	-	-	-	7.481	6.653	6.188
235	-	-	-	-	-	-	-	-	-	-	-	7.702	6.819	6.342
240	-	-	-	-	-	-	-	-	-	-	-	7.923	6.986	6.495
245	-	-	-	-	-	-	-	-	-	-	-	8.144	7.152	6.648
250	-	-	-	-	-	-	-	-	-	-	-	8.364	7.319	6.802
255	-	-	-	-	-	-	-	-	-	-	-	-	7.485	6.955
260	-	-	-	-	-	-	-	-	-	-	-	-	7.652	7.109
265	-	-	-	-	-	-	-	-	-	-	-	-	7.818	7.262
270	-	-	-	-	-	-	-	-	-	-	-	-	7.985	7.415
275	-	-	-	-	-	-	-	-	-	-	-	-	8.151	7.569
280	-	-	-	-	-	-	-	-	-	-	-	-	8.318	7.722
285	-	-	-	-	-	-	-	-	-	-	-	-	8.484	7.876
290	-	-	-	-	-	-	-	-	-	-	-	-	-	8.029
295	-	-	-	-	-	-	-	-	-	-	-	-	-	8.182
300	-	-	-	-	-	-	-	-	-	-	-	-	-	8.336
305	-	-	-	-	-	-	-	-	-	-	-	-	-	8.489
310	-	-	-	-	-	-	-	-	-	-	-	-	-	-
315	-	-	-	-	-	-	-	-	-	-	-	-	-	-
320	-	-	-	-	-	-	-	-	-	-	-	-	-	-
325	-	-	-	-	-	-	-	-	-	-	-	-	-	-
330	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Thickness is intumescent only.

Table 28 Circular Hollow Columns 120 minutes
 Required Thickness (mm) for a Design Temperature (°C)

Section Factor (m-1)	350	400	450	500	512	515	520	521	547	550	600	650	700	750
50	-	-	-	2.878	2.528	2.521	2.385	2.358	1.914	1.892	1.569	1.299	1.054	0.748
55	-	-	-	3.166	3.301	3.297	3.151	3.123	2.451	2.390	1.826	1.532	1.265	0.935
60	-	-	-	-	-	-	3.673	3.662	3.137	3.064	2.144	1.765	1.477	1.131
65	-	-	-	-	-	-	3.949	3.938	3.646	3.614	2.655	1.998	1.688	1.327
70	-	-	-	-	-	-	4.225	4.213	3.910	3.876	3.166	2.380	1.899	1.523
75	-	-	-	-	-	-	4.501	4.489	4.174	4.138	3.601	2.780	2.153	1.718
80	-	-	-	-	-	-	4.777	4.764	4.438	4.401	3.837	3.179	2.465	1.914
85	-	-	-	-	-	-	5.053	5.040	4.702	4.663	4.073	3.558	2.778	2.128
90	-	-	-	-	-	-	5.329	5.315	4.966	4.925	4.309	3.772	3.090	2.363
95	-	-	-	-	-	-	5.605	5.591	5.231	5.188	4.545	3.987	3.403	2.597
100	-	-	-	-	-	-	5.882	5.866	5.495	5.450	4.781	4.201	3.612	2.832
105	-	-	-	-	-	-	6.158	6.142	5.759	5.712	5.018	4.415	3.745	3.067
110	-	-	-	-	-	-	6.434	6.417	6.023	5.975	5.254	4.629	3.878	3.302
115	-	-	-	-	-	-	6.710	6.693	6.287	6.237	5.490	4.843	4.012	3.536
120	-	-	-	-	-	-	6.986	6.968	6.551	6.500	5.726	5.057	4.145	3.594
125	-	-	-	-	-	-	7.262	7.244	6.815	6.762	5.962	5.271	4.278	3.652
130	-	-	-	-	-	-	7.538	7.519	7.080	7.024	6.198	5.485	4.412	3.711
135	-	-	-	-	-	-	7.814	7.795	7.344	7.287	6.435	5.699	4.545	3.769
140	-	-	-	-	-	-	8.090	8.070	7.608	7.549	6.671	5.913	4.678	3.827
145	-	-	-	-	-	-	8.366	8.346	7.872	7.811	6.907	6.128	4.812	3.886
150	-	-	-	-	-	-	-	-	8.136	8.074	7.143	6.342	4.945	3.944
155	-	-	-	-	-	-	-	-	8.400	8.336	7.379	6.556	5.078	4.002
160	-	-	-	-	-	-	-	-	-	-	7.615	6.770	5.212	4.061
165	-	-	-	-	-	-	-	-	-	-	7.852	6.984	5.345	4.119
170	-	-	-	-	-	-	-	-	-	-	8.088	7.198	5.478	4.178
175	-	-	-	-	-	-	-	-	-	-	8.324	7.412	5.612	4.236
180	-	-	-	-	-	-	-	-	-	-	7.626	5.745	4.294	
185	-	-	-	-	-	-	-	-	-	-	7.840	5.878	4.353	
190	-	-	-	-	-	-	-	-	-	-	8.055	6.012	4.411	
195	-	-	-	-	-	-	-	-	-	-	8.269	6.397	4.743	
200	-	-	-	-	-	-	-	-	-	-	8.483	6.888	5.548	
205	-	-	-	-	-	-	-	-	-	-	-	7.378	6.168	
210	-	-	-	-	-	-	-	-	-	-	-	7.869	6.478	
215	-	-	-	-	-	-	-	-	-	-	-	8.360	6.789	
220	-	-	-	-	-	-	-	-	-	-	-	-	7.099	
225	-	-	-	-	-	-	-	-	-	-	-	-	7.410	
230	-	-	-	-	-	-	-	-	-	-	-	-	7.720	
235	-	-	-	-	-	-	-	-	-	-	-	-	8.031	
240	-	-	-	-	-	-	-	-	-	-	-	-	8.341	
245	-	-	-	-	-	-	-	-	-	-	-	-	-	
250	-	-	-	-	-	-	-	-	-	-	-	-	-	
255	-	-	-	-	-	-	-	-	-	-	-	-	-	
260	-	-	-	-	-	-	-	-	-	-	-	-	-	
265	-	-	-	-	-	-	-	-	-	-	-	-	-	
270	-	-	-	-	-	-	-	-	-	-	-	-	-	
275	-	-	-	-	-	-	-	-	-	-	-	-	-	
280	-	-	-	-	-	-	-	-	-	-	-	-	-	
285	-	-	-	-	-	-	-	-	-	-	-	-	-	
290	-	-	-	-	-	-	-	-	-	-	-	-	-	
295	-	-	-	-	-	-	-	-	-	-	-	-	-	
300	-	-	-	-	-	-	-	-	-	-	-	-	-	
305	-	-	-	-	-	-	-	-	-	-	-	-	-	
310	-	-	-	-	-	-	-	-	-	-	-	-	-	
315	-	-	-	-	-	-	-	-	-	-	-	-	-	
320	-	-	-	-	-	-	-	-	-	-	-	-	-	
325	-	-	-	-	-	-	-	-	-	-	-	-	-	
330	-	-	-	-	-	-	-	-	-	-	-	-	-	

Thickness is intumescent only.

Table 29 Rectangular Hollow Columns (RHS / SHS) 15 minutes
 Required Thickness (mm) for a Design Temperature (°C)

Section Factor (m ⁻¹)	350	400	450	500	512	515	520	521	547	550	600	650	700	750
50	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
55	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
60	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
65	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
70	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
75	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
80	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
85	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
90	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
95	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
100	0.380	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
105	0.402	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
110	0.423	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
115	0.444	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
120	0.465	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
125	0.486	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
130	0.507	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
135	0.528	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
140	0.549	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
145	0.570	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
150	0.591	0.375	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
155	0.612	0.394	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
160	0.633	0.413	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
165	0.654	0.432	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
170	0.675	0.451	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
175	0.696	0.470	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
180	0.717	0.489	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
185	0.738	0.508	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
190	0.759	0.527	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
195	0.780	0.546	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
200	0.801	0.565	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
205	0.822	0.585	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
210	0.843	0.604	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
215	0.864	0.623	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
220	0.885	0.642	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
225	0.906	0.661	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
230	0.927	0.680	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
235	0.948	0.699	0.376	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
240	0.969	0.718	0.392	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
245	0.990	0.737	0.408	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
250	1.011	0.756	0.423	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
255	1.032	0.775	0.439	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
260	1.053	0.794	0.455	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
265	1.074	0.813	0.470	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
270	1.095	0.832	0.486	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
275	1.116	0.852	0.502	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
280	1.137	0.871	0.517	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
285	1.158	0.890	0.533	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
290	1.179	0.909	0.549	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
295	1.200	0.928	0.564	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
300	1.221	0.947	0.580	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
305	1.242	0.966	0.596	0.394	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
310	1.263	0.985	0.611	0.419	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
315	1.284	1.004	0.627	0.445	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
320	1.305	1.023	0.643	0.471	0.387	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
325	1.326	1.042	0.658	0.496	0.412	0.391	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
330	1.347	1.061	0.674	0.522	0.438	0.416	0.381	0.373	0.369	0.369	0.369	0.369	0.369	0.369
335	1.368	1.080	0.689	0.548	0.463	0.441	0.405	0.398	0.369	0.369	0.369	0.369	0.369	0.369
340	1.389	1.100	0.705	0.573	0.488	0.466	0.430	0.422	0.369	0.369	0.369	0.369	0.369	0.369
345	1.410	1.119	0.721	0.599	0.513	0.491	0.454	0.447	0.369	0.369	0.369	0.369	0.369	0.369
350	1.431	1.138	0.736	0.625	0.538	0.516	0.479	0.472	0.369	0.369	0.369	0.369	0.369	0.369
355	1.452	1.157	0.752	0.650	0.563	0.541	0.504	0.496	0.369	0.369	0.369	0.369	0.369	0.369

Thickness is intumescent only. Results also apply to rectangular hollow beams exposed on all four sides limited to a maximum protection thickness of 5.667 mm.

Table 30 Rectangular Hollow Columns (RHS / SHS) 20 minutes
 Required Thickness (mm) for a Design Temperature (°C)

Section Factor (m ⁻¹)	350	400	450	500	512	515	520	521	547	550	600	650	700	750
50	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
55	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
60	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
65	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
70	0.384	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
75	0.412	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
80	0.440	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
85	0.468	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
90	0.496	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
95	0.524	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
100	0.552	0.385	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
105	0.580	0.411	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
110	0.609	0.436	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
115	0.637	0.461	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
120	0.665	0.486	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
125	0.693	0.511	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
130	0.721	0.537	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
135	0.749	0.562	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
140	0.777	0.587	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
145	0.805	0.612	0.387	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
150	0.833	0.637	0.408	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
155	0.861	0.663	0.428	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
160	0.890	0.688	0.448	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
165	0.918	0.713	0.468	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
170	0.946	0.738	0.489	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
175	0.974	0.763	0.509	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
180	1.002	0.789	0.529	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
185	1.030	0.814	0.550	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
190	1.058	0.839	0.570	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
195	1.086	0.864	0.590	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
200	1.114	0.889	0.610	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
205	1.142	0.914	0.631	0.382	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
210	1.171	0.940	0.651	0.417	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
215	1.199	0.965	0.671	0.453	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
220	1.227	0.990	0.692	0.488	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
225	1.255	1.015	0.712	0.524	0.403	0.371	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
230	1.283	1.040	0.732	0.560	0.438	0.407	0.376	0.370	0.369	0.369	0.369	0.369	0.369	0.369
235	1.311	1.066	0.752	0.595	0.474	0.442	0.411	0.405	0.369	0.369	0.369	0.369	0.369	0.369
240	1.339	1.091	0.773	0.631	0.509	0.478	0.446	0.440	0.369	0.369	0.369	0.369	0.369	0.369
245	1.367	1.116	0.793	0.666	0.545	0.513	0.482	0.475	0.369	0.369	0.369	0.369	0.369	0.369
250	1.395	1.141	0.813	0.702	0.580	0.549	0.517	0.510	0.369	0.369	0.369	0.369	0.369	0.369
255	1.423	1.166	0.833	0.737	0.616	0.584	0.552	0.546	0.373	0.369	0.369	0.369	0.369	0.369
260	1.452	1.192	0.854	0.773	0.652	0.620	0.587	0.581	0.408	0.387	0.369	0.369	0.369	0.369
265	1.480	1.217	0.874	0.809	0.687	0.655	0.623	0.616	0.443	0.422	0.369	0.369	0.369	0.369
270	1.508	1.242	0.894	0.844	0.723	0.691	0.658	0.651	0.478	0.456	0.369	0.369	0.369	0.369
275	1.536	1.267	0.915	0.880	0.758	0.726	0.693	0.686	0.513	0.491	0.369	0.369	0.369	0.369
280	1.564	1.292	0.935	0.915	0.794	0.762	0.728	0.721	0.548	0.526	0.369	0.369	0.369	0.369
285	1.592	1.318	0.955	0.951	0.829	0.797	0.764	0.757	0.582	0.560	0.369	0.369	0.369	0.369
290	1.620	1.343	0.987	0.987	0.865	0.833	0.799	0.792	0.617	0.595	0.369	0.369	0.369	0.369
295	1.648	1.368	1.022	1.022	0.900	0.868	0.834	0.827	0.652	0.630	0.369	0.369	0.369	0.369
300	1.676	1.393	1.058	1.058	0.936	0.904	0.869	0.862	0.687	0.664	0.369	0.369	0.369	0.369
305	1.704	1.418	1.093	1.093	0.972	0.940	0.904	0.897	0.722	0.699	0.369	0.369	0.369	0.369
310	1.733	1.444	1.129	1.129	1.007	0.975	0.940	0.932	0.757	0.734	0.369	0.369	0.369	0.369
315	1.761	1.469	1.164	1.164	1.043	1.011	0.975	0.968	0.792	0.768	0.369	0.369	0.369	0.369
320	1.789	1.494	1.200	1.200	1.078	1.046	1.010	1.003	0.827	0.803	0.376	0.369	0.369	0.369
325	1.817	1.519	1.236	1.236	1.114	1.082	1.045	1.038	0.862	0.838	0.409	0.369	0.369	0.369
330	1.845	1.544	1.271	1.271	1.149	1.117	1.081	1.073	0.897	0.872	0.441	0.369	0.369	0.369
335	1.873	1.569	1.307	1.307	1.185	1.153	1.116	1.108	0.932	0.907	0.473	0.369	0.369	0.369
340	1.901	1.595	1.342	1.342	1.220	1.188	1.151	1.144	0.967	0.942	0.506	0.369	0.369	0.369
345	1.929	1.620	1.378	1.378	1.256	1.224	1.186	1.179	1.002	0.976	0.538	0.369	0.369	0.369
350	1.957	1.645	1.414	1.414	1.291	1.259	1.222	1.214	1.036	1.011	0.571	0.369	0.369	0.369
355	1.985	1.670	1.449	1.449	1.327	1.295	1.257	1.249	1.071	1.046	0.603	0.369	0.369	0.369

Thickness is intumescent only. Results also apply to rectangular hollow beams exposed on all four sides limited to a maximum protection thickness of 5.667 mm.

Table 31 Rectangular Hollow Columns (RHS / SHS) 30 minutes
 Required Thickness (mm) for a Design Temperature (°C)

Section Factor (m ⁻¹)	350	400	450	500	512	515	520	521	547	550	600	650	700	750
50	0.507	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
55	0.566	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
60	0.626	0.390	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
65	0.685	0.436	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
70	0.744	0.482	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
75	0.804	0.528	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
80	0.863	0.574	0.396	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
85	0.922	0.620	0.426	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
90	0.981	0.666	0.456	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
95	1.041	0.711	0.485	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
100	1.100	0.757	0.515	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
105	1.159	0.803	0.545	0.412	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
110	1.219	0.849	0.575	0.464	0.401	0.385	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
115	1.278	0.895	0.605	0.515	0.452	0.436	0.408	0.402	0.369	0.369	0.369	0.369	0.369	0.369
120	1.337	0.941	0.635	0.567	0.503	0.486	0.458	0.453	0.369	0.369	0.369	0.369	0.369	0.369
125	1.396	0.987	0.665	0.618	0.554	0.537	0.509	0.503	0.369	0.369	0.369	0.369	0.369	0.369
130	1.456	1.032	0.695	0.669	0.605	0.588	0.560	0.554	0.401	0.382	0.369	0.369	0.369	0.369
135	1.515	1.078	0.725	0.721	0.655	0.639	0.610	0.605	0.452	0.433	0.369	0.369	0.369	0.369
140	1.574	1.124	0.772	0.772	0.706	0.690	0.661	0.655	0.503	0.484	0.369	0.369	0.369	0.369
145	1.634	1.170	0.823	0.823	0.757	0.740	0.711	0.706	0.555	0.535	0.369	0.369	0.369	0.369
150	1.693	1.216	0.875	0.875	0.808	0.791	0.762	0.756	0.606	0.586	0.369	0.369	0.369	0.369
155	1.752	1.262	0.926	0.926	0.859	0.842	0.813	0.807	0.657	0.637	0.369	0.369	0.369	0.369
160	1.812	1.308	0.977	0.977	0.910	0.893	0.863	0.857	0.709	0.689	0.369	0.369	0.369	0.369
165	1.871	1.353	1.029	1.029	0.961	0.944	0.914	0.908	0.760	0.740	0.369	0.369	0.369	0.369
170	1.930	1.399	1.080	1.080	1.012	0.994	0.964	0.958	0.812	0.791	0.406	0.369	0.369	0.369
175	1.989	1.445	1.131	1.131	1.063	1.045	1.015	1.009	0.863	0.842	0.457	0.369	0.369	0.369
180	2.049	1.491	1.183	1.183	1.114	1.096	1.066	1.060	0.914	0.893	0.509	0.369	0.369	0.369
185	2.106	1.537	1.234	1.234	1.165	1.147	1.116	1.110	0.966	0.945	0.561	0.369	0.369	0.369
190	2.164	1.583	1.286	1.286	1.216	1.198	1.167	1.161	1.017	0.996	0.612	0.369	0.369	0.369
195	2.221	1.628	1.337	1.337	1.267	1.248	1.218	1.211	1.068	1.047	0.664	0.369	0.369	0.369
200	2.279	1.674	1.388	1.388	1.317	1.299	1.268	1.262	1.120	1.098	0.715	0.369	0.369	0.369
205	2.336	1.720	1.440	1.440	1.368	1.350	1.319	1.312	1.171	1.149	0.767	0.369	0.369	0.369
210	2.394	1.766	1.491	1.491	1.419	1.401	1.369	1.363	1.222	1.200	0.819	0.369	0.369	0.369
215	2.451	1.812	1.542	1.542	1.470	1.452	1.420	1.413	1.274	1.252	0.870	0.369	0.369	0.369
220	2.509	1.858	1.594	1.594	1.521	1.502	1.471	1.464	1.325	1.303	0.922	0.369	0.369	0.369
225	2.566	1.904	1.645	1.645	1.572	1.553	1.521	1.515	1.376	1.354	0.973	0.407	0.369	0.369
230	2.624	1.949	1.696	1.696	1.623	1.604	1.572	1.565	1.428	1.405	1.025	0.446	0.369	0.369
235	2.681	1.995	1.748	1.748	1.674	1.655	1.622	1.616	1.479	1.456	1.077	0.485	0.369	0.369
240	2.739	2.041	1.799	1.799	1.725	1.706	1.673	1.666	1.530	1.508	1.128	0.525	0.369	0.369
245	2.796	2.099	1.851	1.851	1.776	1.756	1.724	1.717	1.582	1.559	1.180	0.564	0.369	0.369
250	2.854	2.156	1.902	1.902	1.827	1.807	1.774	1.767	1.633	1.610	1.231	0.603	0.369	0.369
255	2.911	2.214	1.953	1.953	1.878	1.858	1.825	1.818	1.684	1.661	1.283	0.642	0.369	0.369
260	2.969	2.272	2.005	2.005	1.929	1.909	1.875	1.868	1.736	1.712	1.335	0.681	0.369	0.369
265	3.026	2.330	2.056	2.056	1.979	1.960	1.926	1.919	1.787	1.763	1.386	0.720	0.369	0.369
270	3.084	2.387	2.107	2.107	2.030	2.010	1.977	1.970	1.839	1.815	1.438	0.759	0.369	0.369
275	3.141	2.445	2.159	2.159	2.081	2.061	2.027	2.020	1.890	1.866	1.489	0.798	0.369	0.369
280	3.199	2.503	2.210	2.210	2.132	2.112	2.078	2.071	1.941	1.917	1.541	0.837	0.397	0.369
285	3.257	2.560	2.261	2.261	2.183	2.163	2.128	2.121	1.993	1.968	1.593	0.876	0.432	0.369
290	3.314	2.618	2.313	2.313	2.234	2.214	2.179	2.172	2.044	2.019	1.644	0.916	0.466	0.369
295	3.372	2.676	2.364	2.364	2.285	2.265	2.230	2.222	2.095	2.071	1.696	0.955	0.500	0.369
300	3.429	2.734	2.415	2.415	2.336	2.315	2.280	2.273	2.147	2.122	1.747	0.994	0.534	0.369
305	3.482	2.791	2.467	2.467	2.387	2.366	2.331	2.323	2.198	2.173	1.799	1.033	0.568	0.369
310	3.519	2.849	2.518	2.518	2.438	2.417	2.381	2.374	2.249	2.224	1.851	1.072	0.602	0.369
315	3.556	2.907	2.570	2.570	2.489	2.468	2.432	2.425	2.301	2.275	1.902	1.111	0.636	0.369
320	3.593	2.964	2.621	2.621	2.540	2.519	2.483	2.475	2.352	2.326	1.954	1.150	0.671	0.369
325	3.630	3.022	2.672	2.672	2.591	2.569	2.533	2.526	2.403	2.378	2.005	1.189	0.705	0.369
330	3.667	3.080	2.724	2.724	2.641	2.620	2.584	2.576	2.455	2.429	2.057	1.228	0.739	0.369
335	3.704	3.138	2.775	2.775	2.692	2.671	2.634	2.627	2.506	2.480	2.109	1.267	0.773	0.369
340	3.741	3.195	2.826	2.826	2.743	2.722	2.685	2.677	2.557	2.531	2.160	1.306	0.807	0.369
345	3.778	3.253	2.878	2.878	2.794	2.773	2.736	2.728	2.609	2.582	2.212	1.346	0.841	0.369
350	3.815	3.311	2.929	2.929	2.845	2.823	2.786	2.778	2.660	2.634	2.263	1.385	0.875	0.369
355	3.852	3.369	2.980	2.980	2.896	2.874	2.837	2.829	2.711	2.685	2.315	1.424	0.909	0.369

Thickness is intumescent only. Results also apply to rectangular hollow beams exposed on all four sides limited to a maximum protection thickness of 5.667 mm.

Table 32 Rectangular Hollow Columns (RHS / SHS) 45 minutes
 Required Thickness (mm) for a Design Temperature (°C)

Section Factor (m ⁻¹)	350	400	450	500	512	515	520	521	547	550	600	650	700	750
50	1.030	0.710	0.457	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
55	1.141	0.802	0.523	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
60	1.253	0.895	0.590	0.408	0.378	0.371	0.369	0.369	0.369	0.369	0.369	0.369	0.369	0.369
65	1.364	0.988	0.656	0.461	0.428	0.420	0.407	0.405	0.369	0.369	0.369	0.369	0.369	0.369
70	1.476	1.081	0.723	0.514	0.478	0.470	0.455	0.453	0.376	0.369	0.369	0.369	0.369	0.369
75	1.588	1.173	0.789	0.568	0.528	0.519	0.504	0.501	0.459	0.445	0.369	0.369	0.369	0.369
80	1.699	1.266	0.856	0.621	0.578	0.568	0.552	0.548	0.543	0.528	0.369	0.369	0.369	0.369
85	1.811	1.359	0.922	0.674	0.629	0.626	0.626	0.626	0.611	0.369	0.369	0.369	0.369	0.369
90	1.922	1.452	0.989	0.727	0.709	0.709	0.709	0.709	0.694	0.441	0.369	0.369	0.369	0.369
95	2.034	1.544	1.055	0.792	0.792	0.792	0.792	0.792	0.776	0.521	0.369	0.369	0.369	0.369
100	2.156	1.637	1.122	0.875	0.875	0.875	0.875	0.875	0.859	0.602	0.369	0.369	0.369	0.369
105	2.279	1.730	1.188	0.959	0.959	0.959	0.959	0.959	0.942	0.682	0.387	0.369	0.369	0.369
110	2.403	1.823	1.255	1.042	1.042	1.042	1.042	1.042	1.025	0.762	0.446	0.369	0.369	0.369
115	2.526	1.915	1.321	1.125	1.125	1.125	1.125	1.125	1.107	0.842	0.505	0.369	0.369	0.369
120	2.649	2.008	1.387	1.208	1.208	1.208	1.208	1.208	1.190	0.922	0.565	0.369	0.369	0.369
125	2.772	2.105	1.454	1.292	1.292	1.292	1.292	1.292	1.273	1.002	0.624	0.369	0.369	0.369
130	2.896	2.204	1.520	1.375	1.375	1.375	1.375	1.375	1.355	1.083	0.683	0.388	0.369	0.369
135	3.019	2.303	1.587	1.458	1.458	1.458	1.458	1.458	1.438	1.163	0.743	0.444	0.369	0.369
140	3.142	2.402	1.653	1.541	1.541	1.541	1.541	1.541	1.521	1.243	0.802	0.501	0.369	0.369
145	3.265	2.501	1.720	1.624	1.624	1.624	1.624	1.624	1.604	1.323	0.861	0.558	0.369	0.369
150	3.389	2.600	1.786	1.708	1.708	1.708	1.708	1.708	1.686	1.403	0.920	0.614	0.369	0.369
155	3.487	2.699	1.853	1.791	1.791	1.791	1.791	1.791	1.769	1.483	0.980	0.671	0.369	0.369
160	3.530	2.798	1.919	1.874	1.874	1.874	1.874	1.874	1.852	1.564	1.039	0.727	0.369	0.369
165	3.573	2.898	1.986	1.957	1.957	1.957	1.957	1.957	1.935	1.644	1.098	0.784	0.369	0.369
170	3.616	2.997	2.065	2.041	2.041	2.041	2.041	2.041	2.017	1.724	1.158	0.840	0.369	0.369
175	3.659	3.096	2.217	2.124	2.124	2.124	2.124	2.124	2.100	1.804	1.217	0.897	0.369	0.369
180	3.702	3.195	2.369	2.207	2.207	2.207	2.207	2.207	2.183	1.884	1.276	0.953	0.417	0.417
185	3.745	3.294	2.521	2.290	2.290	2.290	2.290	2.290	2.266	1.964	1.336	1.010	0.472	0.472
190	3.788	3.393	2.673	2.373	2.373	2.373	2.373	2.373	2.348	2.045	1.395	1.066	0.526	0.526
195	3.831	3.480	2.825	2.457	2.457	2.457	2.457	2.457	2.431	2.125	1.454	1.123	0.581	0.581
200	3.874	3.513	2.976	2.540	2.540	2.540	2.540	2.540	2.514	2.205	1.514	1.180	0.636	0.636
205	3.917	3.547	3.128	2.623	2.623	2.623	2.623	2.623	2.597	2.285	1.573	1.236	0.691	0.691
210	3.960	3.580	3.280	2.706	2.706	2.706	2.706	2.706	2.679	2.365	1.632	1.293	0.746	0.746
215	4.003	3.613	3.432	2.790	2.790	2.790	2.790	2.790	2.762	2.445	1.691	1.349	0.801	0.801
220	4.046	3.647	3.496	2.873	2.873	2.873	2.873	2.873	2.845	2.526	1.751	1.406	0.855	0.855
225	4.090	3.680	3.526	2.956	2.956	2.956	2.956	2.956	2.928	2.606	1.810	1.462	0.910	0.910
230	4.133	3.713	3.556	3.075	3.039	3.039	3.039	3.039	3.039	3.010	2.686	1.869	1.519	0.965
235	4.176	3.747	3.586	3.386	3.122	3.122	3.122	3.122	3.093	2.766	1.929	1.575	1.020	1.020
240	4.219	3.780	3.616	3.493	3.213	3.206	3.206	3.206	3.176	2.846	1.988	1.632	1.075	1.075
245	4.262	3.813	3.645	3.520	3.484	3.475	3.289	3.289	3.259	2.927	2.047	1.689	1.130	1.130
250	4.305	3.847	3.675	3.547	3.510	3.501	3.486	3.483	3.372	3.341	3.007	2.107	1.745	1.184
255	4.348	3.880	3.705	3.574	3.536	3.527	3.512	3.509	3.455	3.424	3.087	2.166	1.802	1.239
260	4.391	3.913	3.735	3.600	3.563	3.554	3.538	3.535	3.493	3.483	3.167	2.225	1.858	1.294
265	4.434	3.947	3.765	3.627	3.589	3.580	3.564	3.561	3.517	3.507	3.247	2.285	1.915	1.349
270	4.477	3.980	3.795	3.654	3.615	3.606	3.590	3.586	3.541	3.531	3.327	2.344	1.971	1.404
275	4.520	4.013	3.825	3.681	3.642	3.632	3.616	3.612	3.565	3.555	3.408	2.403	2.028	1.459
280	4.635	4.047	3.855	3.708	3.668	3.658	3.642	3.638	3.589	3.579	3.478	2.462	2.084	1.513
285	4.770	4.080	3.885	3.735	3.694	3.684	3.668	3.664	3.613	3.603	3.498	2.522	2.141	1.568
290	4.906	4.114	3.915	3.761	3.721	3.711	3.694	3.690	3.636	3.627	3.519	2.581	2.197	1.623
295	5.041	4.147	3.945	3.788	3.747	3.737	3.720	3.716	3.660	3.651	3.540	2.640	2.254	1.678
300	5.176	4.180	3.975	3.815	3.773	3.763	3.746	3.742	3.684	3.674	3.561	2.700	2.311	1.733
305	5.312	4.214	4.005	3.842	3.800	3.789	3.772	3.768	3.708	3.698	3.582	2.759	2.367	1.788
310	5.447	4.247	4.035	3.869	3.826	3.815	3.798	3.794	3.732	3.722	3.603	2.818	2.424	1.842
315	5.582	4.280	4.065	3.895	3.852	3.842	3.824	3.820	3.756	3.746	3.623	2.878	2.480	1.897
320	5.717	4.314	4.095	3.922	3.879	3.868	3.850	3.846	3.780	3.770	3.644	2.937	2.537	1.952
325	5.853	4.347	4.125	3.949	3.905	3.894	3.876	3.872	3.804	3.794	3.665	2.996	2.593	2.007
330	5.988	4.380	4.155	3.976	3.931	3.920	3.902	3.898	3.828	3.818	3.686	3.056	2.650	2.062
335	6.098	4.414	4.185	4.003	3.958	3.946	3.928	3.924	3.852	3.841	3.707	3.115	2.706	2.117
340	6.150	4.447	4.215	4.029	3.984	3.973	3.954	3.950	3.876	3.865	3.728	3.174	2.763	2.171
345	6.203	4.480	4.245	4.056	4.010	3.999	3.980	3.976	3.900	3.889	3.748	3.233	2.820	2.226
350	6.256	4.514	4.274	4.083	4.037	4.025	4.006	4.002	3.924	3.913	3.769	3.293	2.876	2.281
355	6.309	4.715	4.304	4.110	4.063	4.051	4.032	4.028	3.948	3.937	3.790	3.352	2.933	2.336

Thickness is intumescent only. Results also apply to rectangular hollow beams exposed on all four sides limited to a maximum protection thickness of 5.667 mm.

Table 33 Rectangular Hollow Columns (RHS / SHS) 60 minutes
 Required Thickness (mm) for a Design Temperature (°C)

Section Factor (m ⁻¹)	350	400	450	500	512	515	520	521	547	550	600	650	700	750
50	1.552	1.166	0.843	0.616	0.567	0.555	0.535	0.531	0.438	0.428	0.369	0.369	0.369	0.369
55	1.716	1.305	0.948	0.705	0.653	0.640	0.619	0.615	0.511	0.500	0.369	0.369	0.369	0.369
60	1.880	1.443	1.053	0.794	0.739	0.725	0.703	0.698	0.588	0.576	0.415	0.369	0.369	0.369
65	2.044	1.582	1.158	0.883	0.824	0.810	0.786	0.782	0.665	0.652	0.480	0.369	0.369	0.369
70	2.234	1.720	1.263	0.972	0.910	0.895	0.870	0.865	0.742	0.728	0.546	0.406	0.369	0.369
75	2.424	1.859	1.368	1.061	0.996	0.980	0.953	0.948	0.818	0.804	0.612	0.461	0.369	0.369
80	2.614	1.997	1.473	1.151	1.082	1.065	1.037	1.032	0.895	0.880	0.677	0.515	0.369	0.369
85	2.804	2.148	1.578	1.240	1.168	1.150	1.121	1.115	0.972	0.956	0.743	0.570	0.444	0.369
90	2.994	2.305	1.684	1.329	1.253	1.235	1.204	1.198	1.049	1.032	0.809	0.625	0.528	0.369
95	3.184	2.461	1.789	1.418	1.339	1.320	1.288	1.282	1.125	1.108	0.874	0.680	0.613	0.369
100	3.373	2.618	1.894	1.507	1.425	1.405	1.372	1.365	1.202	1.184	0.940	0.735	0.697	0.369
105	3.531	2.775	1.999	1.596	1.511	1.490	1.455	1.448	1.279	1.260	1.005	0.790	0.782	0.444
110	3.652	2.932	2.156	1.686	1.596	1.575	1.539	1.532	1.355	1.336	1.071	0.866	0.866	0.524
115	3.774	3.088	2.349	1.775	1.682	1.660	1.622	1.615	1.432	1.412	1.137	0.951	0.951	0.604
120	3.895	3.245	2.542	1.864	1.768	1.745	1.706	1.698	1.509	1.488	1.202	1.035	1.035	0.684
125	4.016	3.402	2.735	1.953	1.854	1.830	1.790	1.782	1.586	1.564	1.268	1.120	1.120	0.764
130	4.138	3.518	2.928	2.043	1.939	1.914	1.873	1.865	1.662	1.640	1.334	1.204	1.204	0.844
135	4.259	3.598	3.121	2.286	2.025	1.999	1.957	1.949	1.739	1.716	1.399	1.289	1.289	0.924
140	4.380	3.679	3.314	2.529	2.248	2.172	2.041	2.032	1.816	1.792	1.465	1.374	1.374	1.004
145	4.502	3.759	3.482	2.772	2.505	2.433	2.305	2.278	1.893	1.868	1.531	1.458	1.458	1.084
150	4.651	3.840	3.527	3.015	2.761	2.693	2.572	2.547	1.969	1.944	1.596	1.543	1.543	1.164
155	4.808	3.920	3.572	3.258	3.017	2.954	2.840	2.816	2.063	2.020	1.662	1.627	1.627	1.244
160	4.965	4.001	3.617	3.478	3.274	3.215	3.107	3.085	2.447	2.323	1.728	1.712	1.712	1.324
165	5.122	4.082	3.662	3.511	3.481	3.474	3.375	3.354	2.832	2.720	1.796	1.796	1.796	1.404
170	5.279	4.162	3.707	3.544	3.514	3.506	3.494	3.492	3.216	3.117	1.881	1.881	1.881	1.484
175	5.436	4.243	3.752	3.577	3.546	3.539	3.526	3.524	3.484	3.477	1.965	1.965	1.965	1.564
180	5.594	4.323	3.797	3.610	3.578	3.571	3.558	3.556	3.514	3.507	2.050	2.050	2.050	1.644
185	5.751	4.404	3.842	3.643	3.611	3.603	3.590	3.588	3.544	3.537	2.366	2.134	2.134	1.724
190	5.908	4.484	3.887	3.676	3.643	3.636	3.623	3.620	3.574	3.567	3.481	2.219	2.219	1.804
195	6.065	4.581	3.932	3.709	3.676	3.668	3.655	3.652	3.604	3.597	3.508	2.303	2.303	1.884
200	6.125	4.696	3.977	3.742	3.708	3.700	3.687	3.684	3.635	3.627	3.535	2.388	2.388	1.964
205	6.174	4.811	4.022	3.775	3.741	3.733	3.719	3.716	3.665	3.657	3.562	2.473	2.473	2.044
210	6.224	4.926	4.067	3.808	3.773	3.765	3.751	3.748	3.695	3.687	3.589	2.557	2.557	2.124
215	6.273	5.042	4.112	3.841	3.806	3.797	3.783	3.780	3.725	3.717	3.616	2.642	2.642	2.203
220	6.322	5.157	4.157	3.874	3.838	3.830	3.815	3.812	3.755	3.747	3.643	2.726	2.726	2.283
225	6.371	5.272	4.202	3.907	3.871	3.862	3.847	3.844	3.785	3.777	3.670	2.811	2.811	2.363
230	6.420	5.388	4.247	3.940	3.903	3.894	3.879	3.876	3.815	3.807	3.696	2.895	2.895	2.443
235	6.469	5.503	4.292	3.973	3.936	3.927	3.911	3.908	3.846	3.837	3.723	3.225	2.980	2.523
240	6.519	5.618	4.337	4.006	3.968	3.959	3.943	3.940	3.876	3.867	3.750	3.488	3.064	2.603
245	6.568	5.734	4.382	4.039	4.001	3.991	3.975	3.972	3.906	3.897	3.777	3.531	3.149	2.683
250	6.617	5.849	4.427	4.072	4.033	4.024	4.008	4.004	3.936	3.927	3.804	3.573	3.233	2.763
255	6.666	5.964	4.472	4.105	4.065	4.056	4.040	4.036	3.966	3.957	3.831	3.616	3.318	2.843
260	6.715	6.080	4.517	4.138	4.098	4.088	4.072	4.068	3.996	3.987	3.858	3.659	3.402	2.923
265	6.765	6.136	4.652	4.171	4.130	4.120	4.104	4.101	4.026	4.017	3.885	3.702	3.480	3.003
270	6.814	6.192	4.821	4.204	4.163	4.153	4.136	4.133	4.057	4.047	3.912	3.744	3.517	3.083
275	6.863	6.248	4.990	4.237	4.195	4.185	4.168	4.165	4.087	4.077	3.938	3.787	3.555	3.163
280	6.912	6.305	5.159	4.270	4.228	4.217	4.200	4.197	4.117	4.107	3.965	3.830	3.593	3.243
285	6.961	6.361	5.328	4.303	4.260	4.250	4.232	4.229	4.147	4.137	3.992	3.873	3.631	3.323
290	7.010	6.417	5.497	4.336	4.293	4.282	4.264	4.261	4.177	4.167	4.019	3.915	3.668	3.403
295	7.060	6.473	5.666	4.369	4.325	4.314	4.296	4.293	4.207	4.197	4.046	3.958	3.706	3.478
300	7.109	6.529	5.835	4.402	4.358	4.347	4.328	4.325	4.237	4.227	4.073	4.001	3.744	3.510
305	7.158	6.585	6.004	4.435	4.390	4.379	4.361	4.357	4.268	4.257	4.100	4.044	3.781	3.543
310	7.207	6.641	6.121	4.468	4.423	4.411	4.393	4.389	4.298	4.287	4.127	4.086	3.819	3.575
315	7.256	6.697	6.194	4.501	4.455	4.444	4.425	4.421	4.328	4.317	4.153	4.129	3.857	3.608
320	7.306	6.753	6.267	4.621	4.488	4.476	4.457	4.453	4.358	4.347	4.180	4.172	3.894	3.640
325	7.355	6.809	6.340	5.245	4.520	4.508	4.489	4.485	4.388	4.377	4.215	4.215	3.932	3.673
330	7.404	6.865	6.413	5.869	4.962	4.741	4.521	4.517	4.418	4.407	4.257	4.257	3.970	3.706
335	7.453	6.921	6.486	6.135	5.559	5.335	5.076	4.986	4.448	4.437	4.300	4.300	4.007	3.738
340	7.502	6.977	6.560	6.217	6.092	5.929	5.806	5.715	4.479	4.467	4.343	4.343	4.045	3.771
345	7.551	7.033	6.633	6.299	6.176	6.143	6.132	6.121	4.509	4.497	4.386	4.386	4.083	3.803
350	7.601	7.089	6.706	6.381	6.259	6.227	6.213	6.203	4.838	4.527	4.428	4.428	4.120	3.836
355	7.650	7.146	6.779	6.463	6.343	6.311	6.294	6.284	5.787	5.416	4.471	4.471	4.158	3.869

Thickness is intumescent only. Results also apply to rectangular hollow beams exposed on all four sides limited to a maximum protection thickness of 5.667 mm.

Table 34 Rectangular Hollow Columns (RHS / SHS) 75 minutes
 Required Thickness (mm) for a Design Temperature (°C)

Section Factor (m ⁻¹)	350	400	450	500	512	515	520	521	547	550	600	650	700	750
50	2.089	1.623	1.229	0.964	0.909	0.895	0.873	0.868	0.759	0.747	0.567	0.398	0.369	0.369
55	2.345	1.807	1.373	1.088	1.029	1.014	0.990	0.985	0.868	0.855	0.661	0.472	0.369	0.369
60	2.600	1.991	1.516	1.212	1.148	1.133	1.107	1.102	0.977	0.964	0.760	0.562	0.399	0.369
65	2.855	2.198	1.660	1.336	1.268	1.252	1.225	1.219	1.087	1.072	0.858	0.653	0.479	0.369
70	3.111	2.413	1.804	1.460	1.388	1.371	1.342	1.336	1.196	1.180	0.957	0.744	0.559	0.378
75	3.366	2.627	1.947	1.584	1.508	1.490	1.459	1.453	1.305	1.289	1.055	0.835	0.639	0.447
80	3.611	2.842	2.124	1.708	1.628	1.609	1.577	1.570	1.414	1.397	1.154	0.926	0.719	0.517
85	3.848	3.057	2.364	1.832	1.748	1.728	1.694	1.687	1.523	1.505	1.252	1.016	0.799	0.587
90	4.085	3.272	2.605	1.956	1.868	1.847	1.811	1.804	1.633	1.614	1.351	1.107	0.879	0.656
95	4.322	3.489	2.845	2.125	1.988	1.965	1.929	1.921	1.742	1.722	1.449	1.198	0.959	0.726
100	4.571	3.741	3.086	2.391	2.191	2.139	2.051	2.038	1.851	1.830	1.548	1.289	1.039	0.796
105	4.895	3.992	3.326	2.658	2.463	2.413	2.327	2.310	1.960	1.939	1.646	1.380	1.119	0.865
110	5.219	4.244	3.526	2.925	2.734	2.686	2.603	2.586	2.123	2.057	1.744	1.470	1.199	0.935
115	5.544	4.496	3.660	3.192	3.006	2.960	2.879	2.863	2.444	2.381	1.843	1.561	1.279	1.004
120	5.868	4.709	3.794	3.458	3.277	3.233	3.155	3.139	2.766	2.706	1.941	1.652	1.359	1.074
125	6.101	4.917	3.928	3.552	3.495	3.483	3.431	3.416	3.087	3.030	2.040	1.743	1.439	1.144
130	6.159	5.125	4.062	3.635	3.570	3.556	3.533	3.529	3.409	3.355	2.446	1.834	1.519	1.213
135	6.217	5.333	4.196	3.718	3.645	3.630	3.604	3.599	3.518	3.508	2.859	1.925	1.599	1.283
140	6.274	5.541	4.331	3.802	3.721	3.703	3.675	3.669	3.573	3.562	3.272	2.015	1.679	1.353
145	6.332	5.748	4.465	3.885	3.796	3.777	3.745	3.739	3.629	3.616	3.492	2.206	1.759	1.422
150	6.390	5.956	4.628	3.968	3.871	3.850	3.816	3.809	3.684	3.670	3.527	2.439	1.839	1.492
155	6.448	6.100	4.817	4.051	3.947	3.924	3.886	3.879	3.740	3.724	3.562	2.672	1.919	1.562
160	6.506	6.149	5.006	4.134	4.022	3.997	3.957	3.949	3.795	3.779	3.597	2.905	1.999	1.631
165	6.563	6.198	5.196	4.217	4.097	4.071	4.027	4.019	3.850	3.833	3.632	3.138	2.171	1.701
170	6.621	6.247	5.385	4.300	4.173	4.144	4.098	4.089	3.906	3.887	3.668	3.371	2.450	1.770
175	6.679	6.296	5.574	4.383	4.248	4.218	4.169	4.159	3.961	3.941	3.703	3.513	2.730	1.840
180	6.737	6.344	5.763	4.467	4.323	4.291	4.239	4.229	4.016	3.995	3.738	3.583	3.010	1.910
185	6.795	6.393	5.953	4.575	4.399	4.365	4.310	4.299	4.072	4.049	3.773	3.653	3.289	1.979
190	6.853	6.442	6.100	4.763	4.474	4.438	4.380	4.369	4.127	4.103	3.808	3.723	3.489	2.096
195	6.910	6.491	6.157	4.950	4.576	4.512	4.451	4.439	4.182	4.157	3.843	3.793	3.533	2.643
200	6.968	6.540	6.215	5.137	4.753	4.662	4.521	4.509	4.238	4.211	3.878	3.863	3.577	3.189
205	7.026	6.588	6.272	5.324	4.929	4.835	4.696	4.663	4.293	4.265	3.933	3.933	3.620	3.492
210	7.084	6.637	6.330	5.511	5.105	5.009	4.883	4.849	4.349	4.319	4.003	4.003	3.664	3.531
215	7.142	6.686	6.388	5.698	5.281	5.182	5.070	5.035	4.404	4.373	4.073	4.073	3.708	3.569
220	7.200	6.735	6.445	5.885	5.457	5.355	5.257	5.221	4.459	4.427	4.143	4.143	3.752	3.608
225	7.257	6.783	6.503	6.072	5.634	5.529	5.444	5.407	4.515	4.481	4.213	4.213	3.796	3.646
230	7.315	6.832	6.560	6.149	5.810	5.702	5.631	5.593	4.667	4.551	4.283	4.283	3.840	3.684
235	7.373	6.881	6.618	6.220	5.986	5.876	5.818	5.779	4.854	4.735	4.353	4.353	3.883	3.723
240	7.431	6.930	6.676	6.291	6.116	6.049	6.005	5.965	5.040	4.919	4.423	4.423	3.927	3.761
245	7.489	6.979	6.733	6.363	6.193	6.145	6.126	6.110	5.227	5.103	4.494	4.494	3.971	3.800
250	7.546	7.027	6.791	6.434	6.270	6.223	6.203	6.187	5.413	5.287	4.574	4.574	4.015	3.838
255	7.604	7.076	6.849	6.505	6.347	6.301	6.280	6.265	5.600	5.472	4.665	4.665	4.059	3.876
260	7.662	7.125	6.906	6.576	6.424	6.378	6.357	6.342	5.786	5.656	4.756	4.756	4.103	3.915
265	7.720	7.174	6.964	6.648	6.500	6.456	6.434	6.419	5.973	5.840	4.846	4.846	4.146	3.953
270	7.778	7.223	7.021	6.719	6.577	6.534	6.511	6.496	6.117	6.024	4.937	4.937	4.190	3.992
275	7.836	7.271	7.079	6.790	6.654	6.612	6.587	6.573	6.204	6.142	5.028	5.028	4.234	4.030
280	7.893	7.320	7.137	6.862	6.731	6.690	6.664	6.651	6.291	6.231	5.119	5.119	4.278	4.069
285	7.951	7.369	7.194	6.933	6.808	6.768	6.741	6.728	6.378	6.319	5.210	5.210	4.322	4.107
290	8.009	7.418	7.252	7.004	6.884	6.846	6.818	6.805	6.465	6.408	5.301	5.301	4.366	4.145
295	8.067	7.466	7.309	7.076	6.961	6.924	6.895	6.882	6.551	6.496	5.391	5.391	4.409	4.184
300	8.125	7.515	7.367	7.147	7.038	7.002	6.971	6.959	6.638	6.585	5.482	5.482	4.453	4.222
305	-	7.564	7.425	7.218	7.115	7.080	7.048	7.036	6.725	6.673	6.084	5.573	4.497	4.261
310	-	7.613	7.482	7.289	7.192	7.158	7.125	7.114	6.812	6.762	6.176	5.664	4.565	4.299
315	-	7.662	7.540	7.361	7.268	7.236	7.202	7.191	6.899	6.850	6.268	5.755	4.696	4.337
320	-	7.710	7.597	7.432	7.345	7.313	7.279	7.268	6.985	6.939	6.360	5.846	4.828	4.376
325	-	7.759	7.655	7.503	7.422	7.391	7.356	7.345	7.072	7.027	6.452	5.936	4.959	4.414
330	-	7.808	7.713	7.575	7.499	7.469	7.432	7.422	7.159	7.116	6.544	6.027	5.091	4.453
335	-	7.857	7.770	7.646	7.575	7.547	7.509	7.499	7.246	7.205	6.636	6.135	5.223	4.491
340	-	7.906	7.828	7.717	7.652	7.625	7.586	7.577	7.333	7.293	6.728	6.268	5.354	4.530
345	-	7.954	7.886	7.788	7.729	7.703	7.663	7.654	7.419	7.382	6.820	6.401	5.486	4.641
350	-	8.003	7.943	7.860	7.806	7.781	7.740	7.731	7.506	7.470	6.912	6.533	5.617	4.751
355	-	8.052	8.001	7.931	7.883	7.859	7.817	7.808	7.593	7.559	7.004	6.666	5.749	4.861

Thickness is intumescent only. Results also apply to rectangular hollow beams exposed on all four sides limited to a maximum protection thickness of 5.667 mm.

Table 35 Rectangular Hollow Columns (RHS / SHS) 90 minutes
 Required Thickness (mm) for a Design Temperature (°C)

Section Factor (m ⁻¹)	350	400	450	500	512	515	520	521	547	550	600	650	700	750
50	2.728	2.095	1.615	1.313	1.250	1.235	1.210	1.205	1.084	1.070	0.878	0.707	0.534	0.369
55	3.045	2.366	1.797	1.472	1.404	1.388	1.361	1.356	1.225	1.211	1.008	0.825	0.631	0.397
60	3.363	2.638	1.980	1.630	1.558	1.541	1.512	1.506	1.367	1.351	1.138	0.948	0.747	0.510
65	3.727	2.909	2.232	1.789	1.712	1.694	1.663	1.657	1.509	1.492	1.268	1.071	0.864	0.622
70	4.118	3.181	2.522	1.948	1.866	1.847	1.814	1.808	1.650	1.633	1.398	1.194	0.980	0.735
75	4.508	3.452	2.811	2.166	2.020	1.999	1.965	1.958	1.792	1.773	1.528	1.317	1.097	0.848
80	5.027	4.148	3.101	2.469	2.304	2.262	2.192	2.178	1.933	1.914	1.658	1.440	1.213	0.960
85	5.553	4.673	3.390	2.772	2.608	2.568	2.498	2.485	2.120	2.072	1.787	1.563	1.330	1.073
90	6.079	4.974	3.706	3.075	2.912	2.873	2.804	2.791	2.453	2.407	1.917	1.685	1.447	1.185
95	6.194	5.275	4.032	3.379	3.216	3.178	3.110	3.097	2.787	2.742	2.057	1.808	1.563	1.298
100	6.307	5.576	4.358	3.605	3.500	3.479	3.416	3.404	3.120	3.077	2.422	1.931	1.680	1.410
105	6.421	5.877	4.668	3.796	3.673	3.648	3.606	3.598	3.454	3.412	2.786	2.066	1.796	1.523
110	6.534	6.107	4.961	3.987	3.846	3.817	3.768	3.759	3.593	3.575	3.151	2.302	1.913	1.635
115	6.648	6.186	5.253	4.178	4.019	3.986	3.930	3.920	3.721	3.700	3.484	2.538	2.029	1.748
120	6.761	6.266	5.545	4.370	4.192	4.155	4.092	4.081	3.848	3.824	3.567	2.774	2.250	1.860
125	6.875	6.345	5.837	4.578	4.365	4.323	4.254	4.242	3.975	3.948	3.651	3.011	2.483	1.973
130	6.988	6.425	6.094	4.876	4.544	4.492	4.417	4.403	4.102	4.073	3.735	3.247	2.716	2.146
135	7.101	6.504	6.175	5.173	4.831	4.751	4.621	4.593	4.229	4.197	3.818	3.481	2.949	2.418
140	7.215	6.584	6.256	5.471	5.117	5.034	4.920	4.891	4.356	4.322	3.902	3.647	3.182	2.690
145	7.328	6.663	6.337	5.769	5.404	5.318	5.219	5.190	4.484	4.446	3.986	3.813	3.415	2.961
150	7.442	6.743	6.417	6.066	5.691	5.601	5.519	5.488	4.720	4.627	4.070	3.979	3.558	3.233
155	7.555	6.822	6.498	6.160	5.977	5.884	5.818	5.786	5.018	4.922	4.153	4.145	3.672	3.482
160	7.669	6.902	6.579	6.243	6.133	6.106	6.090	6.082	5.315	5.216	4.311	4.311	3.785	3.556
165	7.782	6.981	6.660	6.326	6.216	6.187	6.168	6.159	5.613	5.511	4.477	4.477	3.898	3.629
170	7.895	7.061	6.741	6.409	6.298	6.268	6.246	6.237	5.910	5.805	4.596	4.596	4.011	3.703
175	8.009	7.140	6.821	6.492	6.380	6.349	6.324	6.314	6.110	6.085	4.693	4.693	4.124	3.776
180	8.122	7.220	6.902	6.575	6.462	6.430	6.402	6.391	6.180	6.153	4.789	4.789	4.238	3.850
185	8.236	7.299	6.983	6.658	6.545	6.511	6.479	6.469	6.249	6.221	4.967	4.886	4.351	3.924
190	-	7.379	7.064	6.741	6.627	6.592	6.557	6.546	6.318	6.289	5.256	4.983	4.464	3.997
195	-	7.458	7.144	6.824	6.709	6.673	6.635	6.624	6.387	6.357	5.546	5.080	4.561	4.071
200	-	7.538	7.225	6.908	6.791	6.754	6.713	6.701	6.456	6.425	5.835	5.177	4.635	4.144
205	-	7.617	7.306	6.991	6.873	6.835	6.790	6.778	6.525	6.493	6.091	5.274	4.709	4.218
210	-	7.697	7.387	7.074	6.956	6.916	6.868	6.856	6.594	6.561	6.161	5.370	4.784	4.291
215	-	7.776	7.468	7.157	7.038	6.998	6.946	6.933	6.663	6.629	6.231	5.467	4.858	4.365
220	-	7.856	7.548	7.240	7.120	7.079	7.024	7.011	6.732	6.697	6.301	5.564	4.932	4.439
225	-	7.935	7.629	7.323	7.202	7.160	7.102	7.088	6.801	6.765	6.371	5.661	5.006	4.512
230	-	8.015	7.710	7.406	7.284	7.241	7.179	7.165	6.870	6.833	6.441	5.758	5.081	4.588
235	-	8.094	7.791	7.489	7.367	7.322	7.257	7.243	6.939	6.901	6.510	5.855	5.155	4.665
240	-	8.174	7.871	7.572	7.449	7.403	7.335	7.320	7.008	6.969	6.580	5.951	5.229	4.742
245	-	-	7.952	7.655	7.531	7.484	7.413	7.398	7.077	7.037	6.650	6.048	5.304	4.819
250	-	-	8.033	7.738	7.613	7.565	7.491	7.475	7.146	7.104	6.720	6.156	5.378	4.896
255	-	-	8.114	7.821	7.696	7.646	7.568	7.552	7.215	7.172	6.790	6.269	5.452	4.973
260	-	-	8.195	7.904	7.778	7.727	7.646	7.630	7.284	7.240	6.859	6.382	5.526	5.050
265	-	-	-	7.987	7.860	7.808	7.724	7.707	7.353	7.308	6.929	6.495	5.601	5.127
270	-	-	-	8.071	7.942	7.889	7.802	7.785	7.422	7.376	6.999	6.608	5.675	5.204
275	-	-	-	8.154	8.024	7.970	7.880	7.862	7.491	7.444	7.069	6.721	5.749	5.281
280	-	-	-	8.237	8.107	8.051	7.957	7.939	7.560	7.512	7.139	6.834	5.824	5.358
285	-	-	-	-	8.189	8.132	8.035	8.017	7.629	7.580	7.208	6.947	5.898	5.435
290	-	-	-	-	8.271	8.214	8.113	8.094	7.698	7.648	7.278	7.060	5.972	5.512
295	-	-	-	-	-	8.191	8.171	7.767	7.716	7.348	7.173	6.046	5.589	
300	-	-	-	-	-	-	8.249	7.837	7.784	7.418	7.286	6.151	5.666	
305	-	-	-	-	-	-	-	7.906	7.852	7.488	7.399	6.283	5.743	
310	-	-	-	-	-	-	-	-	7.975	7.920	7.558	7.512	6.414	5.820
315	-	-	-	-	-	-	-	-	8.044	7.988	7.627	7.625	6.546	5.897
320	-	-	-	-	-	-	-	-	8.113	8.056	7.738	7.738	6.677	5.974
325	-	-	-	-	-	-	-	-	8.182	8.124	7.851	7.851	6.809	6.051
330	-	-	-	-	-	-	-	-	8.251	8.192	7.964	7.964	6.940	6.147
335	-	-	-	-	-	-	-	-	-	8.260	8.077	8.077	7.072	6.256
340	-	-	-	-	-	-	-	-	-	-	8.190	8.190	7.203	6.365
345	-	-	-	-	-	-	-	-	-	-	8.303	8.303	7.335	6.474
350	-	-	-	-	-	-	-	-	-	-	8.416	8.416	7.466	6.583
355	-	-	-	-	-	-	-	-	-	-	-	-	7.598	6.691

Thickness is intumescent only. Results also apply to rectangular hollow beams exposed on all four sides limited to a maximum protection thickness of 5.667 mm.

Section Factor (m ⁻¹)	Table 36 Rectangular Hollow Columns (RHS / SHS) 105 minutes Required Thickness (mm) for a Design Temperature (°C)													
	350	400	450	500	512	515	520	521	547	550	600	650	700	750
50	3.350	2.651	1.988	1.661	1.592	1.575	1.547	1.542	1.408	1.393	1.193	1.023	0.859	0.664
55	3.907	2.977	2.314	1.855	1.780	1.762	1.732	1.726	1.582	1.566	1.354	1.178	1.002	0.786
60	4.464	3.302	2.654	2.054	1.968	1.948	1.917	1.910	1.756	1.739	1.516	1.333	1.153	0.937
65	5.194	4.589	2.995	2.397	2.250	2.213	2.152	2.140	1.930	1.912	1.677	1.488	1.303	1.087
70	5.946	4.983	3.336	2.741	2.592	2.556	2.495	2.483	2.172	2.132	1.839	1.644	1.453	1.238
75	6.227	5.378	3.944	3.084	2.934	2.899	2.837	2.825	2.533	2.494	2.000	1.799	1.604	1.388
80	6.405	5.772	4.632	3.428	3.277	3.242	3.180	3.168	2.894	2.856	2.316	1.954	1.754	1.539
85	6.582	6.110	5.028	3.823	3.626	3.587	3.521	3.510	3.256	3.218	2.687	2.152	1.904	1.689
90	6.760	6.245	5.424	4.226	3.986	3.938	3.857	3.843	3.575	3.547	3.057	2.409	2.062	1.840
95	6.938	6.379	5.821	4.630	4.346	4.288	4.192	4.175	3.831	3.798	3.428	2.666	2.301	1.990
100	7.116	6.514	6.128	5.040	4.725	4.653	4.528	4.508	4.088	4.048	3.620	2.922	2.539	2.209
105	7.294	6.648	6.265	5.449	5.124	5.048	4.940	4.915	4.344	4.299	3.786	3.179	2.778	2.464
110	7.471	6.783	6.401	5.858	5.523	5.444	5.353	5.326	4.642	4.562	3.952	3.436	3.017	2.720
115	7.649	6.917	6.538	6.145	5.922	5.839	5.765	5.738	5.051	4.967	4.119	3.710	3.255	2.975
120	7.827	7.052	6.675	6.285	6.164	6.134	6.112	6.103	5.460	5.372	4.285	3.987	3.491	3.230
125	8.005	7.186	6.811	6.425	6.303	6.272	6.245	6.235	5.868	5.777	4.452	4.264	3.692	3.481
130	8.182	7.321	6.948	6.564	6.442	6.409	6.378	6.367	6.139	6.111	4.741	4.538	3.892	3.633
135	-	7.455	7.085	6.704	6.581	6.547	6.511	6.500	6.260	6.230	5.137	4.728	4.093	3.784
140	-	7.590	7.222	6.844	6.720	6.684	6.643	6.632	6.381	6.350	5.532	4.919	4.294	3.936
145	-	7.724	7.358	6.984	6.859	6.822	6.776	6.764	6.502	6.470	5.928	5.109	4.494	4.088
150	-	7.859	7.495	7.124	6.998	6.959	6.909	6.896	6.623	6.589	6.139	5.300	4.643	4.240
155	-	7.993	7.632	7.264	7.137	7.096	7.042	7.029	6.744	6.709	6.235	5.490	4.781	4.391
160	-	8.128	7.769	7.404	7.276	7.234	7.174	7.161	6.866	6.829	6.330	5.681	4.919	4.537
165	-	8.263	7.905	7.543	7.414	7.371	7.307	7.293	6.987	6.948	6.425	5.871	5.057	4.628
170	-	-	8.042	7.683	7.553	7.509	7.440	7.425	7.108	7.068	6.520	6.062	5.195	4.718
175	-	-	8.179	7.823	7.692	7.646	7.573	7.558	7.229	7.188	6.615	6.162	5.333	4.808
180	-	-	8.315	7.963	7.831	7.784	7.706	7.690	7.350	7.307	6.711	6.253	5.471	4.898
185	-	-	-	8.103	7.970	7.921	7.838	7.822	7.471	7.427	6.806	6.343	5.609	4.988
190	-	-	-	8.243	8.109	8.059	7.971	7.954	7.592	7.547	6.901	6.434	5.747	5.078
195	-	-	-	-	8.248	8.196	8.104	8.087	7.713	7.666	6.996	6.524	5.885	5.168
200	-	-	-	-	-	8.334	8.237	8.219	7.834	7.786	7.091	6.615	6.023	5.258
205	-	-	-	-	-	-	-	-	7.955	7.906	7.187	6.705	6.132	5.348
210	-	-	-	-	-	-	-	-	8.076	8.025	7.282	6.796	6.219	5.438
215	-	-	-	-	-	-	-	-	8.197	8.145	7.377	6.886	6.306	5.528
220	-	-	-	-	-	-	-	-	8.318	8.265	7.472	6.977	6.393	5.619
225	-	-	-	-	-	-	-	-	-	8.384	7.567	7.067	6.481	5.709
230	-	-	-	-	-	-	-	-	-	-	7.663	7.158	6.568	5.799
235	-	-	-	-	-	-	-	-	-	-	7.758	7.248	6.655	5.889
240	-	-	-	-	-	-	-	-	-	-	7.853	7.338	6.742	5.979
245	-	-	-	-	-	-	-	-	-	-	7.948	7.429	6.829	6.069
250	-	-	-	-	-	-	-	-	-	-	8.043	7.519	6.917	6.164
255	-	-	-	-	-	-	-	-	-	-	8.138	7.610	7.004	6.260
260	-	-	-	-	-	-	-	-	-	-	8.234	7.700	7.091	6.356
265	-	-	-	-	-	-	-	-	-	-	-	7.791	7.178	6.452
270	-	-	-	-	-	-	-	-	-	-	-	7.881	7.265	6.548
275	-	-	-	-	-	-	-	-	-	-	-	7.972	7.353	6.644
280	-	-	-	-	-	-	-	-	-	-	-	8.062	7.440	6.740
285	-	-	-	-	-	-	-	-	-	-	-	8.153	7.527	6.836
290	-	-	-	-	-	-	-	-	-	-	-	8.243	7.614	6.931
295	-	-	-	-	-	-	-	-	-	-	-	8.334	7.701	7.027
300	-	-	-	-	-	-	-	-	-	-	-	8.424	7.789	7.123
305	-	-	-	-	-	-	-	-	-	-	-	-	7.876	7.219
310	-	-	-	-	-	-	-	-	-	-	-	-	7.963	7.315
315	-	-	-	-	-	-	-	-	-	-	-	-	8.050	7.411
320	-	-	-	-	-	-	-	-	-	-	-	-	8.137	7.507
325	-	-	-	-	-	-	-	-	-	-	-	-	8.225	7.603
330	-	-	-	-	-	-	-	-	-	-	-	-	8.312	7.699
335	-	-	-	-	-	-	-	-	-	-	-	-	8.399	7.795
340	-	-	-	-	-	-	-	-	-	-	-	-	-	7.890
345	-	-	-	-	-	-	-	-	-	-	-	-	-	7.986
350	-	-	-	-	-	-	-	-	-	-	-	-	-	8.082
355	-	-	-	-	-	-	-	-	-	-	-	-	-	8.178

Thickness is intumescent only. Results also apply to rectangular hollow beams exposed on all four sides limited to a maximum protection thickness of 5.667 mm.

Section Factor (m ⁻¹)	Table 37 Rectangular Hollow Columns (RHS / SHS) 120 minutes Required Thickness (mm) for a Design Temperature (°C)													
	350	400	450	500	512	515	520	521	547	550	600	650	700	750
50	4.429	4.279	2.545	2.020	1.901	1.884	1.884	1.878	1.733	1.717	1.508	1.345	1.190	1.018
55	5.404	4.767	2.941	2.363	2.233	2.201	2.148	2.137	1.939	1.922	1.701	1.532	1.374	1.191
60	6.157	5.255	3.337	2.753	2.617	2.585	2.530	2.519	2.240	2.206	1.894	1.719	1.558	1.379
65	6.405	5.744	4.646	3.142	3.001	2.969	2.912	2.901	2.635	2.601	2.132	1.906	1.742	1.566
70	6.653	6.142	5.147	3.602	3.385	3.352	3.294	3.283	3.030	2.996	2.524	2.119	1.926	1.753
75	6.901	6.338	5.648	4.473	4.054	3.973	3.840	3.817	3.425	3.391	2.916	2.402	2.137	1.941
80	7.150	6.535	6.108	5.017	4.719	4.651	4.532	4.503	3.911	3.858	3.308	2.684	2.393	2.164
85	7.398	6.731	6.307	5.539	5.231	5.159	5.058	5.034	4.409	4.344	3.651	2.967	2.649	2.429
90	7.646	6.928	6.507	6.061	5.743	5.667	5.585	5.559	4.924	4.848	3.958	3.250	2.905	2.695
95	7.894	7.124	6.706	6.276	6.149	6.118	6.092	6.082	5.444	5.364	4.265	3.562	3.161	2.960
100	8.142	7.320	6.905	6.479	6.351	6.318	6.286	6.275	5.964	5.880	4.600	3.990	3.416	3.226
105	-	7.517	7.104	6.681	6.552	6.517	6.480	6.469	6.220	6.189	5.103	4.418	3.717	3.490
110	-	7.713	7.304	6.884	6.754	6.717	6.673	6.662	6.399	6.367	5.606	4.769	4.031	3.733
115	-	7.910	7.503	7.087	6.955	6.917	6.867	6.855	6.578	6.544	6.089	5.092	4.344	3.976
120	-	8.106	7.702	7.289	7.157	7.117	7.061	7.048	6.758	6.722	6.236	5.416	4.630	4.218
125	-	8.303	7.901	7.492	7.358	7.317	7.255	7.241	6.937	6.899	6.383	5.739	4.876	4.461
130	-	-	8.101	7.695	7.559	7.516	7.448	7.434	7.116	7.077	6.530	6.063	5.123	4.648
135	-	-	8.300	7.897	7.761	7.716	7.642	7.627	7.295	7.255	6.677	6.168	5.369	4.814
140	-	-	-	8.100	7.962	7.916	7.836	7.820	7.475	7.432	6.824	6.260	5.615	4.980
145	-	-	-	8.303	8.164	8.116	8.030	8.013	7.654	7.610	6.971	6.352	5.861	5.145
150	-	-	-	-	8.365	8.316	8.224	8.207	7.833	7.787	7.118	6.444	6.090	5.311
155	-	-	-	-	-	-	-	-	8.012	7.965	7.265	6.536	6.176	5.477
160	-	-	-	-	-	-	-	-	8.192	8.142	7.412	6.628	6.261	5.642
165	-	-	-	-	-	-	-	-	8.371	8.320	7.560	6.720	6.347	5.808
170	-	-	-	-	-	-	-	-	-	-	7.707	6.812	6.432	5.973
175	-	-	-	-	-	-	-	-	-	-	7.854	6.903	6.517	6.109
180	-	-	-	-	-	-	-	-	-	-	8.001	6.995	6.603	6.189
185	-	-	-	-	-	-	-	-	-	-	8.148	7.087	6.688	6.269
190	-	-	-	-	-	-	-	-	-	-	8.295	7.179	6.774	6.348
195	-	-	-	-	-	-	-	-	-	-	-	7.271	6.859	6.428
200	-	-	-	-	-	-	-	-	-	-	-	7.363	6.945	6.508
205	-	-	-	-	-	-	-	-	-	-	-	7.455	7.030	6.588
210	-	-	-	-	-	-	-	-	-	-	-	7.547	7.115	6.667
215	-	-	-	-	-	-	-	-	-	-	-	7.639	7.201	6.747
220	-	-	-	-	-	-	-	-	-	-	-	7.731	7.286	6.827
225	-	-	-	-	-	-	-	-	-	-	-	7.823	7.372	6.907
230	-	-	-	-	-	-	-	-	-	-	-	7.915	7.457	6.987
235	-	-	-	-	-	-	-	-	-	-	-	8.007	7.543	7.066
240	-	-	-	-	-	-	-	-	-	-	-	8.099	7.628	7.146
245	-	-	-	-	-	-	-	-	-	-	-	8.191	7.713	7.226
250	-	-	-	-	-	-	-	-	-	-	-	8.283	7.799	7.306
255	-	-	-	-	-	-	-	-	-	-	-	8.375	7.884	7.385
260	-	-	-	-	-	-	-	-	-	-	-	-	7.970	7.465
265	-	-	-	-	-	-	-	-	-	-	-	-	8.055	7.545
270	-	-	-	-	-	-	-	-	-	-	-	-	8.141	7.625
275	-	-	-	-	-	-	-	-	-	-	-	-	8.226	7.705
280	-	-	-	-	-	-	-	-	-	-	-	-	8.312	7.784
285	-	-	-	-	-	-	-	-	-	-	-	-	8.397	7.864
290	-	-	-	-	-	-	-	-	-	-	-	-	-	7.944
295	-	-	-	-	-	-	-	-	-	-	-	-	-	8.024
300	-	-	-	-	-	-	-	-	-	-	-	-	-	8.103
305	-	-	-	-	-	-	-	-	-	-	-	-	-	8.183
310	-	-	-	-	-	-	-	-	-	-	-	-	-	8.263
315	-	-	-	-	-	-	-	-	-	-	-	-	-	8.343
320	-	-	-	-	-	-	-	-	-	-	-	-	-	8.423
325	-	-	-	-	-	-	-	-	-	-	-	-	-	-
330	-	-	-	-	-	-	-	-	-	-	-	-	-	-
335	-	-	-	-	-	-	-	-	-	-	-	-	-	-
340	-	-	-	-	-	-	-	-	-	-	-	-	-	-
345	-	-	-	-	-	-	-	-	-	-	-	-	-	-
350	-	-	-	-	-	-	-	-	-	-	-	-	-	-
355	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Thickness is intumescent only. Results also apply to rectangular hollow beams exposed on all four sides limited to a maximum protection thickness of 5.667 mm.

Table 38 Rectangular Hollow Beams 15 minutes

Thickness is intumescent only. Results apply to beams with concrete slabs with 3-sided fire exposure.

Table 39 Rectangular Hollow Beams 20 minutes

Thickness is intumescent only. Results apply to beams with concrete slabs with 3-sided fire exposure.

Table 40 Rectangular Hollow Beams 30 minutes

Thickness is intumescent only. Results apply to beams with concrete slabs with 3-sided fire exposure.

Section Factor (m ⁻¹)	Table 41 Rectangular Hollow Beams 45 minutes Required Thickness (mm) for a Design Temperature (°C)																
	350	400	450	500	544	550	553	575	576	580	580	600	603	610	620	650	700
40	0.997	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
45	1.055	0.445	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
50	1.113	0.499	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
55	1.171	0.552	0.447	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
60	1.229	0.605	0.527	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
65	1.287	0.658	0.607	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
70	1.345	0.711	0.687	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
75	1.403	0.767	0.767	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
80	1.461	0.847	0.847	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
85	1.519	0.927	0.927	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
90	1.577	1.007	1.007	0.403	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
95	1.635	1.087	1.087	0.494	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
100	1.693	1.157	1.157	0.586	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
105	1.751	1.248	1.248	0.677	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
110	1.809	1.328	1.328	0.769	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
115	1.867	1.408	1.408	0.861	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
120	1.925	1.488	1.488	0.952	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
125	1.983	1.568	1.568	1.044	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
130	2.068	1.648	1.648	1.135	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
135	2.160	1.728	1.728	1.227	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
140	2.251	1.808	1.808	1.319	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
145	2.343	1.888	1.888	1.410	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
150	2.434	1.968	1.968	1.502	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
155	2.526	2.048	2.048	1.594	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
160	2.617	2.129	2.129	1.685	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
165	2.709	2.209	2.209	1.777	0.488	0.488	0.488	0.488	0.488	0.488	0.488	0.488	0.488	0.488	0.488	0.488	0.488
170	2.800	2.289	2.289	1.868	0.616	0.616	0.616	0.616	0.616	0.616	0.616	0.616	0.616	0.616	0.616	0.616	0.616
175	2.892	2.369	2.369	1.960	0.744	0.744	0.744	0.744	0.744	0.744	0.744	0.744	0.744	0.744	0.744	0.744	0.744
180	2.983	2.449	2.449	2.052	0.872	0.872	0.872	0.872	0.872	0.872	0.872	0.872	0.872	0.872	0.872	0.872	0.872
185	3.057	2.529	2.529	2.143	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000
190	3.123	2.609	2.609	2.235	1.128	1.128	1.128	1.128	1.128	1.128	1.128	1.128	1.128	1.128	1.128	1.128	1.128
195	3.190	2.689	2.689	2.326	1.256	1.256	1.256	1.256	1.256	1.256	1.256	1.256	1.256	1.256	1.256	1.256	1.256
200	3.256	2.769	2.769	2.418	1.384	1.384	1.384	1.384	1.384	1.384	1.384	1.384	1.384	1.384	1.384	1.384	1.384
205	3.323	2.849	2.849	2.510	1.512	1.512	1.512	1.512	1.512	1.512	1.512	1.512	1.512	1.512	1.512	1.512	1.512
210	3.389	2.930	2.930	2.601	1.640	1.640	1.640	1.640	1.640	1.640	1.640	1.640	1.640	1.640	1.640	1.640	1.640
215	3.456	3.010	3.010	2.693	1.768	1.768	1.768	1.768	1.768	1.768	1.768	1.768	1.768	1.768	1.768	1.768	1.768
220	3.522	3.090	3.090	2.784	1.896	1.896	1.896	1.896	1.896	1.896	1.896	1.896	1.896	1.896	1.896	1.896	1.896
225	3.589	3.170	3.170	2.876	2.024	2.024	2.024	2.024	2.024	2.024	2.024	2.024	2.024	2.024	2.024	2.024	2.024
230	3.656	3.250	3.250	2.968	2.153	2.153	2.153	2.153	2.153	2.153	2.153	2.153	2.153	2.153	2.153	2.153	2.153
235	3.722	3.330	3.330	3.059	2.281	2.281	2.281	2.281	2.281	2.281	2.281	2.281	2.281	2.281	2.281	2.281	2.281
240	3.789	3.410	3.410	3.151	2.409	2.409	2.409	2.409	2.409	2.409	2.409	2.409	2.409	2.409	2.409	2.409	2.409
245	3.855	3.490	3.490	3.243	2.537	2.537	2.537	2.537	2.537	2.537	2.537	2.537	2.537	2.537	2.537	2.537	2.537
250	3.922	3.570	3.570	3.334	2.665	2.665	2.665	2.665	2.665	2.665	2.665	2.665	2.665	2.665	2.665	2.665	2.665
255	3.988	3.650	3.650	3.426	2.793	2.793	2.793	2.793	2.793	2.793	2.793	2.793	2.793	2.793	2.793	2.793	2.793
260	4.055	3.745	3.730	3.517	2.921	2.921	2.921	2.921	2.921	2.921	2.921	2.921	2.921	2.921	2.921	2.921	2.921
265	4.121	3.872	3.811	3.609	3.049	3.049	3.049	3.049	3.049	3.049	3.049	3.049	3.049	3.049	3.049	3.049	3.049
270	4.188	3.999	3.891	3.701	3.177	3.177	3.177	3.177	3.177	3.177	3.177	3.177	3.177	3.177	3.177	3.177	3.177
275	4.254	4.125	3.971	3.792	3.305	3.305	3.305	3.305	3.305	3.305	3.305	3.305	3.305	3.305	3.305	3.305	3.305
280	4.321	4.252	4.051	3.884	3.433	3.433	3.433	3.433	3.433	3.433	3.433	3.433	3.433	3.433	3.433	3.433	3.433
285	4.387	4.379	4.131	3.975	3.561	3.561	3.561	3.561	3.561	3.561	3.561	3.561	3.561	3.561	3.561	3.561	3.561
290	-	-	-	4.067	3.689	3.689	3.689	3.689	3.689	3.689	3.689	3.689	3.689	3.689	3.689	3.689	3.689
295	-	-	-	4.291	4.159	3.817	3.817	3.817	3.817	3.817	3.817	3.817	3.817	3.817	3.817	3.817	3.817
300	-	-	-	4.371	4.250	3.945	3.945	3.945	3.945	3.945	3.945	3.945	3.945	3.945	3.945	3.945	3.945
305	-	-	-	4.342	4.210	4.109	4.073	3.786	3.764	3.654	3.654	3.654	3.654	3.654	3.654	3.654	3.654
310	-	-	-	-	-	4.201	3.967	3.950	3.865	3.865	3.471	3.471	3.471	3.471	3.471	3.471	3.471
315	-	-	-	-	-	-	4.329	4.147	4.135	4.076	4.076	3.705	3.641	3.486	3.367	1.940	0.385
320	-	-	-	-	-	-	-	4.327	4.320	4.287	4.287	3.940	3.879	3.792	3.652		

Section Factor (m ⁻¹)	Table 42 Rectangular Hollow Beams 60 minutes																		
	Required Thickness (mm) for a Design Temperature (°C)																		
350	400	450	500	544	550	553	575	576	580	580	600	603	610	620	650	700	750		
40	1.322	0.547	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385		
45	1.421	0.667	0.426	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385		
50	1.520	0.787	0.512	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385		
55	1.619	0.907	0.597	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385		
60	1.717	1.026	0.683	0.419	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385		
65	1.816	1.146	0.769	0.479	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385		
70	1.915	1.266	0.854	0.540	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385		
75	2.034	1.386	0.940	0.601	0.410	0.410	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385		
80	2.241	1.506	1.025	0.662	0.524	0.524	0.524	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385		
85	2.449	1.626	1.111	0.723	0.638	0.638	0.638	0.468	0.458	0.415	0.415	0.385	0.385	0.385	0.385	0.385	0.385		
90	2.656	1.745	1.197	0.783	0.752	0.752	0.752	0.583	0.573	0.531	0.531	0.385	0.385	0.385	0.385	0.385	0.385		
95	2.863	1.865	1.282	0.866	0.866	0.866	0.698	0.688	0.647	0.397	0.385	0.385	0.385	0.385	0.385	0.385	0.385		
100	3.030	1.985	1.368	0.980	0.980	0.980	0.813	0.804	0.763	0.763	0.517	0.473	0.385	0.385	0.385	0.385	0.385		
105	3.099	2.122	1.453	1.094	1.094	1.094	0.928	0.919	0.878	0.878	0.637	0.593	0.481	0.385	0.385	0.385	0.385		
110	3.169	2.260	1.539	1.207	1.207	1.207	1.043	1.034	0.994	0.994	0.757	0.714	0.605	0.385	0.385	0.385	0.385		
115	3.238	2.399	1.625	1.321	1.321	1.321	1.158	1.149	1.110	1.110	0.877	0.835	0.728	0.483	0.385	0.385	0.385		
120	3.308	2.537	1.710	1.435	1.435	1.435	1.274	1.264	1.226	1.226	0.997	0.956	0.851	0.615	0.385	0.385	0.385		
125	3.378	2.675	1.796	1.549	1.549	1.549	1.389	1.379	1.341	1.341	1.117	1.077	0.974	0.746	0.385	0.385	0.385		
130	3.447	2.814	1.881	1.663	1.663	1.663	1.504	1.495	1.457	1.457	1.237	1.198	1.098	0.878	0.385	0.385	0.385		
135	3.517	2.952	1.967	1.777	1.777	1.777	1.619	1.610	1.573	1.573	1.357	1.319	1.221	1.009	0.385	0.385	0.385		
140	3.586	3.064	2.065	1.891	1.891	1.891	1.734	1.725	1.689	1.689	1.477	1.439	1.344	1.141	0.385	0.385	0.385		
145	3.656	3.156	2.169	2.005	2.005	2.005	1.849	1.840	1.804	1.804	1.597	1.560	1.468	1.272	0.385	0.385	0.385		
150	3.725	3.249	2.274	2.119	2.119	2.119	1.964	1.955	1.920	1.920	1.717	1.681	1.591	1.404	0.385	0.385	0.385		
155	3.795	3.341	2.378	2.232	2.232	2.232	2.079	2.071	2.036	2.036	1.837	1.802	1.714	1.595	0.544	0.385	0.385		
160	3.865	3.434	2.482	2.346	2.346	2.346	2.194	2.186	2.152	2.152	1.957	1.923	1.837	1.667	0.711	0.385	0.385		
165	3.934	3.526	2.587	2.460	2.460	2.460	2.309	2.301	2.268	2.268	2.077	2.044	1.961	1.798	0.877	0.385	0.385		
170	4.004	3.619	2.691	2.574	2.574	2.574	2.424	2.416	2.388	2.383	2.197	2.165	2.084	1.930	1.043	0.385	0.385		
175	4.073	3.712	2.795	2.688	2.688	2.688	2.539	2.531	2.499	2.499	2.317	2.285	2.207	2.061	1.210	0.385	0.385		
180	4.143	3.804	2.900	2.802	2.802	2.802	2.654	2.647	2.615	2.615	2.437	2.406	2.330	2.193	1.376	0.385	0.385		
185	4.213	3.897	3.004	2.916	2.916	2.916	2.769	2.762	2.731	2.731	2.557	2.527	2.454	2.324	1.542	0.385	0.385		
190	4.282	3.989	3.220	3.030	3.030	3.030	2.884	2.877	2.846	2.846	2.677	2.648	2.577	2.456	1.709	0.385	0.385		
195	4.352	4.082	3.443	3.144	3.144	3.144	2.999	2.992	2.962	2.962	2.797	2.769	2.700	2.588	1.875	0.385	0.385		
200	-	4.175	3.665	3.257	3.257	3.257	3.114	3.107	3.078	3.078	2.917	2.890	2.823	2.719	2.041	0.385	0.385		
205	-	4.267	3.887	3.371	3.371	3.371	3.230	3.223	3.194	3.194	3.037	3.011	2.947	2.851	2.208	0.385	0.385		
210	-	4.360	4.110	3.485	3.485	3.485	3.485	3.435	3.338	3.309	3.309	3.157	3.132	3.070	2.982	2.374	0.385	0.385	
215	-	-	-	3.623	3.599	3.599	3.460	3.453	3.425	3.425	3.277	3.252	3.193	3.114	2.540	0.385	0.385		
220	-	-	-	3.944	3.713	3.713	3.575	3.568	3.541	3.541	3.397	3.373	3.316	3.245	2.707	0.385	0.385		
225	-	-	-	4.265	3.827	3.827	3.827	3.690	3.683	3.657	3.657	3.516	3.494	3.440	3.377	2.873	0.385	0.385	
230	-	-	-	-	3.941	3.941	3.941	3.805	3.799	3.772	3.772	3.636	3.615	3.563	3.508	3.039	0.385	0.385	
235	-	-	-	-	-	4.055	4.055	3.920	3.914	3.888	3.888	3.756	3.736	3.686	3.640	3.206	0.385	0.385	
240	-	-	-	-	-	4.169	4.169	4.035	4.029	4.004	4.004	3.876	3.857	3.809	3.771	3.372	0.708	0.675	
245	-	-	-	-	-	4.338	4.283	4.150	4.144	4.120	4.120	3.996	3.978	3.933	3.903	3.538	1.210	0.984	
250	-	-	-	-	-	-	4.396	4.265	4.259	4.235	4.235	4.116	4.098	4.056	4.034	3.705	1.712	1.293	
255	-	-	-	-	-	-	-	4.380	4.374	4.351	4.351	4.236	4.219	4.179	4.166	3.871	2.213	1.602	
260	-	-	-	-	-	-	-	-	-	-	4.356	4.340	4.302	4.297	4.037	2.715	1.911	-	-
265	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	4.204	3.217	2.22	
270	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	4.370	3.718	2.529	
275	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	2.838	
280	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	3.147	
285	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	3.456	
290	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	3.765	
295	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	4.074	
300	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
305	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
310	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
315	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
320	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
325	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
330	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
335	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
340	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	

Thickness is intumescent only. Results apply to beams with concrete slabs with 3-sided fire exposure.

Section Factor (m ⁻¹)	Table 43 Rectangular Hollow Beams 75 minutes Required Thickness (mm) for a Design Temperature (°C)																
	350	400	450	500	544	550	553	575	576	580	580	600	603	610	620	650	700
40	1.648	1.001	0.586	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
45	1.788	1.178	0.734	0.436	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
50	1.927	1.355	0.882	0.553	0.427	0.427	0.389	0.387	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385	0.385
55	2.166	1.531	1.031	0.671	0.509	0.509	0.509	0.460	0.457	0.447	0.447	0.395	0.387	0.385	0.385	0.385	0.385
60	2.500	1.708	1.179	0.789	0.591	0.591	0.591	0.530	0.527	0.515	0.515	0.455	0.446	0.425	0.385	0.385	0.385
65	2.834	1.885	1.327	0.906	0.711	0.672	0.672	0.601	0.597	0.583	0.583	0.516	0.505	0.492	0.385	0.385	0.385
70	3.049	2.090	1.475	1.024	0.872	0.793	0.754	0.671	0.667	0.652	0.652	0.617	0.617	0.617	0.385	0.385	0.385
75	3.132	2.343	1.624	1.141	1.034	0.952	0.836	0.742	0.742	0.742	0.742	0.742	0.742	0.742	0.446	0.385	0.385
80	3.215	2.595	1.772	1.259	1.195	1.111	0.918	0.866	0.866	0.866	0.866	0.866	0.866	0.866	0.573	0.385	0.385
85	3.298	2.848	1.920	1.377	1.357	1.269	1.000	0.991	0.991	0.991	0.991	0.991	0.991	0.991	0.701	0.385	0.385
90	3.382	3.040	2.100	1.518	1.518	1.428	1.116	1.116	1.116	1.116	1.116	1.116	1.116	1.116	0.829	0.385	0.385
95	3.465	3.124	2.310	1.679	1.679	1.586	1.241	1.241	1.241	1.241	1.241	1.241	1.241	1.241	0.957	0.385	0.385
100	3.548	3.209	2.521	1.841	1.841	1.745	1.365	1.365	1.365	1.365	1.365	1.365	1.365	1.365	1.085	0.385	0.385
105	3.631	3.294	2.732	2.002	2.002	1.904	1.490	1.490	1.490	1.490	1.490	1.490	1.490	1.490	1.213	0.498	0.385
110	3.714	3.379	2.943	2.164	2.164	2.062	1.615	1.615	1.615	1.615	1.615	1.615	1.615	1.615	1.340	0.643	0.385
115	3.798	3.463	3.076	2.325	2.325	2.221	1.740	1.740	1.740	1.740	1.740	1.740	1.740	1.740	0.788	0.385	0.385
120	3.881	3.548	3.175	2.487	2.487	2.379	1.864	1.864	1.864	1.864	1.864	1.864	1.864	1.864	1.596	0.933	0.385
125	3.964	3.633	3.273	2.648	2.648	2.538	1.989	1.989	1.989	1.989	1.989	1.989	1.989	1.989	1.724	1.078	0.385
130	4.047	3.717	3.371	2.810	2.810	2.697	2.114	2.114	2.114	2.114	2.114	2.114	2.114	2.114	1.852	1.223	0.385
135	4.131	3.802	3.470	2.971	2.971	2.855	2.239	2.239	2.239	2.239	2.239	2.239	2.239	2.239	1.979	1.369	0.385
140	4.214	3.887	3.568	3.084	3.084	3.012	2.364	2.364	2.364	2.364	2.364	2.364	2.364	2.364	2.107	1.514	0.385
145	4.297	3.971	3.666	3.182	3.182	3.114	2.488	2.488	2.488	2.488	2.488	2.488	2.488	2.488	2.235	1.659	0.385
150	-	4.056	3.764	3.280	3.280	3.216	2.613	2.613	2.613	2.613	2.613	2.613	2.613	2.613	2.363	1.804	0.385
155	-	4.141	3.863	3.391	3.377	3.317	2.738	2.738	2.738	2.738	2.738	2.738	2.738	2.738	2.491	1.949	0.385
160	-	4.225	3.961	3.532	3.475	3.419	2.863	2.863	2.863	2.863	2.863	2.863	2.863	2.863	2.618	2.095	0.385
165	-	4.310	4.059	3.674	3.573	3.521	2.987	2.987	2.987	2.987	2.987	2.987	2.987	2.987	2.746	2.240	0.385
170	-	4.395	4.157	3.815	3.671	3.623	3.112	3.112	3.112	3.112	3.112	3.112	3.112	3.112	2.874	2.385	0.385
175	-	-	4.256	3.957	3.769	3.725	3.237	3.237	3.237	3.237	3.237	3.237	3.237	3.237	3.002	2.530	0.385
180	-	-	4.354	4.098	3.867	3.826	3.362	3.362	3.362	3.362	3.362	3.362	3.362	3.362	3.130	2.675	0.385
185	-	-	-	4.239	3.964	3.928	3.486	3.486	3.486	3.486	3.486	3.486	3.486	3.486	3.257	2.821	0.385
190	-	-	-	-	4.052	4.030	3.611	3.611	3.611	3.611	3.611	3.611	3.611	3.611	3.385	2.966	0.385
195	-	-	-	-	-	-	3.831	3.831	3.736	3.736	3.736	3.736	3.736	3.736	3.513	3.111	0.385
200	-	-	-	-	-	-	-	4.126	4.112	4.047	4.047	3.861	3.861	3.861	3.641	3.256	0.578
205	-	-	-	-	-	-	-	-	-	4.371	4.371	4.014	3.985	3.985	3.769	3.401	0.974
210	-	-	-	-	-	-	-	-	-	-	-	-	-	-	4.110	3.897	3.546
215	-	-	-	-	-	-	-	-	-	-	-	-	-	-	4.235	4.024	3.692
220	-	-	-	-	-	-	-	-	-	-	-	-	-	-	4.360	4.152	3.837
225	-	-	-	-	-	-	-	-	-	-	-	-	-	-	4.280	3.982	2.559
230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	4.408	4.127	2.955
235	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	4.272	3.352
240	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	3.748
245	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
250	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
255	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
260	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
265	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
270	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
275	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
280	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
285	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
290	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
295	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
300	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
305	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
310	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
315	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
320	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
325	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
330	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
335	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
340	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Thickness is intumescent only. Results apply to beams with concrete slabs with 3-sided fire exposure.

Section Factor (m ⁻¹)	Required Thickness (mm) for a Design Temperature (°C)																	
	350	400	450	500	544	550	553	575	576	580	580	600	603	610	620	650	700	750
40	1.974	1.456	1.012	0.662	0.536	0.536	0.536	0.492	0.489	0.478	0.478	0.420	0.410	0.385	0.385	0.385	0.385	
45	2.406	1.689	1.214	0.834	0.663	0.663	0.663	0.606	0.603	0.590	0.590	0.523	0.512	0.489	0.454	0.385	0.385	
50	2.872	1.923	1.415	1.006	0.791	0.791	0.791	0.720	0.717	0.702	0.702	0.626	0.614	0.587	0.548	0.429	0.385	
55	-	2.255	1.617	1.178	0.919	0.919	0.919	0.835	0.831	0.814	0.814	0.730	0.716	0.685	0.643	0.513	0.385	
60	-	2.632	1.818	1.350	1.047	1.047	1.047	0.949	0.944	0.926	0.926	0.833	0.819	0.782	0.737	0.596	0.385	
65	-	3.009	2.036	1.522	1.175	1.175	1.175	1.064	1.058	1.038	1.038	0.936	0.921	0.880	0.831	0.680	0.434	
70	-	-	2.364	1.694	1.303	1.303	1.303	1.178	1.172	1.150	1.150	1.039	1.023	0.977	0.926	0.763	0.497	
75	-	-	2.692	1.866	1.443	1.431	1.431	1.292	1.286	1.262	1.262	1.142	1.125	1.075	1.020	0.846	0.560	
80	-	-	3.012	2.064	1.591	1.559	1.559	1.407	1.400	1.374	1.374	1.245	1.227	1.172	1.114	0.930	0.623	
85	-	-	3.105	2.339	1.739	1.687	1.687	1.521	1.514	1.486	1.486	1.349	1.329	1.270	1.209	1.013	0.687	
90	-	-	3.197	2.614	1.887	1.825	1.815	1.635	1.627	1.598	1.598	1.452	1.431	1.367	1.303	1.097	0.750	
95	-	-	3.290	2.890	2.465	1.970	1.943	1.750	1.741	1.710	1.710	1.555	1.533	1.465	1.397	1.180	0.813	
100	-	-	3.383	3.066	3.066	3.032	3.022	2.127	1.864	1.855	1.822	1.822	1.658	1.636	1.562	1.492	1.263	0.876
105	-	-	3.475	3.167	3.149	3.116	3.116	2.349	1.979	1.969	1.933	1.933	1.761	1.738	1.660	1.586	1.347	0.939
110	-	-	3.568	3.267	3.232	3.199	3.199	2.571	2.166	2.148	2.082	2.082	1.865	1.840	1.757	1.681	1.430	1.002
115	-	-	3.660	3.368	3.314	3.283	3.283	2.793	2.365	2.346	2.277	2.277	1.968	1.942	1.855	1.775	1.514	1.065
120	-	-	3.753	3.469	3.397	3.366	3.366	3.012	2.564	2.545	2.471	2.471	2.122	2.076	1.952	1.869	1.597	1.129
125	-	-	3.845	3.570	3.480	3.450	3.450	2.763	2.743	2.665	2.665	2.294	2.245	2.091	1.989	1.724	1.192	1.165
130	-	-	3.938	3.670	3.563	3.534	3.534	3.257	2.962	2.941	2.859	2.859	2.466	2.414	2.261	2.114	1.852	1.299
135	-	-	4.030	3.771	3.645	3.617	3.617	3.379	3.117	3.103	3.043	3.043	2.638	2.583	2.431	2.258	1.979	1.432
140	-	-	4.123	3.872	3.728	3.701	3.701	3.502	3.259	3.246	3.190	3.190	2.811	2.753	2.601	2.415	2.107	1.566
145	-	-	4.216	3.972	3.811	3.784	3.784	3.624	3.401	3.388	3.337	3.337	2.983	2.922	2.771	2.573	2.235	1.699
150	-	-	4.308	4.073	3.894	3.868	3.868	3.746	3.542	3.531	3.485	3.485	3.165	3.101	2.941	2.731	2.363	1.833
155	-	-	-	4.174	3.976	3.951	3.869	3.684	3.674	3.632	3.632	3.348	3.293	3.137	2.888	2.491	1.966	1.966
160	-	-	-	4.275	4.059	4.035	3.991	3.825	3.817	3.779	3.779	3.532	3.484	3.349	3.072	2.618	2.100	2.100
165	-	-	-	4.375	4.142	4.118	4.114	3.967	3.959	3.927	3.927	3.715	3.675	3.562	3.344	2.746	2.240	2.234
170	-	-	-	-	4.236	4.236	4.236	4.109	4.102	4.074	4.074	3.899	3.866	3.774	3.615	2.874	2.385	2.367
175	-	-	-	-	4.307	4.285	4.358	4.250	4.245	4.222	4.222	4.083	4.057	3.987	3.886	3.002	2.530	2.501
180	-	-	-	-	-	-	-	-	-	4.369	4.369	4.266	4.248	4.199	4.157	3.130	2.675	2.634
185	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	3.690	2.821	2.768
190	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	2.966	2.901
195	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	3.706	3.082
200	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	3.461
205	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	3.840
210	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	4.219
215	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
220	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
225	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
235	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
240	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
245	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
250	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
255	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
260	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
265	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
270	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
275	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
280	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
285	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
290	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
295	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
300	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
305	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
310	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
315	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
320	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
325	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
330	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
335	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
340	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Thickness is intumescent only. Results apply to beams with concrete slabs with 3-sided fire exposure.

Section Factor (m ⁻¹)	Table 45 Rectangular Hollow Beams 105 minutes. Required Thickness (mm) for a Design Temperature (°C)																	
	350	400	450	500	544	550	553	575	576	580	580	600	603	610	620	650	700	750
40	2.832	1.910	1.439	1.064	0.878	0.878	0.878	0.817	0.813	0.801	0.801	0.734	0.724	0.699	0.658	0.523	0.385	0.385
45	-	2.354	1.693	1.287	1.049	1.049	1.049	0.972	0.968	0.953	0.953	0.877	0.865	0.836	0.792	0.650	0.399	0.385
50	-	2.860	1.948	1.509	1.220	1.220	1.220	1.127	1.122	1.105	1.105	1.019	1.007	0.972	0.927	0.776	0.508	0.385
55	-	-	2.364	1.731	1.391	1.391	1.391	1.282	1.277	1.258	1.258	1.162	1.148	1.109	1.061	0.902	0.616	0.385
60	-	-	2.816	1.953	1.579	1.561	1.561	1.437	1.431	1.410	1.410	1.304	1.290	1.246	1.196	1.029	0.725	0.385
65	-	-	-	2.311	1.775	1.732	1.732	1.592	1.585	1.562	1.562	1.447	1.431	1.383	1.330	1.155	0.833	0.456
70	-	-	-	2.699	1.972	1.918	1.903	1.747	1.740	1.714	1.714	1.589	1.572	1.520	1.465	1.281	0.942	0.677
75	-	-	-	-	3.013	2.728	2.145	1.902	1.894	1.867	1.867	1.732	1.714	1.656	1.599	1.407	1.050	0.897
80	-	-	-	-	3.095	3.073	2.469	2.114	2.098	2.041	2.041	1.874	1.855	1.793	1.734	1.534	1.159	1.118
85	-	-	-	-	3.178	3.155	2.794	2.414	2.397	2.335	2.335	2.036	1.998	1.930	1.868	1.660	1.338	1.338
90	-	-	-	-	3.260	3.238	3.043	2.713	2.696	2.628	2.628	2.307	2.265	2.136	2.010	1.786	1.559	1.559
95	-	-	-	-	3.343	3.320	3.143	3.010	2.994	2.922	2.922	2.579	2.533	2.406	2.265	1.913	1.779	1.779
100	-	-	-	-	3.426	3.403	3.243	3.114	3.107	3.082	3.082	2.850	2.801	2.676	2.520	2.074	2.000	2.000
105	-	-	-	-	3.508	3.486	3.343	3.217	3.211	3.187	3.187	3.054	3.093	2.947	2.776	2.301	2.220	2.220
110	-	-	-	-	3.591	3.568	3.444	3.321	3.315	3.291	3.291	3.163	3.143	3.095	3.019	2.527	2.441	2.441
115	-	-	-	-	3.673	3.651	3.544	3.424	3.419	3.396	3.396	3.272	3.253	3.206	3.135	2.754	2.661	2.661
120	-	-	-	-	3.756	3.734	3.644	3.528	3.522	3.500	3.500	3.381	3.362	3.317	3.252	2.981	2.882	2.882
125	-	-	-	-	3.839	3.816	3.744	3.631	3.626	3.604	3.604	3.489	3.472	3.429	3.368	3.121	3.048	3.048
130	-	-	-	-	3.921	3.899	3.845	3.735	3.730	3.709	3.709	3.598	3.581	3.540	3.484	3.249	3.140	3.140
135	-	-	-	-	4.004	3.982	3.945	3.838	3.833	3.813	3.813	3.707	3.691	3.652	3.600	3.378	3.232	3.232
140	-	-	-	-	4.087	4.064	4.045	3.942	3.937	3.917	3.917	3.816	3.800	3.763	3.717	3.506	3.324	3.324
145	-	-	-	-	4.169	4.147	4.145	4.045	4.041	4.022	4.022	3.924	3.910	3.874	3.833	3.634	3.417	3.417
150	-	-	-	-	4.252	4.246	4.246	4.149	4.144	4.126	4.126	4.033	4.019	3.984	3.949	3.762	3.509	3.509
155	-	-	-	-	4.334	4.312	4.346	4.252	4.248	4.230	4.230	4.142	4.129	4.097	4.065	3.890	3.601	3.601
160	-	-	-	-	-	-	4.356	4.352	4.335	4.335	4.251	4.239	4.208	4.182	4.019	3.693	3.693	
165	-	-	-	-	-	-	-	-	-	-	-	-	-	-	4.147	3.814	3.785	
170	-	-	-	-	-	-	-	-	-	-	-	-	-	-	4.275	4.007	3.877	
175	-	-	-	-	-	-	-	-	-	-	-	-	-	-	4.403	4.201	3.970	
180	-	-	-	-	-	-	-	-	-	-	-	-	-	-	4.394	4.062	-	
185	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	4.154	-	
190	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	4.246	-	
195	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	4.338	-	
200	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
205	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
210	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
215	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
220	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
225	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
235	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
240	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
245	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
250	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
255	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
260	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
265	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
270	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
275	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
280	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
285	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
290	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
295	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
300	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
305	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
310	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
315	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
320	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
325	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
330	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
335	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
340	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	

Thickness is intumescent only. Results apply to beams with concrete slabs with 3-sided fire exposure.

Section Factor (m ⁻¹)	Required Thickness (mm) for a Design Temperature (°C)																	
	350	400	450	500	544	550	553	575	576	580	580	600	603	610	620	650	700	750
40	-	2.691	1.865	1.467	1.221	1.221	1.142	1.138	1.123	1.123	1.049	1.038	1.011	0.972	0.844	0.578	0.385	
45	-	-	2.329	1.739	1.434	1.434	1.434	1.337	1.333	1.316	1.316	1.230	1.219	1.186	1.145	1.010	0.731	0.385
50	-	-	2.908	2.026	1.670	1.648	1.648	1.533	1.528	1.508	1.508	1.412	1.399	1.362	1.319	1.176	0.884	0.547
55	-	-	-	2.531	1.914	1.868	1.862	1.729	1.723	1.701	1.594	1.580	1.583	1.493	1.343	1.036	0.856	
60	-	-	-	-	2.772	2.542	2.157	1.924	1.917	1.894	1.894	1.776	1.760	1.713	1.667	1.509	1.189	1.164
65	-	-	-	-	-	2.586	2.252	2.237	2.183	2.183	1.957	1.941	1.889	1.840	1.675	1.472	1.472	
70	-	-	-	-	-	-	2.655	2.639	2.579	2.579	2.293	2.255	2.144	2.034	1.841	1.781	1.781	
75	-	-	-	-	-	-	-	-	2.976	2.976	2.668	2.627	2.518	2.392	2.089	2.089	2.089	
80	-	-	-	-	-	-	-	-	3.098	3.098	3.018	2.998	2.892	2.750	2.397	2.397	2.397	
85	-	-	-	-	-	-	-	-	3.195	3.195	3.115	3.103	3.076	3.086	2.706	2.706	2.706	
90	-	-	-	-	-	-	-	-	3.292	3.292	3.212	3.201	3.173	3.135	3.010	3.010	3.010	
95	-	-	-	-	-	-	-	-	3.389	3.389	3.309	3.298	3.271	3.233	3.108	3.086	3.086	
100	-	-	-	-	-	-	-	-	3.486	3.486	3.407	3.395	3.368	3.332	3.207	3.163	3.163	
105	-	-	-	-	-	-	-	-	3.583	3.583	3.504	3.492	3.465	3.430	3.306	3.239	3.239	
110	-	-	-	-	-	-	-	-	3.680	3.680	3.601	3.589	3.563	3.529	3.405	3.315	3.315	
115	-	-	-	-	-	-	-	-	3.777	3.777	3.698	3.687	3.660	3.627	3.504	3.391	3.391	
120	-	-	-	-	-	-	-	-	3.874	3.874	3.795	3.784	3.757	3.726	3.603	3.467	3.467	
125	-	-	-	-	-	-	-	-	3.971	3.971	3.892	3.881	3.854	3.824	3.702	3.544	3.544	
130	-	-	-	-	-	-	-	-	4.068	4.068	3.989	3.978	3.952	3.923	3.801	3.620	3.620	
135	-	-	-	-	-	-	-	-	4.165	4.165	4.087	4.076	4.049	4.022	3.900	3.706	3.696	
140	-	-	-	-	-	-	-	-	4.262	4.262	4.184	4.173	4.146	4.120	3.999	3.812	3.772	
145	-	-	-	-	-	-	-	-	4.359	4.359	4.281	4.270	4.244	4.219	4.098	3.917	3.848	
150	-	-	-	-	-	-	-	-	-	4.378	4.367	4.317	4.317	4.197	4.023	3.925	-	
155	-	-	-	-	-	-	-	-	-	-	-	-	-	4.296	4.128	4.001	-	
160	-	-	-	-	-	-	-	-	-	-	-	-	-	-	4.234	4.077	-	
165	-	-	-	-	-	-	-	-	-	-	-	-	-	-	4.339	4.153	-	
170	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	4.229	-	
175	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	4.305	-	
180	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	4.382	-	
185	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
190	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
195	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
200	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
205	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
210	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
215	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
220	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
225	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
235	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
240	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
245	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
250	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
255	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
260	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
265	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
270	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
275	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
280	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
285	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
290	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
295	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
300	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
305	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
310	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
315	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
320	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
325	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
330	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
335	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
340	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	

Thickness is intumescent only. Results apply to beams with concrete slabs with 3-sided fire exposure.

4.0 Direct field of application

- ⊕ This certificate relates to the use of FIRETEX® FX6010 for the fire protection of I and H shaped beam and column sections, rectangular / square hollow beam sections, and circular and rectangular / square hollow column sections.
- ⊕ The data presented in this certificate refers to both beams (3-sided fire exposure) and columns (four sided or surface exposure). Column results also apply to beams with four side fire exposure, as specified in the results.
- ⊕ The precise scope is given in section 2 of this certificate which shows the total dry film thickness of FIRETEX® FX6010 (excluding primer and topcoat) required to fire protect up to 120 minutes for I / H-section beams, circular hollow columns, rectangular / square hollow columns and beams, and up to 150 minutes for H-section columns, and steel temperatures in the range of 350°C to 750°C for various design temperatures and section factors.
- ⊕ The data shown are applicable to steel sections blast cleaned to AS 1627.9-2002, ISO 8501-1 SA2.5 or equivalent and primed with a suitable and compatible primer. Specifications of surface preparations, primers and top sealers are available from Sherwin-Williams UK Limited who's responsibility is to ensure that FIRETEX® FX6010 is compatible for use in respect of both ambient and fire conditions. The total dry film thickness of primer should not exceed that tested.
- ⊕ The data shown is applicable to FIRETEX® FX6010 applied by spray to horizontal, vertical, flexural and compression members supporting loads up to the maximum design loads specified in AS 4100:1998 (R2016). Specifications for other steel design temperatures are available from Sherwin-Williams UK Limited.
- ⊕ The dry film thickness of FIRETEX® FX6010 specified within this certificate must not vary. Changes in specification will affect the performance of the paint.
- ⊕ The product is approved on the basis of:
 - Approval testing in accordance with the principles of AS 1530.4:2014.
 - A design appraisal adopting the principles defined in AS 4100:1998 (R2016).

5.0 Accreditation

The Jensen Hughes FireMark Product Certification scheme operated by Jensen Hughes Fire Testing Pty Ltd is accredited by JASANZ as a Conformity Assessment Body providing Product Certification in the Jensen Hughes FireMark Scheme. Our scope is available on the JASANZ website at [JASANZ register](#).

6.0 Validity

Jensen Hughes does not endorse the tested or assessed product in any way. The conclusions of the results in this certificate may be used to directly assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all conditions.

Due to the nature of fire testing and the consequent difficulty in quantifying the uncertainty of measurement, it is not possible to provide a stated degree of accuracy. The inherent variability in test procedures, materials and methods of construction, and installation may lead to variations in performance between elements of

similar construction.

The assessed systems within this certificate are based on information and experience available at the time of preparation. The published procedures for the conduct of tests and the assessment of test results are subject to constant review and improvement. It is therefore recommended that this report be reviewed on, or before, the stated expiry date.

The assessed results represent our opinion about the performance of the proposed system/s expected to be demonstrated on a test carried out in accordance with the requirements of the referenced technical schedule.

The client has requested product certification for the specified product under the Jensen Hughes FireMark scheme for their own purposes, and this certificate has been prepared to meet the requirements of the relevant product technical schedule and any disclosed and agreed objectives reflected in the fee proposal. This certificate may be used as Evidence of Suitability in accordance with the requirements of the relevant National Construction Code. However, Jensen Hughes cannot guarantee the following:

- + Whether it will be accepted by the relevant building authorities and / or any other relevant parties.
- + The suitability of the system/s for a specific installation. This must be determined by the installer, builder and / or relevant building authority.

7.0 Authority

Applicant undertakings and conditions of use

Sherwin-Williams UK Limited confirms that:

- + To their knowledge the component or element of structure, which is the subject of the assessed results within this certificate, has not been subjected to a fire test to the standard against which assessment of this product is being made.
- + They agree to withdraw this certificate from circulation should the component or element of structure be the subject of a fire test by a test authority in accordance with the standard against which the assessed results are being made and the results are not in agreement with this certificate.
- + They are not aware of any information that could adversely affect the conclusions of the assessed results in this certificate and if they subsequently become aware of any such information, agree to ask the assessing authority to withdraw the assessment and subsequent product certificate.

General conditions of use

This certificate may only be reproduced in full without modifications by the report sponsor. Copies, extracts or abridgments of this certificate in any form must not be published by other organisations or individuals without the permission of Jensen Hughes Fire Testing Pty Ltd.

Appendix A - Overview of test / assessment evidence

Table 3 and Table 4 outline all the fire resistance test evidence and assessed configurations that form the basis of approval for the scope outlined in this certificate.

Table 3 Test Evidence

Number	Report number	Test sponsor	Test date	Testing authority
1.	FT12720 (FTR 108)	Sherwin-Williams	11-Jun-18	Sherwin-Williams, Bolton
2.	FT12723 (FTR 109)	Sherwin-Williams	13-Jun-18	Sherwin-Williams, Bolton
3.	FT12725 (FTR 110)	Sherwin-Williams	14-Jun-18	Sherwin-Williams, Bolton
4.	FT12729 (FTR 111)	Sherwin-Williams	18-Jun-18	Sherwin-Williams, Bolton
5.	FT12731 (FTR 112)	Sherwin-Williams	19-Jun-18	Sherwin-Williams, Bolton
6.	FT12734 (FTR 129)	Sherwin-Williams	21-Jun-18	Sherwin-Williams, Bolton
7.	FT12737 (FTR 113)	Sherwin-Williams	22-Jun-18	Sherwin-Williams, Bolton
8.	FT12740 (FTR 114)	Sherwin-Williams	25-Jun-18	Sherwin-Williams, Bolton
9.	FT12744 (FTR 115)	Sherwin-Williams	27-Jun-18	Sherwin-Williams, Bolton
10.	FT12751 (FTR 117)	Sherwin-Williams	2-Jul-18	Sherwin-Williams, Bolton
11.	FT12752 (FTR 118)	Sherwin-Williams	3-Jul-18	Sherwin-Williams, Bolton
12.	FT12754 (FTR 119)	Sherwin-Williams	4-Jul-18	Sherwin-Williams, Bolton
13.	FT12756 (FTR 126)	Sherwin-Williams	5-Jul-18	Sherwin-Williams, Bolton
14.	FT12761 (FTR 130)	Sherwin-Williams	6-Jul-18	Sherwin-Williams, Bolton
15.	FT12763 (FTR 121)	Sherwin-Williams	9-Jul-18	Sherwin-Williams, Bolton
16.	FT12765 (FTR 124)	Sherwin-Williams	10-Jul-18	Sherwin-Williams, Bolton
17.	FT12767 (FTR 123)	Sherwin-Williams	11-Jul-18	Sherwin-Williams, Bolton
18.	FT12773 (FTR 125)	Sherwin-Williams	13-Jul-18	Sherwin-Williams, Bolton
19.	FT12779 (FTR 127)	Sherwin-Williams	17-Jul-18	Sherwin-Williams, Bolton
20.	FT12789 (FTR 128)	Sherwin-Williams	23-Jul-18	Sherwin-Williams, Bolton
21.	FT12793 (FTR 131)	Sherwin-Williams	24-Jul-18	Sherwin-Williams, Bolton
22.	FT12795 (FTR 116)	Sherwin-Williams	25-Jul-18	Sherwin-Williams, Bolton
23.	FT12798 (FTR 120)	Sherwin-Williams	26-Jul-18	Sherwin-Williams, Bolton
24.	FT12801 (FTR 122)	Sherwin-Williams	27-Jul-18	Sherwin-Williams, Bolton

Number	Report number	Test sponsor	Test date	Testing authority
25.	FT12976 (FTR 136 Issue 2)	Sherwin-Williams	13-Nov-18	Sherwin-Williams, Bolton
26.	WF Gent No.18934A	Sherwin-Williams	23-Mar-18	Warringtonfire, Gent
27.	WF Gent No.19694A Issue 2	Sherwin-Williams	17-Jun-19	Warringtonfire, Gent
28.	WF Gent No.19695A	Sherwin-Williams	10-Jul-19	Warringtonfire, Gent
29.	WF Gent No.19946A	Sherwin-Williams	25-Sep-19	Warringtonfire, Gent
30.	WF No. 394855	Sherwin-Williams	7-Apr-18	Exova Warringtonfire, UK
31.	WF No. 394856	Sherwin-Williams	15-Apr-18	Exova Warringtonfire, UK
32.	WF No. 395159	Sherwin-Williams	9-Jun-18	Exova Warringtonfire, UK
33.	WF No. 395161	Sherwin-Williams	19-Jun-18	Warringtonfire, UK
34.	WF No. 395162	Sherwin-Williams	25-Jun-18	Exova Warringtonfire, UK
35.	WF No. 413500 Issue 2	Sherwin-Williams	23-Jun-19	Warringtonfire, UK
36.	WF No. 415692	Sherwin-Williams	4-Aug-19	Warringtonfire, UK
37.	WF No. 415693	Sherwin-Williams	20-Aug-19	Warringtonfire, UK

Table 4 Assessment evidence

Number	Report number	Assessed standard	Sponsor	Latest issue date	Authority
1.	FAS190187	AS 4100-1998 (R2016)	Sherwin-Williams	1 April 2020	Warringtonfire, AUS
2.	WF 409488	AS 4100-1998 (R2016)	Sherwin-Williams	17 March 2021	Warringtonfire, UK
3.	Issue 4	EN 16623:2015	Sherwin-Williams	17 August 2022	Warringtonfire, UK
4.	WF 521685	EAD 350402-00-1106	Sherwin-Williams	5 October 2022	Element Materials Technology Rotterdam B.V.