

- Read the IAQ
 Backgrounder and the Background Information for this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response
 requires further
 attention.)
 - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAO Coordinator.

Food Service Checklist

_			
N	Name: Timothy Noel		
- 1	school: BEAM Elen / Access HS - Ed Advonc		
R	Room or Area:Date Completed:	_	
S	signature:		
1.	COOKING AREA		
la.	avaagiraly mains)	No	N/
1b.	Checked for odors near cooking, preparation, and eating areas		
1c.	Ensured that exhaust fans are used whenever cooking, washing dishes,		
1d.	and cleaning		
le.			
1 f.	Ensured there are no combustion gas or natural gas odors, leaks, back-		
1	drafting, or headaches when gas appliances are used		
lg.	Ensured that kitchen is clean after use		
111.	the upper walls and ceiling (for example, mold, slime, and algae)		
1 i.	Selected biocides registered by EPA (if required), followed the		_
	manufacturer's directions for use, and carefully reviewed the		
1j.	wethod of application		
٠,٠	stains, discoloration, and damp areas)		
2	FOOD HARIDI ING AND OTODAGE		
2.	FOOD HANDLING AND STORAGE		
2a.	Checked food preparation, cooking, and storage areas for signs of insects		
2b.	and vermin (for example, feces or remains)		
20.	surfaces		
2c.	Ensured that food preparation, cooking, and storage practices are sanitary \(\mathbb{F} \)		
2d.	Disposed of food scraps properly and removed crumbs		
2e.	Cleaned counters with soap and water or a disinfectant (according to		
2f.	school policy)		
21.	Swept and wet mopped floors	U	
3.	WASTE MANAGEMENT		
3a.	Selected and placed waste in appropriate containers		
3b.	Ensured that containers' lids are securely closed		
3c.	Separated food waste and food-contaminated items from other wastes,		
3d.	if possible		
3e.	Ensured that dumpsters are properly located (away from air intake	L	
	vents, operable windows, and food service doors in relation to		

prevailing winds)

4.	DELIVERIES	Yes	No	N/A	T
4a.	Instructed vendors to avoid idling their engines during deliveries	🔼			
4b.	Posted a sign prohibiting vehicles from idling their engines in receiving areas				
4c.	Ensured that doors or air barriers are closed between receiving area and kitchen				






- Read the IAQ
 Backgrounder and
 the Background
 Information for
 this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response requires
 further attention.)
 - Make comments in the "Notes" section as necessary.
- Return the checklist portion of this document to the IAQ Coordinator.

Building and Grounds Maintenance Checklist

	ame: Timothy Noel			
Sc	chool: BEAM Ekm ACCESS HS - EdAdry.	,ce		
Ro	oom or Area: Date Completed:	5		
Si	gnature:	×		
1.	BUILDING MAINTENANCE SUPPLIES	V		B1 / A
1a	Developed appropriate procedures and stocked supplies for spill control		No	N/A
	Reviewed supply labels			
	Ensured that air from chemical and trash storage areas vents to	_		
	the outdoors	. 🗆		×
ld.	Stored chemical products and supplies in sealed, clearly labeled			
10	containers			
1f.	Ensured that supplies are being used according to manufacturers'		_	_
		M		
lg.	the second secon			
. 1	disposed of according to manufacturers' instructions			
1h.	(F)	1		
li.	Scheduled work involving odorous or hazardous chemicals for periods when the school is unoccupied	M		
lj.	Ventilated affected areas during and after the use of odorous or	Γ		-
	hazardous chemicals	. X		
•				
2.	GROUNDS MAINTENANCE SUPPLIES			
2a.	Stored grounds maintenance supplies in appropriate area(s)	. 🗆		X
2b.	Ensured that supplies are used and stored according to manufacturers'			•
2~	instructions	. Ц		7
20.	from supplies			X
2d.	Reviewed and followed manufacturers' guidelines for maintenance			Sp
	Replaced portable gas cans with low-emission cans			A
2f.	Stored chemical products and supplies in sealed, clearly-labeled			
2	containers	. 🗆		P
2g.	Ensured that chemicals, chemical-containing wastes, and containers are disposed of according to manufacturers' instructions	П		M
	anoposed of decorating to manufacturery monderations	_		
3.	DUST CONTROL			
3a.	Installed and maintained barrier mats for entrances	1		
3b.	Used high efficiency vacuum bags			
3c.	Used proper dusting techniques	X		

4a. Established	and followed schedule for vacuuming and mopping floors	-	-	N/A	
		10.0			
	lls on floors promptly (as necessary) restorative maintenance (as necessary)				
5. DRAIN T	RAPS				
	er down floor drains once per week (about 1 quart of water)				
	n sinks at least once per week (about 2 cups of water)ets once each week (if not used regularly)				
6. MOISTU	RE, LEAKS, AND SPILLS		,		
	r moldy odors	A			
	eiling tiles, floors, and walls for leaks or discoloration (may iodic leaks)	\$			
6c. Checked are	eas where moisture is commonly generated (e.g., kitchens, as, and bathrooms)	(
6d. Checked that	at windows, windowsills, and window frames are free of		_	L	
	at indoor surfaces of exterior walls and cold water pipes are	P .			
free of conc	lensate	×			
	following areas are free from signs of leaks and water damage: s near known roof or wall leaks	%			
	d leaky or broken windows				
	ceilings under plumbing				
Duct interio	rs near humidifiers, cooling coils, and outdoor air intakes	AT.			
7. COMBUS	STION APPLIANCES				
	odors from combustion appliances				
	pliances for backdrafting (using chemical smoke)				
	khaust components for leaks, disconnections, or deterioration				
/a. Inspected fl	ue components for corrosion and soot			\$	
8. PEST CO	NTROL				
8a. Completed	the Integrated Pest Management Checklist	X.			



- Read the IAQ
 Backgrounder and
 the Background
 Information for
 this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response
 requires further
 attention.)
 - Make comments in the "Notes" section as necessary.
- Return the checklist portion of this document to the IAQ Coordinator.

Waste Management Checklist

Name: Timothy Nocl
School: BEAM Elen / ACCESS HS - EdAdvance
Room or Area: Date Completed:
Signature:

1.	WASTE MANAGEMENT			
i		5	No	N/A
1a.	Ensured that waste containers are appropriate for use (for example, food waste containers should have lids)			
1b.	Ensured that waste containers are lined	1		
	Ensured that waste from art, science, vocational classes, etc., are			
	handled separately			S
1d.	Labeled recycling bins clearly	Ĵ		
1e.	Ensured number of bins and dumpsters is adequate)		
1 f.	Ensured appropriate location of dumpsters (i.e., away from air intakes,			
	doors, and operable windows in relation to prevailing winds)			
1g.	Ensured waste containers are emptied regularly			
1h.	Ensured appropriate waste removal schedule	,		
1 i.	Ensured waste is stored in a well-ventilated room	,		
1j.	Ensured any exhaust fans in the room are operating properly			
1k.	Checked waste storage areas for odors, contaminants, or signs of vermin			A
	, , , , ,			(



- Read the IAQ
 Backgrounder and the Background Information for this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 this checklist for
 each ventilation
 unit in your school,
 as well as a
 copy for future
 reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response
 requires further
 attention.)
 - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

Ventilation Checklist

N	lame: Timothy Noe!		
S	chool: BEAM Elem / ACCESS		
U	nit Ventilator/AHU No:		
R	oom or Area: Date Completed: 12/18/20		
S	ignature:		
1.	OUTDOOR AIR INTAKES		
la.	Marked locations of all outdoor air intakes on a small floor plan (for example, a fire escape floor plan)	No	N/A
1b.	Ensured that the ventilation system was on and operating in "occupied"	_	
	mode		
A(CTIVITY 1: OBSTRUCTIONS		
1c.	Ensured that outdoor air intakes are clear of obstructions, debris, clogs,		,
1d.	or covers		Ц
2 00.	frequently block an intake)		1
AC	CTIVITY 2: POLLUTANT SOURCES		
1e.	Checked ground-level intakes for pollutant sources (dumpsters, loading docks, and bus-idling areas)		*
1 f.	Checked rooftop intakes for pollutant sources (plumbing vents; kitchen,		,
	toilet, or laboratory exhaust fans; puddles; and mist from air-conditioning cooling towers)		
lg.	Resolved any problems with pollutant sources located near outdoor air		
	intakes (e.g., relocated dumpster or extended exhaust pipe)		M
	CTIVITY 3: AIRFLOW		
lh.	Obtained chemical smoke (or a small piece of tissue paper or light plastic)		A
11.	Confirmed that outdoor air is entering the intake appropriately		
2.	SYSTEM CLEANLINESS		
	CTIVITY 4: AIR FILTERS		
	Replaced filters per maintenance schedule		
26.	Shut off ventilation system fans while replacing filters (prevents dirt from blowing downstream)		
	Vacuumed filter areas before installing new filters		
2d.	Confirmed proper fit of filters to prevent air from bypassing (flowing around) the air filter		
2e.	Confirmed proper installation of filters (correct direction for airflow)		

2. SYSTEM CLEANLINESS (continued)

	TIVITY 5: DRAIN PANS			
2f.	Ensured that drain pans slant toward the drain (to prevent water from accumulating)		No	N/
	Cleaned drain pans			
2h.	Checked drain pans for mold and mildew	50		
	TIVITY 6: COILS			
2i.	Ensured that heating and cooling coils are clean	\$		
AC'	TIVITY 7: AIR-HANDLING UNITS, UNIT VENTILATORS			
2j.	Ensured that the interior of air-handling unit(s) or unit ventilator (air-mixing chamber and fan blades) is clean	∳		
2k.	Ensured that ducts are clean	🗚		
AC'	TIVITY 8: MECHANICAL ROOMS			
21.		🗖		×
2m.	Ensured that mechanical rooms and air-mixing chambers are free of trash, chemical products, and supplies	🗆		\$
3.	CONTROLS FOR OUTDOOR AIR SUPPLY			
3a.	Ensured that air dampers are at least partially open (minimum position)	*		
	Ensured that minimum position provides adequate outdoor air for occupants			
		·		
	TIVITY 9: CONTROLS INFORMATION			
3C.	Obtained and reviewed all design inside/outside temperature and humidity requirements, controls specifications, as-built mechanical drawings, and controls operations manuals (often uniquely designed)	-1		
AC'	TIVITY 10: CLOCKS, TIMERS, SWITCHES			
3d.	Turned summer-winter switches to the correct position	X		
3e.	Set time clocks appropriately	□		¥
3f.	Ensured that settings fit the actual schedule of building use (including night/weekend use)	🗆		₹
	TINUTE VIA CONTROL COMPONENTS			
	TIVITY 11: CONTROL COMPONENTS Engage de appropriete grutere processes by teating line processes at both the			
og.	Ensured appropriate system pressure by testing line pressure at both the occupied (day) setting and the unoccupied (night) setting	A		Г
3h.	Checked that the line dryer prevents moisture buildup			7
3i.	Replaced control system filters at the compressor inlet based on the			7
	compressor manufacturer's recommendation (for example, when you blow down the tank)	🗅		¥
3j.	Set the line pressure at each thermostat and damper actuator at the proper level (no leakage or obstructions)	\Z		
۸C	TIVITY 12: OUTDOOR AIR DAMPERS			
	Ensured that the outdoor air damper is visible for inspection	📉		
31.	Ensured that the recirculating relief and/or exhaust dampers are visible	,		
3m.	for inspection	-		_
NO	outdoor air damper is within the normal operating range	/		
11/1/1	THE THE PROPERTY TO OBSURE THAT THE COMPON IS OBORATION BY OBORING BY	TIPI TH		-CVI/11



NOTE: It is necessary to ensure that the damper is operating properly and within the normal range to continue.



3.	CONTROLS FOR OUTDOOR AIR SUPPLY (continued)			
3n.	Checked that the outdoor air damper fully closes within a few minutes of shutting off appropriate air handler		No	N/A
30.	Checked that the outdoor air damper opens (at least partially with no delay) when the air handler is turned on	,		
	If in heating mode, checked that the outdoor air damper goes to its minimum position (without completely closing) when the room thermostat is set to 85°F	. (24		
3q.	If in cooling mode, checked that the outdoor air damper goes to its minimum position (without completely closing) when the room thermostat is set to 60°F and mixed air thermostat is set to 45°F			
3r.	If the outdoor air damper does not move, confirmed the following items: • The damper actuator links to the damper shaft, and any linkage set screws or bolts are tight	. 🗆		₩.
	 Moving parts are free of impediments (e.g., rust, corrosion) Electrical wire or pneumatic tubing connects to the damper actuator 			A A
	The outside air thermostat(s) is functioning properly (e.g., in the right location, calibrated correctly)	. 🗆		本
	ceed to Activities 13–16 if the damper seems to be operating properly.			
	TIVITY 13: FREEZE STATS Disconnected power to controls (for automatic reset only) to test continuity across terminals			Pr.
3t.	Confirmed (if applicable) that depressing the manual reset button (usually red) trips the freeze stat (clicking sound indicates freeze stat was tripped)			*
3u.	Assessed the feasibility of replacing all manual reset freeze-stats with automatic reset freeze-stats			, 29 0
clos	TE: HVAC systems with water coils need protection from the cold. The freeze- te the outdoor air damper and disconnect the supply air when tripped. The ty ge is 35°F to 42°F.	-stat pical	may trip	
	TIVITY 14: MIXED AIR THERMOSTATS			
	Ensured that the mixed air stat for heating mode is set no higher than 65°F			M
3w.	Ensured that the mixed air stat for cooling mode is set no lower than the room thermostat setting			X
AC	TIVITY 15: ECONOMIZERS			
3x.	Confirmed proper economizer settings based on design specifications or local practices	X.		
NO	TE: The dry-bulb is typically set at 65°F or lower.	•		
	Checked that sensor on the economizer is shielded from direct sunlight Ensured that dampers operate properly (for outside air, return air, exhaust/relief air, and recirculated air), per the design specifications	•		
load Dry- and	TE: Economizers use varying amounts of cool outdoor air to assist with the call of the room or rooms. There are two types of economizers, dry-bulb and entended by the conomizers vary the amount of outdoor air based on outdoor temperal enthalpy economizers vary the amount of outdoor air based on outdoor temperal humidity level.	oolir halpy ture,	ig ∴	J


3. CONTROLS FOR OUTDOOR AIR SUPPLY (continued)

ACTIVITY 16: FANS 3aa. Ensured that all fans (supply fans and associated return or relief fans) Yes No N/A that move outside air indoors continuously operate during occupied hours (even when room thermostat is satisfied)...... NOTE: If fan shuts off when the thermostat is satisfied, adjust control cycle as necessary to ensure sufficient outdoor air supply. 4. AIR DISTRIBUTION **ACTIVITY 17: AIR DISTRIBUTION** 4a. Ensured that supply and return air pathways in the existing ventilation system perform as required..... 4b. Ensured that passive gravity relief ventilation systems and transfer grilles between rooms and corridors are functioning...... X NOTE: If ventilation system is closed or blocked to meet current fire codes, consult with a professional engineer for remedies. 4c. Made sure every occupied space has supply of outdoor air (mechanical system or operable windows) 4d. Ensured that supply and return vents are open and unblocked NOTE: If outlets have been blocked intentionally to correct drafts or discomfort, investigate and correct the cause of the discomfort and reopen the vents. 4e. Modified the HVAC system to supply outside air to areas without an outdoor air supply 4f. Modified existing HVAC systems to incorporate any room or zone layout 4g. Moved all barriers (for example, room dividers, large free-standing blackboards or displays, bookshelves) that could block movement of air in the room, especially those blocking air vents 4h. Ensured that unit ventilators are quiet enough to accommodate classroom 4i. Ensured that classrooms are free of uncomfortable drafts produced by air from supply terminals **ACTIVITY 18: PRESSURIZATION IN BUILDINGS** NOTE: To prevent infiltration of outdoor pollutants, the ventilation system is designed to maintain positive pressurization in the building. Therefore, ensure that the system, including any exhaust fans, is operating on the "occupied" cycle when doing this activity. Ensured that air flows out of the building (using chemical smoke) through windows, doors, or other cracks and holes in exterior wall (for example, 5. EXHAUST SYSTEMS **ACTIVITY 19: EXHAUST FAN OPERATION** 5a. Checked (using chemical smoke) that air flows into exhaust fan grille(s) If fans are running but air is not flowing toward the exhaust intake, check for the following: Inoperable dampers · Obstructed, leaky, or disconnected ductwork

· Undersized or improperly installed fan

· Broken fan belt






5. EXHAUST SYSTEMS (continued)

ACTIVITY 20: EXHAUST AIRFLOW

NOTE: Prevent migration of indoor contaminants from areas such as bathrooms, kitch and labs by keeping them under negative pressure (as compared to surrounding space	chens es).	<i>S</i> ,
5b. Checked (using chemical smoke) that air is drawn into the room from adjacent spaces	No	N/
Stand outside the room with the door slightly open while checking airflow high and let the door opening (see "How to Measure Airflow").	ow ii	1
5c. Ensured that air is flowing toward the exhaust intake		
ACTIVITY 21: EXHAUST DUCTWORK 5d. Checked that the exhaust ductwork downstream of the exhaust fan (which is under positive pressure) is sealed and in good condition		
6. QUANTITY OF OUTDOOR AIR		
ACTIVITY 22: OUTDOOR AIR MEASUREMENTS AND CALCULATIONS		
NOTE: Refer to "How to Measure Airflow" for techniques.		
6a. Measured the quantity of outdoor air supplied (22a) to each ventilation unit		
6b. Calculated the number of occupants served (22b) by the ventilation unit under consideration.		
6c. Divided outdoor air supply (22a) by the number of occupants (22b) to determine the existing quantity of outdoor air supply per person (22c)		
ACTIVITY 23: ACCEPTABLE LEVELS OF OUTDOOR AIR QUANTITIES		
6d. Compared the existing outdoor air per person (22c) to the recommended levels in Table 1		
6e. Corrected problems with ventilation units that supplied inadequate quantities of outdoor air to ensure that outdoor air quantities (22c) meet the recommended levels in Table 1		



- 1. Read the IAQ
 Backgrounder and the Background
 Information for this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes," "no," or "not applicable" box beside each item. (A "no" response requires further attention.)
 - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAO Coordinator.

Walkthrough Inspection Checklist

Name: Timothy Noel	
School: BEAM Elem /	ACCESS HS - Editedyance
Room or Area:	Date Completed: 12/18/25
Signature:	
organitate.	

1.	GROUND LEVEL	Yes	No	N/A
1a.	Ensured that ventilation units operate properly	Es.		
1b.	Ensured there are no obstructions blocking air intakes			
	Checked for nests and droppings near outdoor air intakes			
1d.	Determined that dumpsters are located away from doors, windows, and outdoor air intakes)		
le.	Checked potential sources of air contaminants near the building	. (
	(chimneys, stacks, industrial plants, exhaust from nearby buildings)			
1f.	Ensured that vehicles avoid idling near outdoor air intakes	\		
lg.	Minimized pesticide application	🞾		
lh.	Ensured that there is proper drainage away from the building (including roof downspouts)	\$		
1 i .	Ensured that sprinklers spray away from the building and outdoor			
	air intakes	🔾		×
lj.	Ensured that walk-off mats are used at exterior entrances and that they are cleaned regularly	≱		
2.	ROOF			
Wh	ile on the roof, consider inspecting the HVAC units (use the Ventilation Che	cklist).	
2a.	Ensured that the roof is in good condition	∀		
2b.	Checked for evidence of water ponding	•		
2c.	Checked that ventilation units operate properly (air flows in)	🛣		
2d.				
2e.	Ensured that air intakes remain open, even at minimum setting	🛣		
2f.	Checked for nests and droppings near outdoor air intakes	\$		
2g.	Ensured that air from plumbing stacks and exhaust outlets flows away from outdoor air intakes		П	
	nom outdoor an intakes			u
3.	ATTIC			
3a.	Provide the second seco			
3b.	Checked for birds and animal nests	× C		
4.	GENERAL CONSIDERATIONS			
4a.	Ensured that temperature and humidity are maintained within acceptable ranges	,		
	Ensured that no obstructions exist in supply and exhaust vents			
	Checked for odors			
4d.	Checked for signs of mold and mildew growth	1		

4.	GENERAL CONSIDERATIONS (continued)	Ves	No	N/A	
4e.	Checked for signs of water damage				
4f.	Checked for evidence of pests and obvious food sources				
4g.	Noted and reviewed all concerns from school occupants	Q			
5.	BATHROOMS AND GENERAL PLUMBING				
	Ensured that bathrooms and restrooms have operating exhaust fans Ensured proper drain trap maintenance:	. K			
	Water is poured down floor drains once per week (approx. 1 quart of water) 💢			
	Water is poured into sinks at least once per week (about 2 cups of water)				
	Toilets are flushed at least once per week	🎘			
6.	MAINTENANCE SUPPLIES				
6a.	Ensured that chemicals are used only with adequate ventilation and when				
	building is unoccupied	🏲			
6b.	Ensured that vents in chemical and trash storage areas are operating			£	
60	Ensured that portable fuel containers are properly closed			10	
	Ensured that power equipment, like snowblowers and lawn mowers, have	🛥	_	Fas	
ou.	been serviced and maintained according to manufacturers' guidelines	🗆		X	
7.	COMBUSTION APPLIANCES				
7a.	Checked for combustion gas and fuel odors	A			
7b.	Checked for combustion gas and fuel odors				
	Checked for leaks, disconnections, and deterioration				
	Ensured there is no soot on inside or outside of flue components			X	
8.	OTHER				
8a.	Checked for peeling and flaking paint (if the building was built before				
	1980, this could be a lead hazard)				
8b.	Determined date of last radon test	*			



- 1. Read the IAQ Backgrounder and the Background Information for this checklist.
- 2. Keep the Background Information and make a copy of the checklist for future reference.
- 3. Complete the Checklist.
 - · Check the "yes," "no," or "not applicable" box beside each item. (A "no" response requires further attention.)
 - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

Integrated Pest Management Checklist

N	Jame: Tinothy Noch			
S	chool: BEAM Elen ACCESS #5 - EdAd	Van	ce	
R	oom or Area: Date Completed:	ler		
S	ignature:			
1	OFFICIAL POLICY STATEMENT			
1.		Yes	No	N/A
la.	Developed or located the school's official policy statement for integrated pest management (IPM)	A		
2.	DESIGNATING PEST MANAGEMENT ROLES			
	Assigned and trained a qualified person to be the pest manager	A		
	Involved decision makers in the IPM program Educated students and staff (the occupants of the building) about IPM	. X		
	and asked them to keep their areas clean and free of clutter	. 🔊		
2d.	Encouraged parents to learn about IPM practices and implement them at home	\(\frac{1}{2}\)		
2e.	Developed a program to educate and train all IPM participants			
2f.	Included language about IPM into contracts with pest management professionals			
3.	SETTING PEST MANAGEMENT OBJECTIVES			
3a.	Set appropriate pest management objectives for school buildings (such as preventing pests from interfering with students' learning environment			
	and preserving the integrity of the building structure)	4		
3b.	Set appropriate pest management objectives for school grounds (such as providing safe playing areas and the best athletic surfaces possible)	\ \square		
	providing sare praying areas and the best atmetic surfaces possible)	. 4		_
4.	INSPECTING, IDENTIFYING, AND MONITORING			
4a.	Inspected all buildings and grounds for pest evidence, entry points,	ch.		
4b.	food, water, and harborage sites			
4c.	Pinpointed the source of any current pest problems			
4d.	Monitored to determine the extent of pest problems and to estimate pest populations	. 🔟		
4e.	Developed plans to modify habitat (for example, exclusion, repair, and			
4f.	sanitation efforts) to prevent or resolve any pest problems	. 2		
.1.	estimate pest population levels and identify evidence of pests and	10		
	potential habitat	. 💯		

5 .	SETTING ACTION THRESHOLDS			
5a.	aluated all available data obtained through inspecting, identifying,		No	N/A
5b.	Determined how many pests the school buildings, grounds, and	(
_	occupants can tolerate			
5c.	Set action thresholds		_	
6.	PREVENTIVE STRATEGIES			
	DOOR SITES			
6a.	Implemented appropriate strategies to prevent pests from inhabiting the fol			eas:
	• Entryways	4		u
	• Classrooms			U
	• Gymnasiums			₩
	• Locker rooms			A
	• Offices			
	• Staff lounges			
	• Bathrooms	1		
	Food preparation and serving areas	. 7		
	Rooms with extensive plumbing Maintenance areas	7		
	Maintenance areas	E		
	• Other	. 🎾		
ot	TDOOR SITES			
6b.	Implemented appropriate strategies to prevent pests from inhabiting the fol	lowir	ig ar	eas:
	Playgrounds	X L		
	Parking lots			
	Lawns and athletic fields			
	Teaching gardens or greenhouses			
	Loading docks	🏂		
	• Dumpsters			
	Areas with ornamental shrubs and trees			
	• Other			
7.	PESTICIDE USE AND STORAGE			
7a.	Explored alternative pest management methods before concluding that			
	pesticides were necessary	🕽		
7b.	Ensured that pest management professionals integrate IPM into their	4		
-	pest management methods	🕰	ч	
/c.	Identified the least toxic, target-specific chemical (or pesticide formulation) that is the most effective to address the pest problem,			
	preferably as baitsand granules	X	П	
7.4	Reviewed and followed all label instructions on pesticides and learned		-	-
/u.	how to properly apply and handle these chemicals	M		
70	Used spot-treatment (or bait, crack, and crevice applications) to apply	/	_	
70.	pesticides whenever possible and only treated the obviously infested			
	plants in the area			
7f.				X
7g.				
0	inaccessible to children and non-target species	🔾		X.





7.	PESTICIDE USE AND STORAGE (cont.)			
7h.	Locked or fastened lids of all bait boxes and placed bait away from the runway of the box		No	N/A
7i.	Applied pesticides when occupants were not present or in areas where they would not be exposed to the chemicals	A	۵	
7j.	upcoming positive approacions in ough positive	A		
7k.	unough tetters	×		
71.	easily accessible			A
	Stored pesticides off site or in areas that are locked and accessible only to designated personnel			×
	Ensured that storage areas are adequately ventilated and are located away from areas prone to flooding or where spills or leaks may contaminate the environment			*
7o.	Ensured that flammable liquids are stored away from ignition sources			×
7p.	Ensured that pesticides are stored in their original containers and all lids are securely fastened			A
7q.	Ensured that air in the storage space cannot mix with the air in the central ventilation system			A
8.	EVALUATING RESULTS AND RECORD KEEPING			
8a.	Ensured that accurate, up-to-date records of IPM practices and a pest management log for each property are kept	1		
8b.	board requirements are maintained	×		
8c.	Ensured that each log book contains the following items:	V/L		
	Copy of the pest management plan Service schedules for maintenance of buildings and grounds			
	Current EPA-registered labels			
	• Current Material Safety Data Sheets (MSDS) for each pesticide project			
	Pest surveillance data sheets Diagram noting the location of pest activity, traps, and bait stations	4		
	• Diagram noting the location of pest activity, traps, and balt stations	7		