

CERTIFICATE OF COMPLIANCE

Certificate Number 20151204-EX5138
Report Reference EX5138-19970728
Issue Date 2015-DECEMBER-04

Issued to: NOVA TUBE INC
5870 RUE ST-PATRICK
MONTREAL
QC H2A 3C3 CANADA

**This is to certify that
representative samples of**

METALLIC SPRINKLER PIPE ;
STEEL SPRINKLER PIPE

Schedule 10 pipe, sizes 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4,
5 and 6 in. Schedule 40 pipe, sizes 1/2, 3/4, 1, 1-1/4, 1-1/2,
2, 2-1/2, 3, 3-1/2, 4, 5 and 6.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 852 -METALLIC SPRINKLER PIPE FOR FIRE
PROTECTION SERVICE
ULC/ORD C199S LIGHT WALL STEEL PIPES FOR
SPRINKLER SYSTEMS FOR FIRE PROTECTION
SERVICE

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

